

A DESIGN FOR A SEWAGE TREATMENT
PLANT FOR THE TOWN OF
ELK RAPIDS, MICHIGAN

Thesis for the Degree of B. S.
MICHIGAN STATE COLLEGE

Paul T. Spelman—Raymond J. Kostecke
1949

THESIS

C.I

SUPPLEMENTARY MATERIAL IN BACK OF BOOK

MICHIGAN STATE UNIVERSITY LIBRARIES



3 1293 50023 4699

PLACE IN RETURN BOX to remove this checkout from your record.

TO AVOID FINES return on or before date due.

MAY BE RECALLED with earlier due date if requested.

DATE DUE	DATE DUE	DATE DUE
AUG 20 2009		

6/07 p:/CIRC/DateDue.indd-p.1

A Design for a Sewage Treatment Plant for the Town
of Elk Rapids, Michigan

A Thesis Submitted to
The Faculty of
MICHIGAN STATE COLLEGE
of
AGRICULTURE AND APPLIED SCIENCE
by

Paul T. Spelman

Raymond J. Kostecke

Candidates for the Degree of
Bachelor of Science

June 1949

THESIS

C.1

Acknowledgement

The authors wish to express their appreciation for the helpful advice and assistance of; Professor Frank R. Theroux and Professor Alfred Harle Leigh.

CONTENTS

Introduction	1-2
Preliminary Investigation.....	3-8
Manholes and Interceptor Lines.....	3-4
Flow Diagram.....	5
Secondary Settling	6
Aeration Tank	6
Clorination Tank	6
Wet Well	7
Primary Settling Tank	7
Digester	8
Sludge Drying Beds	8
Design	9-32
Main Tank Walls	9-11
Primary Tank	12-13
Primary Influent Channel.	14
Primary Scum Trough	15
Primary Effluent Channel.	16
Aerator and Clarifier.	17
Aerator Support Beam	18-19
Clorination Tank and Effluent Channel	20-21
Digester Tank Wall, Base and Roof	22-29
Walk Ways	30-31
Cantilever Wall for Wet Well and Comminutor. .	32
Conclusion	33
Illustrations found in folder on back cover.	

INTRODUCTION

The village of Elk Rapids Michigan, located in Antrim county in the north east section of the lower peninsula, has been in need of a sewage treatment plant for many years. The present wastes emptying into the east arm of Grand Traverse Bay contaminate over 2 miles of public sandy beach. This condition has forced the village health authorities to abandon the beautiful beach in front of the village park. The public bathing beach had to be located well over a mile up the bay.

The village is adverse to letting any industry, small or large, operate there. They would rather depend on tourist business for their livelihood than rely on other means. The existence of a desire for their type of business and an existence of a contaminated public beach is an inconsistency. The petty jealousy and strong desire to block progress on the part of the younger inhabitants tends to prevent the development of any industries. Therefore, to exist they need the tourists and to keep the tourists they need adequate sewage treatment.

With this in mind we decided to undertake the design of a treatment plant. The winter population is but 700. Knowing the attitude of the town, we do not expect this number to grow, more probably it will decrease. The summer population is 1500. This number has been increasing ever since 1920. This increase has not been uniform. There was a big spurt in 1929 and again in 1946. We estimate the

probable maximum population for the next 20 years at 2500 in the summer months.

In arriving at our design constants we looked into the water supply records. There is an average of 127,000 g.p.d. for the winter months. This would give about 180 gallons per capita per day. The piping in the system is old, so considering the high wastage and leakage the figure isn't too far out of line. The summer water records are of no value. With lawn sprinkling, cemetery sprinkling and 200,000 gallons per day to the cannery we could arrive at no definite amount that would enter the sewage system. A value was assumed of 100 gallons per capita per day, or 250,000 gal. per day.

To obtain B.O.D. values, samples taken from the present line would be of no value. The lines serve but 500 and the rate of infiltration more than equals the volume of the sewage. (Town Engineer's statement). Since the remaining lines will be new we expect very little infiltration. We took an average value of B.O.D. from 70 cities having a system and whose lines were less than 5 years old. The value of 200 p.p.m. B.O.D. was reached in this manner. A value of 200 p.p.m. was taken.

Allowance was made for the eventual introduction of a line from the eastern section of the village. The depth of the wet well will allow a drop of 6 ft. from the east side to the plant. Transite pipe will be used to maintain a good velocity flow to the plant.

Manholes and Interceptor Lines

The total sewage coming into our plant will be 250,000 gallons per day (G.P.D.). The west side of the village has 75% of the existing population. We do not believe this will change. The west side will therefore contribute 75% of the sewage or $.75 \times 250,000 = 187,000$ G.P.D..

The maximum flow expected will be 175% of the average because there are storm drains connected to the present system and during canning season the cherry pit wastes will enter the plant. $1.75 \times 187,000 = 328,000$ G.P.D. maximum. $328,000 + 24 \times 60 \times 60 \times 7.5 = .508$ cu. ft. per sec. at max. flow.

Referring to the map, we numbered the existing lines (1) to (3). No. one (1) being the westernmost line and number three (3) being the line coming from the block in front of the plant. The old line running from the cannery is to remain undisturbed. The cannery has ceased operating and will be removed soon.

Line # 1 will carry 20% of the west side total flow, or $.20 \times .508 = .102$ cu. ft. per sec.. Line # 2 will carry 75% of total west side flow or, $.75 \times .508 = .38$ cu. ft. per sec.. Line # 3 will carry 5% of total flow or, $.05 \times .508 = .025$ cu. ft. per sec.. These figures are based on assumed No. of people to be served.

At the present time all three lines empty directly into the river so special interceptor lines had to be installed to carry the sewer to the treatment plant.




Intercept line one (1) 200 ft. southwest of its outlet. The invert elevation of the intersection will be 585 ft. The lead off pipe leaving manhole # 2 and going toward man-hole # 3 will be an 8 inch pipe. The velocity when flowing full at a slope of .006 will be 2.6 ft. per sec.. The vol. when full is .9 cu. ft. per sec.. At .102 cu. ft. per sec. the velocity is 1.3 ft. per sec.. Distance to line # 2 is 315 ft. and the invert drop is 1.88 ft. Bearing from man-hole # 2 to manhole # 3 is $77^{\circ} 30'$ NE.

The 8 inch pipe enters manhole # 3 at an invert elevation of 583.11 ft.. The exit elevation of a 10 inch pipe is 583.01 ft.. The 10 inch pipe will have a slope of .008, a capacity of 1.9 cu. ft. per sec., velocity of 3.7 ft. per sec.. With a flow of .38 cu. ft. per sec., the velocity will be 2.75 ft. per sec.. Invert drop to diversion man-hole is 3.2 ft. Distance to manhole # 4 is 400 ft.. Bearing is N $52^{\circ} 15'$ E. Manhole # 4, entering invert 579.81 ft. and exit invert 579.81ft.

A special shut-off valve will be employed in manhole # 4 to divert the flow into the bay in case of a break down at the disposal plant.

Distance from manhole # 4 to wet well is 230 ft.. A 10-inch pipe will be used with a slope of .008. The vel. of a .815 cu. ft. per sec. flow is 2.8 ft. per sec. Invert at comminutor is 576.76 ft. A Chicago pump comminutor and by-pass bar screen is to be used before wet well. (See drawing of flow diagram on following page).

FLOW DIAGRAM



sludge. Figuring a draw off of twice a day we have 25 gal. of raw sludge. 25 gal. @ 95 % water = 500 gal.. $500 \div 7.5 = 66.7$ cu. ft.

Area of sludge hoppers (detailed in primary section) is 84.5 cu. ft.. This will allow twice a day draw off during summer and once a day during the winter months.

Secondary Settling

Secondary settling is accomplished in the aeration tank. The accompanying bulleten of the Chicago Pump Co goes into detail concerning their featuress.

Aeration Tank

After checking various types of aeration tanks we decided to use a Chicago Combination Aerator-Clarifier. This combination has been proven to be the most economical and efficient, with B.O.D. reductions as high as 98 %. This efficiency was of prime concern because the effluent from the clarifier is emptied into the bay on which is located a public bathing beach.

Two concrete tanks 25 ft. wide by 25 ft. long by 13 ft. 6 inches deep will be used as specified in "Bulletin 128-kl Chicago Pump Co." (Copy of the bulletin is attached) The maximum allowable flow rate through each clarifier in one day is 235,000 gal.

Clorination Tank


The volume of the clorination tank was found by a 20 minute detention period; $V = .508 \times 60 \times 20 = 600$ cu. ft. A tank 10 ft. long by 7 ft. wide by 11 ft. 9 inches deep.

Wet Well

Average flow = 10,400 gal. per hr.. Max. = 18,250 gal. per hr.. 8 min. flow = $18,250 \div 7.5 \times 60 = 324$ cu. ft.. The wet well will be pumped every 8 min. at a maximum flow. The volume of the wet well will be $18,250 \times 8 \div 7.5 \times 60 = 324$ cu. ft..

The pumps are to pump for 10 min. and will pump a total of 730 cu. ft., or 73 cu. ft. per min., or 550 gal. per min. against a head of 17 ft.. Two Yeomans 6MS4 @ 5 H.P. each will be used alternately to pump the sewer from the wet well. Six-inch cast iron pipes may be used to primary and 4-inch pipes for the rest of the system.

Dimension of Wet Well



Primary Settling Tank

Suspended solids = 200 P.P.M. Detention period of 1.5 hours for average daily flow. $250,000 \times 1.5 \div 24 \times 7.5 = 2080$ cu. ft.. Tank size = 19 ft. long x 10 ft. wide x 11 ft. deep = 2090 cu. ft.. Detention time for maximum flow = .86 hours. Volume of raw sludge @ 200 P.P.M. = 50 gal. raw


Digestor

To make the appearance of the sewer treatment plant symmetrical, and to utilize the west side of the digestor as one wall of the proposed fire house, we decided to design a rectangular shaped digestor. Many problems were encountered in the design of the digestor tank walls. However, after experimenting with various methods of design, we decided that the most economical would be to design the walls as cantilever walls. The tank was designed for capacity of 6 cu. ft. per capita. The tanks size is 26 ft. long by 25 ft. wide by 23 ft. deep giving a total volume of 15,000 cu. ft.. This is exactly what is needed to supply 6 cu. ft. per capita. $2500 \times 6 = 15,000$ cu. ft..

Sludge Drying Beds


The minimum area required per person for the sludge drying beds is about .5 sq. ft. per capita. (Water Supply and Sewage by Steel) We decided to be on the safe side and use an area of 1.3 sq. ft. per capita. The area needed will be, $2500 \times 1.3 = 3300$ sq. ft.. The size of the drying beds will be 55 ft. by 62 ft. giving us a total area of 3420 sq. ft..

Dimension of Sludge Drying Beds



MAIN TANK WALLS

Sheet W-1

Internal Pressure

$$\frac{13.5 \times 62.4}{2} \times 13.5 = 5,700 \#$$

$$M = 5,700 \times \frac{13.5}{3} \times 12 = 306,000 \text{ in-lbs.}$$

$$d = \frac{306,000}{359 \times 12} = 8.4 \text{ " say } 9 \text{ "}$$

$$A_s = \frac{306,000}{20,000 \times .842 \times 9} = 2.02 \text{ sq. in.}$$

$$\text{Use } 1'' \phi @ 4'' \text{ c/c } A_s = 2.37 = 9.4 \text{ in. } 1'' \phi @ 4'' \text{ c/c}$$

$$v = \frac{5,700}{12 \times .842 \times 9} = 62.5 > 60 \text{ but o.k.}$$

$$u = \frac{5,700}{9.4 \times 9 \times .842} = 80 < 150 \text{ o.k.}$$

Check u 10' from top. $S_s = 3120 \#$

$$u = \frac{3120}{4.7 \times 9 \times .842} = 88 < 150 \text{ o.k.}$$

Check u 8' from the top $S_s = 1950 \#$

$$u = \frac{1950}{2.35 \times 9 \times .842} = 110 < 150 \text{ o.k.}$$

Reduce to
1" Ø @ 8"
c/c
6' from
top

Reduce to
1" Ø @ 16"
4' from
top



External Steel

$$P' = \frac{13.5 \times 100}{2} \times .28 \times 13.5 = 2560 \text{ #}$$

$$P'' = 62.4 \times \frac{5}{2} \times 5 = 780 \text{ #}$$

$$\text{Sheer} = 3,340 \text{ #}$$

$$M = (3,340 \times 13.5 + 780 \times 1.67) 12 \\ = 195,600 \text{ in. lbs.}$$

$$A_s = \frac{195,600}{20,000 \times 9 \times .842} = 1.29 \text{ sq. in.}$$

$$\text{Use } \frac{3}{4"} \text{ o @ } 4" \text{ c/c } A_s = 1.32 \quad \zeta_o = 7.1$$

$$u = \frac{195,600}{7.1 \times 9 \times .842} = 37 < 150 \text{ o.k.}$$

Check u 11 ft. from the top.

$$u = \frac{1895}{3.6 \times 9 \times .842} = 70 \text{ o.k.}$$

Check u 9 ft. from the top.


$\frac{3}{4"} \text{ o}$
 $4" \text{ c/c}$

Reduce
to $\frac{3}{4"}$
 $@ 8" 8"$
from top

$$u = \frac{1140}{1.8 \times 9 \times .842} = 84 \text{ o.k.}$$

Walls having water on each side will have
internal reinforcement on each side.

Reduce
to $\frac{3}{4"}$
 $@ 16" 6"$
from top



Complete drawing of the primary tank will be found on separate sheet in folder in back of book.

Effluent, influent, scum troughs and sludge hopper sketches will be found on the following sheets.

Base to be 9" thick with a 3/4" ϕ @ 6" mesh located midway in slab. Hook into sidewalls, extend up into wall by waste sludge pit and bend down under wall by chlorination chamber.

Walls to have steel the same as all main walls. This steel is used to resist internal and external pressure.

Provide sludge and scum removing mechanism.

Provide pop off valve set to let go 300 lbs. per sq. ft..



Detention period of 1.5 hrs. of average daily flow.

$$\frac{250,000}{24} \times \frac{1.5}{7.5} = 2080 \text{ cu. ft.}$$

Tank size: 19 ft. long by 10 ft. wide by 11 ft. deep = 2090 cu. ft. o.k.

PRIMARY TANK


Sheet W-11





Sludge Hopper - Draw off to be
regulated by operator.

PRIMARY INFLUENT CHANNEL

Sheet W-1



Data



$$\text{Total wt. of channel} = 161 \times 150 = 350 \text{#/ft.}$$

$$350 \times 12 = 4200 \text{#}$$

$$\text{Wt. per wall} = 2100 \text{#}$$

$$\text{Unit wt. at wall} =$$


$$2100 \div 12 \times 17 = 10.4 \text{ psi.}$$

Provide wooden baffle 1' - 6" in front of openings.

PRIMARY SCUN TROUGH

Sheet W-1

Data



Design as 3 different beams:

Beam "A"

$3 - \frac{1}{2}'' @ 1\frac{1}{2}'' c/c$

$$M = \frac{1}{8} WL^2 = \frac{30}{8} \times 144 \times 12 = 6500 \text{ in.} \#$$

$$A_s = \frac{6500}{20,000 \times .866 \times 5} = .065 \text{ sq. in.}$$

$$v = \frac{360 + 4 \times .866 \times 5}{15} = 15 \text{ o.k.}$$

Beam "B"

$u = 360 \div 1.6 \times 5 \times .866 = 36 \text{ o.k.}$

$$M = \frac{1}{8} WL^2 = \frac{30}{8} \times 144 \times 12 = 6500 \text{ in.} \#$$

Beam "C"


$A_s = \frac{6500}{20,000 \times .866 \times 2.5} = 1.5 \text{ sq. in.}$

$$M = \frac{1}{8} WL^2 = \frac{280}{8} \times 144 \times 12 = 48,300 \text{ in.} \#$$

$$A_s = \frac{48,300}{20,000 \times .866 \times 12} = .232 \text{ sq. in.}$$



Use $3/4" \emptyset @ 2 3/4" c/c$

u and v o.k.



PRIMARY EFFLUENT CHANNEL


Sheet W-1



Elev. 592'- 0"

$\frac{1}{2}$ " Ø as noted

Elev. 590'- 3"



Elev. 590'- 6"

$\frac{1}{2}$ Ø @ 12" c/c

Side View
u and v o.k.

Provide 2' anchorage in wall for all $\frac{1}{2}$ " Ø bars.

4-3/4"
 ϕ @
4" c/c
in wall
away
from
the
trough
bend 3'
into
trough

AERATOR AND CLARIFIER

Sheet W-1


Data

Interior size = 25' x 25'

Dimension to follow specifications of manufacturer (Chicago Pump).


Walls - 1 ft. thick. Steel as prescribed in "Wall Steel" on sheets preceding.

Base - 6" slab 3/8" x 4" mesh- add 3/4" o @ 6" to 5' sq. center. Extend 3' for bond.



To top of base slab add 7/8" o @ 9" c/c.

Extend 3'-6" beyond deflection point and hook on short end.




To bottom of base slab extend steel resisting external pressure 3' beyond deflection point or 8' from wall.

Provide relief valve to go @ 300 p.s.f.

AERATOR SUPPORT BEAM

Sheet W-1

Data



$$M = 13.5 \times 4800 - 4 \times 1600 - 200 \times \frac{13.5^2}{2} \times 12 \\ = 482,400 \text{ in. lbs.}$$

Assume $b = 12$ $d = (\frac{482,400}{256} \times 12)^{\frac{1}{2}}$
 $= 13"$


$$v = 4800 \div 13 \times 12 \times .866 = 36 \text{ o.k.}$$

$$A_s = \frac{482,400}{20,000 \times 13 \times .866} = 2.14 \text{ sq. in.}$$

Use 6-3/4" Ø $A_s = 2.14$


6-3/4"
Ø

$$u = \frac{4800}{14.1 \times 13 \times .866} = 30 \text{ o.k.}$$



AERATOR SUPPORT BEAM

Sheet W-11



Data

Concrete slab in center to support a load of 1000 lbs.

$$M = 1000 \times 2 + 300 \times \frac{16}{8} = 2600 \text{ ft. lbs.}$$

$$d = (\frac{2600 \times 12}{236 \times 40})^{\frac{1}{2}} = 2.1 \text{ say } 4"$$

$$A_s = \frac{26,000 \times 12}{20,000 \times .866 \times 4} = .45 \text{ sq. in.}$$

Use $\frac{1}{2}$ " # bars spaced at 6" c/c from each end.
2-rows both ways.

$$v = \frac{800}{40 \times .866 \times 4} = 8 \text{ psi. o.k.}$$

$$u = \frac{800}{9.6 \times .866 \times 4} = 33 \text{ psi. o.k.}$$

Bearing Pressure on walls caused by the
two beams =


$$\frac{4800}{12 \times 12} = 33 \text{ psi. o.k.}$$

6- $\frac{1}{2}$ "
bars
3 each
side of
hole
hook
those
going
into
beam

CLORINATION TANK * EFFLUENT CHANNEL

Sheet W-1

Effluent weir to be the same as in primary tank. The exit opening will be in the center of the back wall. Trough will slope from sedes to center.



Beam to support grating use
4 x 8" beam.

Dead wt. = 34 lbs.
Grate = 175 "
L.L. = 50 "
Total = 159 lbs./ft.

5" down at
end drop 3"
per side
to 16" flat

liquid elev
590.6'

$$M = 1/8 WL^2 = \frac{159 \times 12^2 \times 12}{8} = 34,400 \text{ in. #}$$

$$A_s = \frac{34,400}{20,000 \times .866 \times 6} = .33 \text{ sq. in.}$$

2- $\frac{1}{2}$ " bars @
 $1\frac{1}{2}$ " c/c

$$v = \frac{1910}{.866 \times 6 \times 42} = 46 \text{ psi. o.k.}$$

$$u = \frac{1910}{2 \times .866 \times 6 \times 3.1} = 59 \text{ psi. o.k.}$$

Final effluent shall drop into a 16" x 16" well.

The sides of the well will have steel plates projecting 7" out spaced at 16". The well walls shall be concrete blocks. Anchors will be provided in concrete wall.

The clorination by pass shall consist of 2 pipes the same size as the clarifier effluent pipe.

Both shall lead directly to the effluent well and shall be connected to the clarifier effluent pipe by a B.F. Goodrich flexible rubber connector.

The pipes in the clorination tank shall be coated with a acid resistant material.

CLORINATION TANK

Sheet W-11

The clorination tank was designed for a 20 min detention.

The size of the tank is:

$$\frac{250,000}{24} \times \frac{.33}{7.5} \times 1.35 = 620 \text{ cu. ft.}$$

Make the tank 12' wide x 9' long x 11' deep.

In all walls use main wall steel. All walls are 12" thick.

Base is 12" thick. Place steel same as aerator clarifier except keep the 3/4" @ 6" c/c , 3" 3/4" o @ 6" c/c from top of slab. The steel is to run all the way across. Take steel resisting external pressure and run half way across tank to steel from opposite wall. Add sufficient steel to resist wall moments in top and bottom of slab.

DESIGN OF WALLS FOR DIGESTION TANK

Sheet W 1

Design data:

$$f_c' = 3000 \text{ psi}$$

$$f_c = 1350 \text{ psi}$$


$$v_c = 60 \text{ psi}$$

$$f_s = 18,000 \text{ psi}$$

$$u = 150 \text{ psi}$$

$$K = 248$$

$$\text{Soil P.} = 5000 \text{ psf}$$



Data

Tank Full

$$P = 62.4 \times \frac{23^2}{2} = 16500 \text{ lbs.}$$

$$M_{17} = 16500 \times 7.66 \times 12 = 1,516,000 \text{ in.}^{\#}$$

$$d = \frac{1,516,000^{\frac{1}{3}}}{248 \times 12} = 22.6 \text{ in. say 24 in.}$$

$$v = \frac{16500}{12 \times .875 \times 24} = 65 \text{ psi o.k.}$$

$$A_s = \frac{1,516,000}{18,000 \times .875 \times 24} = 4.0 \text{ sq. in./ft.}$$

1 sq in
3 in
c/c

$$M_{17} = 62.4 \times \frac{17^3}{6} \times 12 = 613,000 \text{ in.}^{\#}$$

$$A_s = \frac{613,000}{18,000 \times .875 \times 18} = 2.16 \text{ sq. in./ft.}$$

7/8 ϕ
3 in.
c/c

$$M_{17} = 62.4 \times \frac{12^3}{6} \times 12 = 216,000 \text{ in.}^{\#}$$

$$A_s = \frac{216,000}{18,000 \times .875 \times 12} = 1.14 \text{ sq. in./ft.}$$

5/8 ϕ
3 in.
c/c

$$M_6 = 62.4 \times 6^2 \times 12 = 27,000 \text{ in.}^{\#}$$

$$A_s = \frac{27,000}{18,000 \times .875 \times 12} = .143 \text{ sq. in./ft.}$$

1/4 ϕ
3 in.
c/c

$$u = \frac{16,500}{16 \times .875 \times 24} = 50 \text{ o.k.}$$

DESIGN OF WALLS FOR DIGESTOR TANK

Sheet W-II

TANK EMPTY:

Data: p_1 = Earth Pressure (Rankine) p_2 = Water Pressure(External)

$$P_1 = .28 \times 100 \times \frac{10^2}{2} = 1400 \text{ #}$$

$$P_2 = 62.4 \times \frac{5^2}{2} = 780 \text{ #}$$

$$M_1 = 1400 \times 3.33 \times 12 = 56,000 \text{ in. lbs.}$$

$$M_2 = 780 \times 1.67 \times 12 = \underline{15,600} \text{ "}$$

$$\text{Total} = 71,600 \text{ in lbs.}$$

$$A_s = \frac{71,600}{18,000 \times .866 \times 24} = .190 \text{ sq in/ft. } \frac{\frac{1}{2} \phi}{10" c/c} @$$

$$v = \frac{2180}{12 \times .866 \times 24} = 10 \text{ psi. o.k.}$$

$$u = \frac{2180}{1.9 \times .866 \times 24} = 52 \text{ psi. o.k.}$$

$$\text{Embedment: } L = \frac{18,000}{4 \times 150} = 30 \text{ in. } (\text{Hook Bottom & Top})$$

Temperature Steel:

$$.002 \times 12 \times 18 = .44 \text{ sq. in.}$$

$$\text{Front: } \frac{1}{2} \phi @ 9" c/c = .27 \text{ sq. in.}$$

$$\text{Back : } \frac{1}{2} \phi @ 12" c/c = .20 \text{ sq. in. } \text{Total} = .47 \text{ sq. in. o.k.}$$

Cut off steel as shown on sheets W- III
and W- IV.

Steel Data for Digestor Tank:

Sheet W-III

$1/2"$ sq. @ $3"$ c/c

0

3

8

12

18

23

$7/8"$ o @ $3"$ c/o

11'

5'

.40

$1"$ sq. @ $3"$ c/c

Cutting off Steel For Inside Wall

$1/2"$ o @ $10"$ c/c

8

13

18

23

5'

.30


$1/2"$ o @ $5"$ c/c

Cutting off Steel For Outside Wall



Design of Base for Digester Tank

Sheet W-1



Base steel: Use 1" sq. bars 3" c/c 3"
from top of slab. Cut steel to 1" sq. bars
6" c/c 6 ft. from each corner.

Base is to be 2 ft. thick at the corners,
and will taper off to 1 ft., 3 ft. from
the corners.

Hook steel as shown.


3" from bottom of base use $\frac{1}{2}$ " # bars @ 10"
c/c.

1" sq. @
3" c/c
Reduce to
1" sq. @
6" c/c
6' from
each
corner.

DIGESTOR ROOF

Sheet W-1

Data



$$\begin{aligned}
 \text{Slab } 5'' &= 62.5 \text{ #/sq. ft.} \\
 \text{Snow} &= 25 \text{ "} \\
 \text{L.L.} &= 50 \text{ "} \\
 \text{total} &= \underline{\underline{137.5}} \text{ "}
 \end{aligned}$$

Moments using 4" slab.

End span:

$$\begin{aligned}
 \text{Negative} = \text{D.L.} &= 62.5 \times 81 \times .04 = 202 \\
 \text{L.L.} &= 75 \times 81 \times .04 = 243 \\
 M &= \underline{\underline{445}}
 \end{aligned}$$

$$M = 445 \times 12 = 5330 \text{ in. lbs.}$$

$$\begin{aligned}
 \text{Positive: D.L.} &= 62.5 \times 81 \times .085 = 430 \\
 \text{L.L.} &= 75 \times 81 \times .105 = 638 \\
 M &= 1068 \times 12 = 12,800 \text{ in. lbs.}
 \end{aligned}$$

Mid span:

$$\begin{aligned}
 \text{1st. support: D.L.} &= 62.5 \times 81 \times .10 = 505 \\
 \text{L.L.} &= 75 \times 81 \times .120 = 730
 \end{aligned}$$

$$\text{Neg. M} = 1235 \times 12 = 14,800 \text{ in. lbs.}$$

DIGESTOR ROOF

Sheet W-11

Data

Positive Moment Mid-span:

$$D.L. = 62.5 \times 81 \times .03 = 152$$

$$L.L. = 75 \times 81 \times .08 = 485$$

$$M = 637 \times 12 = 7650 \text{ in. lbs.}$$

Steel Slab B:

$$A_s = \frac{7650}{20,000 \times .866 \times 2.5} = .177 \text{ sq. in.}$$

$\frac{1}{2}" \phi @ 8"$
bend up
every other

$$- A_s = \frac{14,800}{20,000 \times .866 \times 2.5} = .342 \text{ sq. in.}$$

from sup-
port. carry

$$v = \frac{617}{12 \times 2.5 \times .866} = 24 \text{ psi. o.k.}$$

neg. mom.
2' beyond
deflection

$$u = \frac{617}{2.5 \times .866 \times 3.1} = 92 \text{ psi. o.k.}$$

$\frac{1}{2}" \phi @ 16"$
over sup-
port

Slab A and C:

$$A_s = \frac{12,000}{20,000 \times .866 \times 2.5} = .295 \text{ sq. in.}$$

$\frac{1}{2}" \phi @ 8"$
c/c

$$- A_s = \frac{5330}{20,000 \times .866 \times 2.5} = .123 \text{ sq. in.}$$

$\frac{1}{2}" \phi @ 16"$
c/c

bend up
every other

$$v \text{ o.k.}$$

l'-10"
from the
support
hook all
end bars

$$u = \frac{617}{2.5 \times .866 \times 3.1} = 92 \text{ o.k.}$$


T - Beams to support roof.

$$\text{Sheer} = 137.5 \times 9 \text{ in. } \\ \times 13 = 16,000 \text{ #}$$

$$M = 137.5 \times 9 \times 26 \\ \times 26 \times \frac{12}{8} = 1,260,000 \text{ in. } \#$$

$$d = \frac{16,000}{12 \times .866 \times 90} = 17" \quad \text{use stirrups for} \\ 30 \text{ psi. in v.}$$

$$A_s = \frac{1,260,000}{20,000 \times 17 \times .866} = 4.30 \text{ sq. in.}$$



4-1" \square
@ 3" c/c

bend up
2 bars
6' from
wall.
Add 2-1"
 \square hooked
over
wall
extend
10' from
wall.

6- $\frac{1}{2}$ " \bullet
stirrup
@ 10"


Sheer taken by stirrups:

$$v = 32 \times 14 \times 22 \times .866 = 8520 \text{ lbs.}$$

Use $\frac{1}{2}$ " round stirrups taking 6200 lbs.

Space 6 @ 11 inches. Hook main bars.


At center place a flame arretor and manhole.




Add $\frac{1}{2}$ " \bullet @ 6" c/c 2' either side of hole
perpendicular to beams. Place $\frac{1}{2}$ " \bullet @ 4" c/c
8' long parallel to beam either side of hole.


Data

Supernatant overflow box:




Bend bars up end and carry 2'-6" into slab on each side.





Data



u is kept low because necessary embedment not available.

WALK WAYS

Sheet Wall

Data

-132	+132	-24.6	+246	-132	+132
+132	+ 66	- 64	- 66	-132	-132
0	- 45	-128	- 64	0	0
		+87.5	+175	+61.6	
		-22.8	-64.7	-32.4	
		+12.0	+24	+8.4	
		-3.1	-8.9	-4.9	
		+1.8	+3.6	+1.3	
		-.5	-1.3	-.7	
		+.3	+.5	.2	
		-.1	-.2		
		+126.5	-126.7	+126.7	-126.5
R ¹	R ²	R ³	R ⁴		

$$R^1 \times 30 \times 12 - 146 \times 30 \times 15 = 126,500 \\ R^1 = 2920 = R^4$$

$$R^2 \times 13 \times 12 - 2530 \times 43 \times 12 - 146 \times \frac{43 \times 2}{12} \\ R^2 = 2920 = R^3$$

$$A_s = \frac{126,500}{20,000 \times .866 \times 4} = 1.82 \text{ sq. in.} \\ 7/8" @ 4" both poss. and neg.$$

$$v = \frac{2530}{12 \times 4 \times .866} = 60 \text{ psi. o.k.}$$

$$u = \frac{2530}{8.3 \times 4 \times .866} = 88 \text{ pse. o.k.}$$

Provide hooks in bars @ R¹ and R².

Bend up every other bar, extend 3 ft. 6 in.
beyond inflection point.


CANTILEVER WALL FOR WET WELL AND COMMINUTOR

Sheet W-1

Data

$P_1 = 1950$ lbs. due to water.

$P_2 = 2590$ lbs. due to sand.



Sum of Moments Overturning:

$$4.16 \times 1950 + 2590 \times 6 = 24,000 \text{ ft. lbs.}$$

Sum of Moments Riding:

$$3040 \times .75 + 1900 \times 4.25 + 14,000 \times 5 = 80,000 \text{ ft. } \#$$

$$x = 18,940 \div \text{into } 56,350 = 3$$

$$e = 4.25 - 3 = 1.25 \text{ inches.}$$

$$p = \frac{18,940}{8.5} (1 - 6 \times \frac{1.25}{8.5}) = 4190 \& 270$$

$$M = 203,300 \text{ in. lbs.}$$

$$A_s = \frac{203,300}{20,000 \times .866 \times 15} = .78 \text{ sq. in.}$$

u and v o.k.

Base use $3/4"$ ϕ @ 5" c/c Hook under column



$3/4"$ ϕ @
5" c/c
reduce to
 $3/4"$ ϕ @
10" c/c
5' from
top


CONCLUSION

This thesis is not completely finished. The architectural drawings and fire house design are not completed. We had the fire house design finished along with the rest of the plant by the first of May. We then received a letter from the Chicago Pump Company saying the clarifier units we had designed for were carrying too heavy a load. Their latest findings had rerated the loadings downward. This threw out most of our work and consequently in the 3 weeks left we had to redo our entire thesis. There is enough work left in this paper to complete another senior civil engineering thesis. The firehouse design, cost estimate and complete drawings will take more time than our short six week time will allow.

This thesis, while it adds nothing to the worlds store of knowledge, had increased the sum total of our knowledge immeasurably. These design sheets are short but behind each is a series of trials and errors too. Each design was tried in numerous different ways untill we finally evolved the easiest and the most economical to build. Building codes and convention hampered us to some degree, but we do believe our design to be of the best.

12 Jun 59







TOP VIEW OF PROPOSED SEWER
TREATMENT PLANT FOR VILLAGE
OF ELK RAPIDS

Scale 1" = 5'

SHEET No 1







MICHIGAN STATE UNIV. LIBRARIES



31293500234699