

A DESIGN OF A SEWAGE SLUDGE
GAS COLLECTOR, AND A HOT
WATER HEATING SYSTEM FOR THE
EAST LANSING MICHIGAN
SEWAGE TREATMENT PLANT

Thesis for the Degree of B. S.

Clair A. Shaler

1936

THESIS

8-11

**SUPPLEMENTARY
MATERIAL
IN BACK OF BOOK**

Civil eng

Secretary engineering



3 1293 50023 4715

PLACE IN RETURN BOX to remove this checkout from your record.

TO AVOID FINES return on or before date due.

MAY BE RECALLED with earlier due date if requested.

DATE DUE	DATE DUE	DATE DUE
02 AUG 4 0 2009		

A Design of A Sewage Sludge Gas Collector, and A Hot Water
Heating System for the East Lansing Michigan
Sewage Treatment Plant

A Thesis Submitted to
The Faculty of
MICHIGAN STATE COLLEGE
of
AGRICULTURE AND APPLIED SCIENCE

By

Clair A. Shaler

Candidate for the Degree of
Bachelor of Science

June 1936


THESIS

copied

ACKNOWLEDGMENT

I wish to take this opportunity to thank Mr. Theroux for the advice he has given to me in regards to this Thesis.

C. A. S.



A view of the Imhoff tank

INTRODUCTION

The city of East Lansing Michigan and Michigan State College jointly constructed a sewage treatment plant in 1928 to care for the sewage from the city and the College. This plant consists of a bar rack, a pump station, and an Imhoff sewage treatment tank. A brick building houses the pump station and the bar rack.

The sewage flows through the Imhoff tank, during which time suspended solids settle to the bottom of the tank. These settled solids accumulate in the bottom part of the tank, and together with its contained water is known as sludge. This sludge is held in the tank for a period of several months. The organic solids of the sludge undergo digestion, during which process combustible gases, largely methane, are given off. At present these gases rise to the surface of the tank through four gas vents, and escape to the atmosphere. It is proposed to cover these gas vents and collect and utilize the gases. These gases when burned will be used to heat water, which will be circulated through radiators to heat the pump station. During the summer months the gas will be wasted by burning it in a waste burner.

A typical analysis of sewage sludge gas shows:

Methane	76.6%
Carbon Dioxide	14.7%
Nitrogen	8.2%
Oxygen	0.5%

Experience at other plants has shown that the amount of gas collected is from 0.36 - 0.44 cu. ft. per capita per day. The average is 0.40 cu. ft. per capita per day. On the basis of the present population this will amount to 3,520 cu. ft. per day, and on the basis of the year 1950 population this will amount to 5,380 cu. ft. per day. Corresponding heat values are 650 to 750 B. T. U. per cu. ft. of gas.

It will be shown later that the present estimated amount of gas is more than sufficient to heat the pump station building.

PROCEDURE

The design has the estimated population of 14,200 persons for the year 1950 as its' basis. The amount of gas produced is assumed to be 0.4 cu. ft. per capita per day. Using these assumptions the amount of gas produced will be 5,680 cu. ft. per day.

The four gas vents of the Imhoff tank will be covered with a 4" reinforced concrete cover, and each cover will be fitted with a gas collecting dome. In the outside gas vents the five pillars, which are spaced at regular intervals, extend from the surface of the tank to the top of the sludge hoppers. In order to construct the cover a section of the pillar will have to be removed. The underside of the ends of the covers will be built 1 foot below the level of the water surface in the flowing through chambers, and the highest point on the covers will be at the water level. The covers are sloped upward from the ends to the gas domes so the gas will collect at these points. The covers are below the water level so the scum will not rise to the surface of the water in the vents and form a hard mat. If the scum is kept wet it will settle to the sludge hoppers. To prevent clogging, a scum barrier made of boards set loosely is placed at the bottom of the gas domes.

In order to get a good bond between the old concrete, and the cover, a portion of the old concrete will have to be

removed. A strip of concrete 6" wide and 2" deep will be removed from each side of each vent along the line of the cover. The joint between the vent, and the cover will have to be water tight.

The gas collecting domes will be made of 3/8" steel plates. Details of the cover and of the dome are shown on the blue print.

The gas burner that will be used is a Basmor 25 - W - 6 boiler. This boiler has an input rating of 165,000 B. T. U. per hour and an output or available B. T. U. rating of 132,000 B. T. U. per hour. This boiler is made by the Premier Heater Division of the Crane Co. LaForte, Indiana.

There are three rooms that will require heat. They are ; the motor room, and the room adjoining, both of which are on the first floor; and the pump room, which is in the basement below the motor room.

The amount of radiation surface required in sq. ft. for each room was obtained by following the procedure given by H. A. Thrush and Co. of Peru, Indiana in Sweet's Catalog File for 1936. The temperature to be maintained will be 70 degrees Fahrenheit.

The size of the pipe used for piping the gas from the Imhoff tank to the burner will be 2" in diameter. The size of the pipe for the hot water flow to the radiators will be 2" and 1½" in diameter, and the return pipe to the boiler will be 2" in diameter. All sizes of pipe were taken from other designs.

DESCRIPTION OF THE LAYOUT

The gas which rises to the surface of the tank is collected in the gas collecting domes. The pressure due to the rising gas forces the gas in the domes through pipes 2" in diameter to the pump station. The gas goes through a condensate trap, and then a meter records the amount of gas produced. For safety measures the gas passes through a pressure relief and a flame trap. The pressure relief is connected to the waste burner which is placed outside of the building. From the flame trap the gas goes to the burner. The water which is heated to 180 degrees Fahrenheit is circulated through pipes 2" and 1½" in diameter to the radiators, and is returned to the boiler through pipes 2" in diameter by means of an electric circulating water pump.

A water tank is installed near the ceiling above the boiler to care for the expansion and contraction of the water being heated. A pipe is connected from the flow line to this tank. A two pen temperature recorder records the temperature of the flow to the radiators and the return water. A 10 foot chimney 10 inches in diameter is used to carry away the products of combustion.

CALCULATIONS

Gas Pipe from Gas Collecting Domes to Boiler

Formula from the Textbook,

Sewerage and Sewage Disposal by Metcalf and Eddy

page 638

$$S = \frac{1.352}{1,000} \frac{Q}{d} \sqrt{\frac{t}{4.573}}$$

S = drop in pressure per 1,000 feet of pipe in lb. per sq. in.

Q = cu. ft. of gas per minute

t = recorded temperature in degrees F + 459.6

p = gage pressure + 14.7

d = diameter of pipe in inches

Try d = 2" assume p = 20

$$S = \frac{1.352}{1,000} \times \frac{3.94}{20 \times 2} \sqrt{\frac{(70 + 459.6)}{4.573}}$$

$$S = 0.0105 \text{ lb. per sq. in./1,000 ft.}$$

The length of the gas pipe from the gas collecting domes to the boiler is 50 feet. Therefore the drop in pressure is,

$$S = 0.0005 \text{ lb. per sq. in.}$$

It is alright to use a pipe 2" in diameter, for the drop in pressure is less than 1.0 lb. per sq. in.

The drop in pressure in inches of water pressure is,

$$0.0005 \times 2.31 \div 12 = 0.000115 \text{ inches}$$

Small Room - size 30' x 9' x 12'

Heat loss through all exposed or cold surfaces.

Exposed wall - brick wall coefficient = 0.46

$30 \times 12 + 2(9 \times 12) - (7 \times 3)(\text{doors}) -$

$3(3 \times 3)(\text{windows}) = 523 \text{ sq. ft.}$

Loss per hour = $70 \times 0.46 \times 523 = 17,000 \text{ B. T. U.}$

Single window (3 x 3) - coefficient = 1.35

Loss per hour = $70 \times 1.35 \times 3(3 \times 3) = 2,550 \text{ B. T. U.}$

Ceiling - coefficient = 0.60

Loss per hour = $70 \times 0.60 \times (9 \times 30) = 1,133 \text{ B. T. U.}$

Floor - assume temperature in basement to be

45 degrees in zero weather

Temperature difference is 25 degrees (70 - 45)

Coefficient = 0.62

Loss per hour = $25 \times 0.62 \times (9 \times 30) = 4,190 \text{ B. T. U.}$

Door (3 x 7) - coefficient = 0.69

Loss per hour = $70 \times 0.69 \times (3 \times 7) = 1,012 \text{ B. T. U.}$

Air entering room by infiltration

Two air changes every hour

Volume of room = $30 \times 9 \times 12 = 3,240 \text{ cu. ft.}$

Coefficient = 0.033

Loss per hour = $70 \times 0.033 \times 3,240 = 7,150 \text{ B. T. U.}$

Total B. T. U. loss per hour = 34,035 B. T. U.

Pump Room - size 30' x 15' x 18'

Assume temperature to be 45 degrees in zero weather

Temperature difference is 25 degrees (70 - 45)

Concrete wall coefficient = 0.44

$$30 \times 15 + 2(15 \times 15) + 2(15 \times 30) = 2,070 \text{ sq. ft.}$$

$$\text{Loss per hour} = 25 \times 0.44 \times 2,070 = 22,800 \text{ B. T. U.}$$

Air entering room by infiltration

One air change every hour

$$\text{Volume of room} = 30 \times 15 \times 18 = 8,100 \text{ cu. ft.}$$

$$\text{Coefficient} = 0.009$$

$$\text{Loss per hour} = 25 \times 0.009 \times 8,100 = 1,820 \text{ B. T. U.}$$

$$\text{Total B. T. U. loss per hour} = 24,620 \text{ B. T. U.}$$

Radiation Requirements for Each Room

Using water with a temperature of 180 degrees F there will be a heat emission of 170 B. T. U. per hour from each sq. ft. of radiating surface.

$$\text{Motor Room} \quad 76,642 \div 170 = 451 \text{ sq. ft.}$$

$$\text{Small Room} \quad 34,045 \div 170 = 200 \text{ sq. ft.}$$

$$\text{Pump Room} \quad 24,620 \div 170 = 145 \text{ sq. ft.}$$

$$\text{Total radiating surface} = 796 \text{ sq. ft.}$$

$$\text{Total B. T. U. requirement per hour} = 135,297$$

GAS REQUIRED FOR HEATING

An estimate of the gas consumption following the procedure given by the Premier Heater Division, Crane Co., LaPorte Indiana.

With an average B. T. U. value of gas of 700, the amount of gas necessary for heating the water will be 0.1 cu. ft. per degree day per sq. ft. of radiation.

Detroit Michigan has 6,494 degree days

Grand Rapids Michigan has 6,534 degree days

Using the average value of these two cities the number of degree days for East Lansing Michigan would be 6,514.

The total radiation is 796 sq. ft.

Assume 210 heating days

Average cu. ft. of gas per day

$$\frac{6,514 \times 0.1 \times 796}{210} = 2,470$$

Approximately 3,000 cu. ft. of gas will be wasted in the year 1950, if the present type of treatment plant is still in use. On the basis of the present population of 8,801 persons, approximately 1,050 cu. ft. of gas will be wasted.

With an outdoor temperature of -10 degrees F and an inside temperature of 70 degrees F the amount of gas required is as follows:

difference in temperature, 80 degrees

Maximum consumption in cu. ft. per day

$$0.1 \times 80 \times 796 \times 0.875 = 5,575$$

At present there is available only 3,530 cu. ft. of gas per day. The temperature that can be maintained is:

$$\frac{3,530}{\frac{70}{27} \times 0.1 \times 786} = 17 \text{ degrees F}$$

ESTIMATED TOTAL COST

Basmor 25 - W - 6 Boiler	\$235.00 + freight (\$2.79)	\$237.79
Flame Trap		10.00
Pressure Relief		10.00
Condensate Trap		10.00
Wrought Iron Pipe		
233 ft. 2" diameter	C \$0.19	44.30
92 ft. 1½" diameter	C 0.12	11.05
20 ft. ¾" diameter	C 0.04	0.80
Globe Valve		
7 - 2"	C \$3.50	24.50
6 - 1½"	C 1.75	10.50
1 - ¾"	C 0.50	0.50
Tees		
7 - 2"	C \$0.50	3.50
4 reducers		
2" - 1½"	C 0.50	2.00
Elis 90 degree		
20 - 2"	C \$0.40	8.00
12 - 1½"	C 0.20	2.40
2 - ¾"	C 0.05	0.10
Radiators		
796 sq. ft.	C \$0.35	278.50

Gas Vent Covers 8.61 cu. yd. of concrete

Cement

5.36 bags per cu. yd. x 8.61 @ \$0.453 \$20.50

Fine Aggregate

0.534 tons per cu. yd. x 8.61 @ 1.20 6.03

Coarse Aggregate

1.17 tons per cu. yd. x 8.61 @ 1.30 15.15

Reinforcing Steel

3/8" ϕ wt. = 0.376 lb. per ft.

307 ft. @ \$2.20 per 100' 7.50

Lumber

2,000 ft. B. M. @ \$24.00 per 1,000 ft. B. M. 48.00

Gas Domes Steel Plates

77 sq. ft. wt. = 15.3 lb. per sq. ft. @ \$0.03 94.85

Carpenters

Assume 40 hours for job with 4 men

@ \$1.00 per hour 160.00

Common Labor

Assume 80 hours for job with 3 men

@ \$0.55 per hour 52.00

Extra Work


200.00

Total Estimated Cost

\$1,555.37

CONCLUSION

The amount of gas assumed to be generated is a minimum, also the coefficients used in determining the B. T. U. losses are conservative. Consequently on the coldest day there will probably be enough gas to maintain the desired inside temperature of 70 degrees F.




~~PERSON USE ONLY~~

125
125
TMS
Plan 1

MICHIGAN STATE UNIVERSITY LIBRARIES
3 1293 03149 8748

SUPPLEMENTARY MATERIAL



BOILER ROOM LAYOUT
EAST LANSING MICHIGAN
SEWAGE TREATMENT PLANT
SCALE 1"=1' CLAIR A. SHALER

MICHIGAN STATE UNIV. LIBRARIES



31293500234715