

THESIS

INVESTIGATION OF THE WATER
SUPPLY SYSTEM OF JACKSON, MICHIGAN
WITH RECOMMENDATIONS FOR
FUTURE IMPROVEMENTS

William C. Johnson Carl M. Waltz

1924

THESIS

Jackson, Mich. - Water - supply

LIBRARY
MICHIGAN STATE COLLEGE
OF AGRI. AND APP. SCIENCES

LIBRARY
MICHIGAN STATE COLLEGE
OF AGRI. AND APP. SCIENCES

INVESTIGATION OF THE WATER SUPPLY SYSTEM OF
JACKSON, MICHIGAN,
WITH RECOMMENDATIONS FOR FUTURE IMPROVEMENTS.

A Report Submitted to the Faculty
of
MICHIGAN AGRICULTURAL COLLEGE

By

William C. ^{Cooper}Johnson

Carl M. Waltz

Candidates for the Degree of
BACHELOR OF SCIENCE.

June, 1924.

THESIS

PART I.

INTRODUCTION.

PART II.

PRESENT SYSTEM.

PART III.

STUDIES AND ESTIMATES.

PART IV.

ELLA SHARP PARK PROJECT.

PART V.

RECOMMENDED PLAN.

PART VI.

TESTS ON SIX NEW WELLS IN LOSEY AVENUE.

PART I.

Introduction.

The investigation of the water supply system of Jackson, Michigan, was undertaken with the idea of showing just what the conditions are at the existing water works plant, and with a view of determining its adequacy and efficiency. It is proposed to criticise favorably or otherwise and to recommend improvements if they are deemed necessary.

Criticisms, recommendations and conclusions are based on references taken from treatises of good water supply methods as presented by recognized authorities. The authority in most cases being:

1. Public Water Supply, - Turneaure and Russell,
2. Hydraulics, - Hughes and Safford,
3. History of Jackson County, - G. A. Morton.

The authors wish to thank H. K. Vedder, Professor of the Civil Engineering Department, who permitted us to write a report on the "Water Supply System of Jackson, Michigan".

To Dr. Town of the Public Department of Health, Superintendent Hatch of the Water Works Department, and to Professor H. C. Woods of the M. A. C., gratitude is expressed for the helpful suggestions and time spent on this investigation.

History of Jackson Water Works.

During the early days, the people of Jackson Michigan obtained their supply of water from the Grand River. But as this water was very poor for drinking purposes, a meeting of the Citizens was called in December of 1869 for the purpose of voting a sum of money for the construction of a system of water works. The result of this meeting was the formation of a company to take the enterprise in hand, as the charter terms opposed such an investement on the part of the city. During March and April of the year 1870 contracts were made for engines, pipes, hydrants, machinery and buildings. The erection of the water works house was begun April 26 1870 and finished August 1, 1870. At this time the water was taken from the Grand River and passed through large filters. But some time about 1890 steps were taken to obtain the supply of water from the ground.

The first wells that were drilled yielded a supply of water under a head sufficient to cause over flow at ground surface. And at this time these wells were connected direct to the suction lines of the main pumps. After a short period of use the ground water head was considerably depressed, however, so much that additional wells were found necessary. Within a few years following the first drilling, the level of the ground water continued to be depressed to such an extent, that it was found necessary to construct a suction well from which the pumps might draw their supply, and into which the several drilled wells might be discharged through siphonic action. At varying intervals up to the present time, there have appeared recurring evidences of the gradual and steady depression of the ground water table in the vicinity of the Municipal Water Works. In 1901 a pump was installed on the siphon lines to increase the yield; in 1916 a storage reservoir of about 50,000,000 gallons capacity was built to carry the peak loads of the plant; in 1917 & 1918 an additional supply was developed in the area south of the Grand River and west of Losey Avenue.

By the establishment of these water-works the city has been singularly benefited. A supply of artesian water is brought into the very homes of the people, and hydrants at regular intervals are ready to offer opposition to the fire fiend. This artesian water is known to be of the very best quality and is said to equal that which is obtained from the celebrated artesian wells of Europe. But through out the years since the first construction was undertaken, there appears never to have been a time, when there was assured an adequate supply of water for any great time in the future.

PART II.

Description of Present Plant.

The present high-service plant is located on the small strip of land lying between the Grand River and Water street. An area of approximately 2.25 acres in extent. The engine house is built of brick and was designed by J. F. Coots. It is rectangular in shape being 76 feet long and 56 feet wide. It is 20 feet high with a tower 45 feet, rising from the main building, and close by the lofty octagonal chimney shaft rising to a height of 78'. The roof is a mansard, slated and tastefully ornamented after the french style of architecture. Adjacent to the main building we have the suction well and the $\frac{1}{2}$ million gallon reinforced concrete reservoir built in 1916.

The machinery comprises one 6 Mil. gal. per. da. Holly Gaskell pumping engine; one 10 Mil. gal. per. da. Holly Gaskell pumping engine; and one 8 Mil. gal. per. da. Snow pumping engine. The boiler equipment consists of two batteries of two boilers each, with usual auxiliaries, such as boiler feed pump, air pumps, etc.

The design of the three engines is to vary the supply of water according to the demand, only two being needed for the ordinary supply, and the other in case of fire. An extra supply is commanded by simply opening a hydrant and be it ever so far away, this action acts automatically on the machinery, giving fresh impetus to the pumps, supplying the increased force necessary for the extra flow in a few seconds. At the same time an alarm is sounded to warn the engineer, so that the accessory engine may be set in motion. The water is forced through a 24 inch main, and thence through smaller pipes leading to the less populous districts of the city.

Losey Avenue Pumping Station.

The recent constructed low service pumping station near Losey Avenue, consists of a brick and concrete building, 18 feet square, and extending to a depth of approximately 15 feet below the ground surface and having one story above ground. This station house at present has a 12 inch motor driven centrifugal pump. To this pump is connected the suction line from four 12 inch drilled wells in the adjacent area. The water from these wells is lifted and pumped through a 20 inch wooden force main into the receiving well at the main pumping station.

General Character and Condition of Existing Plant.

Practically all of the equipment at main pumping station, with exception of Snow pumping engine is in a very depreciated condition. The two Holly pumping engines, have expended practically all of their useful life and little justification can be found for their further operation. The Snow pumping engine is a comparatively new piece of machinery, and has evidently been well handled, as it appears to be in excellent condition. The advance in the art of pumping stations and the design of pumping equipment, alone has rendered many of the elements of the old plant obsolete, even if they were not worn out. The available area at the site of the main pumping plant is so limited, that there is no opportunity at this site for an expansion, such as will be necessary in order to furnish the city of Jackson a sufficient water supply in future years.

Geological Considerations Affecting Ground Water.

It has been stated by some investigators, that the municipal supply of the city of Jackson is drawn from the Marshall sandstone stratum underlying this region. A careful study of geological records indicate that this is probably not the case, however, as it is generally accepted that the Marshall sandstone under Jackson is found at a depth of somewhere around 1,000 feet. While the municipal wells are in general drilled to a depth of about 350 feet. It is more probable that the city supply is taken from the Parma sandstone stratum. It may be possible that the water originally comes from the Marshall sandstone, and is forced by artesian head into wells which reach only into the overlying formations. It is probable that the catchment area for the water which reaches these wells, is in the table lands lying south of Jackson some 25 to 30 miles, and that the ground water flow is general from south to north.

Present Development of Ground Water Supplies in Jackson.

Drawing number I. of this report is a map of the location of some of the larger water supplies, which are taken from the ground in the city of Jackson. A number of the industrial plants in city depend almost entirely upon this source for their boiler supply. It will be noted that most of the wells are located along the course of the Grand River, and it is possible that some of the supplies are taken from the ground water flows in the drift, comparatively near the surface. Others of the supplies, however, go down several hundred feet and draw their water from the underlying rock formation. It has been estimated that the normal amount of water taken from the ground by private supplies, independent of the municipal water works system, will reach a total of about 3 Mil. gal. per. da. This is a little more than half the amount used by the municipal supply on the average day of the year. On reference again to the map it will be noted that some of the municipal wells (indicated in black) are located well within the area, in which are many of the large private supplies. The private wells are shown in red. At the present time there is noted a marked interference between these supplies. During certain pumping tests which were made some four or five years ago, at which time the city was drawing heavily from the ground water strata, a number of private well supplies failed entirely. Others of them were very noticeably reduced. The general lowering of the ground water table, due to heavy pumping of municipal wells, broke the suction in some plants, where the equipment was not arranged for such deep pumping.

It is very apparent from a consideration of the facts at hand, that if the city attempts to develop the ground water supply near the present main pumping plant by air lift pumping or any other means, which will further lower the ground water table. It will result in the failure of many of the large private supplies now in use in the city. It appears to be incontrovertible that the central area of the city is at the present time almost completely developed so far as ground water is concerned.

NO. 1

MAP OF
JACKSON'S WATER SUPPLY
SHOWING
WELLS AND STATIONS

N



MILL POND

LOSEY AVENUE
PUMPING STATION

● PRIVATE WELLS



Available Sources of Supply.

There is no question concerning the fact that the city of Jackson must by some means develop a more adequate and dependable water supply. The present wells could probably be made to yield a slightly greater quantity than is at present drawn from them, by air lifting or some other means, which would cause a further depression of the ground water table. The amount of water which could be obtained by any such method however, would not justify the effort.

There are two possible sources of water supply which are available. The ground water supply at and near the city of Jackson is by no means depleted, even though there may be a local depression in the immediate area of present development. There is also a possibility of developing a supply from the many available lakes, streams and other surface sources near the city. Through a carefully designed and properly operated filter plant, a water supply from the latter sources would prove entirely satisfactory for municipal use.

The area in and around Jackson is underlain with water bearing strata, which can be made to yield great quantities of water of fairly good quality, although containing a considerable amount of iron. This abundance of ground water has led to a development of supplies from this source to a rather unusual extent.

Water Main Construction in Jackson Michigan.

From the available data shown below, and attempt has been made to show by graph, the number of miles of water mains constructed each year in the city of Jackson. Also along with this, the total number of miles of mains up to and including last year. The first water mains were laid in the year 1870 but no complete record for the numbers of miles of mains laid each of the preceding years up to the year 1908. But the total number of miles of mains laid was shown to be 67.2 miles. Below is shown the number of miles of mains laid each year from 1908-1924. Also the total number of miles which is 117.156.


| Years. | Miles of mains constructed Each year. |
|--------|--|
| 1908 | 3.00 |
| 1909 | 2.78 |
| 1910 | 4.25 |
| 1911 | 2.60 |
| 1912 | .50 |
| 1913 | 4.25 |
| 1914 | 2.72 |
| 1915 | 2.10 |
| 1916 | 8.50 |
| 1917 | 2.30 |
| 1918 | 2.60 |
| 1919 | .636 |
| 1920 | .89 |
| 1921 | .56 |
| 1922 | 2.00 |
| 1923 | 5.07 |

From an investigation of the graph it is seen that very little construction work was done during the years 1919,-1920-1921. This was just at the closing part of the world war when there was little growth in the city of Jackson. And at that time labor and the material for construction work were very expensive. But in 1922 construction work began to pick up a little and in 1923 a total of 5.07 miles of water mains were lain. In 1924 there will probably be still a greater number of mains constructed because of the extension of the city limits of Jackson and also due to the new reservoir and pumping station which is now under construction.

Size of Mains.

| Length of 4" | 131,543 Ft. | 24.91 Miles. |
|--------------|-------------|--------------|
| " " 6" | 374,908 F | 71.10 " |
| " " 8" | 26,666 " | 5.05 " |
| " " 10" | 34,870 " | 6.60 " |
| " " 12" | 44,444 " | 8.41 " |
| " " 16" | 3,040 " | .575 " |
| " " 18" | 300 " | .057 " |
| " " 20" | 2,020 " | .387 " |
| " " 24" | 380 " | .072 " |

MILES OF MAINS



Prior to the year 1904, a great many services had been installed in the city of Jackson. But the per cent of these services that were metered were surprisingly small, which was due to the fact that it was not compulsory. But beginning with the year 1904, an attempt was made to meter all services, which prior to this year was supplying water to the consumers free of charge. This has been a very difficult task, but at the present time it is estimated that the percent of services, which have been metered is about 99.8%. The curves on the following page indicate how rapidly the work of installing meters in all buildings and factories has been carried out. The effect of this compulsory metering of all services upon water consumption reveals the very interesting fact that metering has so reduced the consumption of water, that the present water supply has served at least ten years longer than it would otherwise have done.


At the present time there are eleven different kinds of meters used in the city of Jackson. The Artic has gained the most favor and is the only one which is now being installed by the Water Department. The other meters in use are the Hersey, Worthington, Crown, Gem, Keystone, Thompson, Empire, Tryden, Lambert and the Niagara. The greater part of these meters are either 5/8" or 3/4" in size. There is one 6" Keystone and several 2", 3", and 1 1/2" meters in use at the present time

Services and Percent Metered.

| Year | Total | Metered | % Metered. |
|------|-------|---------|------------|
| 1904 | 3963 | 937 | 23.64 |
| 1905 | 4197 | 1077 | 25.66 |
| 1906 | 4444 | 1105 | 24.86 |
| 1907 | 4767 | 1209 | 25.36 |
| 1908 | 5091 | 1363 | 26.82 |
| 1909 | 5409 | 1972 | 36.52 |
| 1910 | 5876 | 3565 | 60.50 |
| 1911 | 6318 | 5519 | 87.20 |
| 1912 | 6797 | 6201 | 91.10 |

Services and Percent Metered.

| <u>Year</u> | <u>Total</u> | <u>Metered</u> | <u>% Metered.</u> |
|-------------|--------------|----------------|-------------------|
| 1913 | 7288 | 6754 | 92.50 |
| 1914 | 7700 | 7230 | 93.80 |
| 1915 | 8069 | 7675 | 95.00 |
| 1916 | 8758 | 8192 | 93.60 |
| 1917 | 9255 | 8717 | 94.20 |
| 1923 | 15000 | 14998 | 99.80 |




A study of the death-rate or case-rate of typhoid fever in the city of Jackson for the past number of years, illustrates in a striking way, the relation that exists between this disease and the general character of the public water supply. From the data shown below, it is easy to see that the number of typhoid fever cases about the year 1911 was rather high. According to Dr. Town of the Health Department of Jackson, the water at that time did not give very favorable results on being tested. But since that time more precautions have been taken and the number of typhoid cases have diminished fairly rapidly. But in 1920 and 1921 we find that the number of typhoid cases increased somewhat. On investigating the cause of these cases, it was found that some of the private wells, of which there are several in Jackson, were in a very bad condition, and that the majority of the people who were sick with typhoid fever, had been using water from these wells. The use of water from these wells was then prohibited and the number of cases at once became fewer. The water supply of Jackson is from the best artesian wells in the country, and so there should be very few typhoid fever cases in Jackson at any one time.

Data.

| <u>Years</u> | <u>Cases</u> | <u>Deaths</u> |
|--------------|--------------|---------------|
| 1911 | 75 | 8 |
| 1912 | 66 | 5 |
| 1913 | 44 | 4 |
| 1914 | 65 | 7 |
| 1915 | 17 | 1 |
| 1916 | 30 | 6 |
| 1917 | 0 | 0 |
| 1918 | 10 | 1 |
| 1919 | 4 | 0 |
| 1920 | 17 | 4 |
| 1921 | 20 | 3 |
| 1922 | 12 | 2 |
| 1923 | 3 | 0 |

GRAPH SHOWING TYPHOID
CASES PER 10,000



Comparison of Pumping Statistics for the Years 1922-1923.

1922.

| | |
|----------------------------|--------------|
| Revenue sale of water | \$130,402.54 |
| Meter deposits | 3,080.00 |
| Miscellaneous sales | 1,041.52 |
| Amounts payable | 1,187.55 |
| Amounts receivable | 3,587.36 |
| Gas Meter Tests | 36.00 |
| Earnings (service repairs) | 1,665.00 |
| Testing meters | 16.00 |
| Gas penalties | 25.00 |
| Show permits | <u>60.00</u> |
| Total Revenue | \$141,100.57 |

| | | | |
|-------------------|-----------------|-------------------|-------------------|
| Expenses | \$119,136.56 | Revenue | \$141,100.57 |
| Capital account | <u>8,926.10</u> | Operating expense | <u>110,210.46</u> |
| Operating expense | \$110,210.46 | Income | \$ 30,890.11 |

Total amount pumped for year 1922 = 222,722.00 cu. ft.

Cost of pumping per 1000 cu. ft. for year = \$0.4948

1923.

| | |
|----------------------------|--------------|
| Revenue sale of water | \$147,628.24 |
| Meter deposits | 4,222.00 |
| Earnings (service repairs) | 1,564.47 |
| Accounts receivable | 489.60 |
| Miscellaneous sales | 405.44 |

| | |
|-----------------|-------------|
| Show permits | 60.00 |
| Gas penalties | 28.50 |
| Gas meter tests | 15.00 |
| Pumping rental | 16.00 |
| Testing meters | <u>7.00</u> |

| | |
|---------------|--------------|
| Total Revenue | \$154,436.25 |
|---------------|--------------|

| | | | |
|-------------------|-----------------|-------------------|-------------------|
| Expenses | \$113,943.46 | Revenue | \$154,436.25 |
| Capital account | <u>7,853.40</u> | Operating expense | <u>106,090.56</u> |
| Operating expense | \$106,090.56 | Income | \$ 48,345.69 |

Total amount pumped for year 1923 = 241,843,000 cu. ft.

Cost of pumping per 1000 cu. ft. for year = \$0.438

Reduction per 1000 cu. ft. for year 1923 over 1922 was \$0.056

The Water Department does not charge for fire service, but for domestic and manufacturing purposes, they charge \$1.00 a 1000 for the first 5000 cu. ft. consumed in a month, and 75¢ for all above 5000 cu. ft. The gas is tested every three hours, and if it falls below 540 B.T.U. at any one time, the Gas Company is fined \$25. The amount of chlorine used is about .4 parts per million.

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

•

PART III.

Population Studies and Estimates.

The population of the city of Jackson from the date of the earliest United States Census, up to the present time is given in the following table.

Table 1.

Population of Jackson, Michigan, by U. S. Census Returns.

| Year | Population |
|------|------------|
| 1850 | 2,363 |
| 1860 | 4,799 |
| 1870 | 11,447 |
| 1880 | 16,105 |
| 1886 | 18,919 |
| 1887 | 19,388 |
| 1888 | 19,858 |
| 1889 | 20,328 |
| 1890 | 20,798 |
| 1891 | 21,236 |
| 1892 | 21,674 |
| 1893 | 20,112 |
| 1894 | 22,550 |
| 1895 | 22,988 |
| 1896 | 23,426 |
| 1897 | 23,864 |
| 1898 | 24,303 |

| Year | Population |
|------|------------|
| 1899 | 24,742 |
| 1900 | 25,180 |
| 1901 | 25,805 |
| 1902 | 26,430 |
| 1903 | 27,055 |
| 1904 | 27,680 |
| 1905 | 28,305 |
| 1906 | 28,930 |
| 1907 | 29,555 |
| 1908 | 30,181 |
| 1909 | 30,807 |
| 1910 | 31,433 |
| 1911 | 33,394 |
| 1912 | 35,355 |
| 1913 | 37,316 |
| 1914 | 39,277 |
| 1915 | 41,238 |
| 1916 | 43,200 |
| 1917 | 47,500 |
| 1920 | 48,474 |
| 1922 | 50,000 |

These records indicate a steady, but not unusual gain over the whole life of the city. From the curve it can be seen that during the World War, the increase in polulation was very small. But as soon as the soldiers returned from

the war and the factories began working under normal conditions, the population has increased more rapidly.

An effort has been made to estimate the future growth in population for the city of Jackson, up to, and including the year 1950. Curve Number 1 of this report is a past, and probable future increase in population for the year 1950. This estimation for the future was made by per cent increase per decade.

Estimated Future Population of Jackson, Michigan.

| Year | Population. |
|------|-------------|
| 1930 | 65,000 |
| 1940 | 95,000 |
| 1950 | 118,000 |

To attain a population, which has been estimated in this forecast, the city of Jackson will not be required to experience any unusual growth, but just a normal increase, such as may reasonably be expected of any Michigan city.

Water Consumption Studies and Estimates.

The records of the Water Works Department of the city of Jackson have yielded some valuable information concerning the average daily quantity of water consumed for recent years. The following table gives the data which is available for the years 1910 - 1922.

Table 2.

Data Concerning Water Consumption at Jackson, Michigan,
For Years 1910 - 1922.

Average Consumption Rate in Million Gallons per Day.

| Year | For Year | For Maximum Day | For Minimum Day | For Maximum Hour |
|------|-------------|-----------------------|-----------------------|------------------------|
| 1910 | 2.92 | 7.70 | 1.84 | |
| 1911 | 2.71 | 4.97 | 1.85 | |
| 1912 | 2.90 | 4.96 | 2.04 | |
| 1913 | 2.89 | 6.17 | 2.13 | |
| 1914 | 2.95 | 5.45 | 1.73 | |
| 1915 | 2.55 | 4.13 | 1.92 | |
| 1916 | 3.11 | 5.66 | 2.13 | |
| 1917 | 3.73 | 7.46 | 2.16 | |
| 1918 | 4.12 | 6.94 | 2.40 | |
| 1919 | 4.23 | 8.33 | 2.23 | 13.62 |
| 1920 | 4.51 | 7.42 | 2.89 | 13.57 |
| 1921 | 4.36 | 8.35 | 3.05 | 15.34 |
| 1922 | 4.56 | 7.90 | 3.10 | 15.00 |

Table 3.
 Ratios in Per Cent.

| <u>Max. Da. To Average</u> | <u>Min. Da. To Average</u> | <u>Max. Hr. To Average</u> |
|--------------------------------|--------------------------------|--------------------------------|
| 264 | 63 | |
| 183 | 68 | |
| 171 | 70 | |
| 213 | 74 | |
| 185 | 59 | |
| 162 | 75 | |
| 182 | 68 | |
| 200 | 58 | |
| 168 | 58 | |
| 197 | 53 | 322 |
| 165 | 64 | 300 |
| 191 | 70 | 330 |
| 173 | 68 | 338 |

The following table is a record of daily average gallons, and daily consumption per capita in the city of Jackson, for years 1886 - 1923. While these figures might be taken to show that the per capita consumption might be expected to continue to be about 90 gallon per. It is shown by curve Number 2 that for the year 1950, it will be about 108 gallons per capita. This curve was constructed from the following data, and the estimation for the future was made by per cent increase per decade.

Table 4.

| Year | Daily Average Gallons | Daily Consumption Per Capita. |
|------|--------------------------|----------------------------------|
| 1886 | 1,730,000 | 92.5 gallons |
| 1887 | 1,600,000 | 83 " |
| 1888 | 1,650,000 | 84 " |
| 1889 | 2,010,000 | 100 " |
| 1890 | 1,805,000 | 90 " |
| 1891 | 1,770,000 | 84.5 " |
| 1892 | 1,730,000 | 80.5 " |
| 1893 | 1,953,000 | 89 " |
| 1894 | 2,342,000 | 104.5 " |
| 1895 | 2,330,000 | 102 " |
| 1896 | 1,945,000 | 83.5 " |
| 1897 | 2,180,000 | 92 " |
| 1898 | 2,460,000 | 101.5 " |
| 1899 | 2,290,000 | 93 " |
| 1900 | 2,200,000 | 87.8 " |
| 1901 | 2,240,000 | 87 " |
| 1902 | 1,855,000 | 70.5 " |
| 1903 | 2,130,000 | 79 " |
| 1904 | 2,150,000 | 78 " |
| 1905 | 2,120,000 | 75.5 " |
| 1906 | 2,610,000 | 90 " |
| 1907 | 2,255,000 | 76.5 " |
| 1908 | 2,605,000 | 87 " |

| <u>Year</u> | <u>Daily Average Gallons</u> | <u>Daily Consumption Per Capita.</u> |
|-------------|----------------------------------|--|
| 1909 | 2,410,000 | 78.5 gallons |
| 1910 | 2,760,000 | 88 " |
| 1911 | 2,770,000 | 83 " |
| 1912 | 2,720,000 | 77 " |
| 1913 | 2,785,00 | 75 " |
| 1914 | 2,745,000 | 70.5 " |
| 1915 | 2,445,000 | 59 " |
| 1916 | 3,055,000 | 67 " |
| 1917 | 3,750,000 | 78.5 " |
| 1918 | 3,800,000 | 79 " |
| 1919 | 3,960,000 | 84.5 " |
| 1920 | 4,105,000 | 93.5 " |
| 1921 | 4,210,000 | 89 " |
| 1922 | 4,600,000 | 91.5 " |

Basis of Design for Future.

As a basis upon which a design for an improved water works for the city of Jackson may be carried forward, the following conclusions have been reached.

That the general features of the plans should be designed to adequately serve a population of approximately 118,000 persons, which population should be attained about the year 1950.


That an average consumption of 108 gallon per capita per day should be provided for.


That the ratio of consumption rate during maximum hour to the average, be taken as 320 per cent.

That the ratio of consumption during maximum day to that of the average day, be taken as 180%.


That the design should provide for an average pumping rate of 12,000,000 gallons per day.

CURVE SHOWING PAST AND PROBABLE FUTURE
AVERAGE PUMPING RATE FOR YEAR





1943 1944 1945 1946 1947 1948 1949 1950



1937 1938 1939 1940 1941 1942

21

51

61

3

6

4

5

1937 1938 1939 1940 1941 1942

PART IV.

"Ella Sharp Park Project"

It has been apparent to the people of Jackson, that the present system of obtaining water to supply the city of Jackson, will be adequate for only a few more years. In the minds of some people there exists the thought that the Ella Sharp Park is a desirable place for a water supply development for the city of Jackson Michigan. Reference to this is also found in the report of Mr. S. G. Pollard, who acted as consultant to the city of Jackson upon water works improvement in the years 1917 & 1918. It appears from Mr. Pollard's report that some little thought and investigation was given to this question at that time.

In the present investigation of the water supply system of Jackson, attention is again drawn to Ella Sharp Park, as a suitable place for a future water supply development for the city of Jackson. The Ella Sharp Park is situated on either side of 4 th street just south of the southern limits of the city of Jackson. It is a beautiful tract of rolling land which under the terms of its bequest to the city, has been artistically landscaped. It will be a very valuable asset to the city of Jackson, if continued in a restricted use as a public park.

According to the available records the highest point in the park is about elevation 1010. This height of land coupled with the presence of small flows of spring water, in the lower levels, has prompted the suggestion for a water supply development at the park. On careful investigation, a water supply development in this area may be along two different plans. The water supply might be taken from the ground water underlying the park, and be pumped to a reservoir located on the high land, from which it would flow by gravity into the city. Another plan might be to obtain the water from some of the present wells and pump it across the city to a reservoir located in the park, from which it would flow by gravity down into the city as under the other scheme. In the study of these possibilities such calculations have been made which show conclusively, that neither one of these two plans can be worked out satisfactorily.

In the working of this problem it was necessary to determine which part of the city not only was the center of the business district, but also contained the tallest building. This being necessary because under either of the plans previously mentioned, there would have to be enough pressure to force the water to the top of the tallest building. If this is not possible, under the present conditions in the city of Jackson, there is little need of fostering either of the plans, because Jackson is growing rapidly and will be constructing buildings, which are taller than those already existing.

The center of the business section of the city is taken at the intersection of Michigan Avenue and Mechanic St. At this place, is also situated the Peoples National Bank building, which is eight stories in height. At this point the elevation of the ground surface is 935 feet. The distance from the reservoir site in the park to the latter point is about 13,750 feet. Calculations as to the desirable size of main from the reservoir to the city, indicates that there should be at least a 30 inch main from the park in as far as High St. From that point it may be reduced to 24 inches on account of possible cross connections with the existing distribution system. A study of the consumption rates which have been obtained in the past in the city of Jackson, indicates that the maximum hourly rate of consumption has already reached 15 Mil - gal - per - da. A rate of 13 mil - gal - per - da has occurred several times in the past few years. Reference to an earlier page of this report indicates that any proposed development, should be made on the basis of a probable maximum daily consumption rate of 18 Mil - gal - per - da. And a maximum hourly rate of 30 Mil - gal - per - da these figures being calculated for about the year 1940.

The following table brings together some of the results determined in a calculation of the friction loss in a 30 inch main, from a reservoir site in the park to the intersection of Michigan Avenue and Mechanic St.

Table 5

Data Concerning an Available Water Pressure
Resulting from a Reservoir Located in the Ella Sharp Park.

| Rate of water Consumption in Gal.per.da. | Friction loss between Mechanic St. and Michigan Ave. In feet. | Elevation of water in reservoir. In feet. |
|--|--|--|
| 10,000,000 | 28 | 1010 |
| 15,000,000 | 66 | 1010 |
| 18,000,000 | 79 | 1010 |
| 30,000,000 | 129 | 1010 |

| Elevation of Hydraulic Gradient at Mechanic St. and Michigan Ave. In feet. | Elevation of ground surface at Mechanic St. and Michigan Ave. In feet. | Height to which water will rise at ground surface at Mechanic St. and Michigan Ave. In feet |
|--|--|---|
| 982 | 935 | 47' above. |
| 944 | 935 | 9' " |
| 931 | 935 | 4' below. |
| 880 | 935 | 55' " |

In order to determine the friction head for the data given in table 5 the formulae $hf = f \frac{LV^2}{D2g}$ and $V = \frac{Q}{A}$ were used.

L=the length in feet of the pipe measured on its axis.

D=the internal diameter in feet of the pipe.

V=the mean velocity of flow in feet per second.

h= the acceleration due to gravity, taken as 32.16.

The results of these calculations will be considered in the light of the service, which would be rendered to a water consumer under the conditions previously stated. Now it is possible to determine just how high the water would rise in the Peoples National Bank building due to gravity pressure.

The elevations of the different floors are as follows.

| Floor. | Elevation. |
|----------|------------|
| First. | 935 |
| Second. | 951 |
| Third. | 962 |
| Fourth. | 973 |
| Fifth. | 984 |
| Sixth. | 995 |
| Seventh. | 1006 |
| Eighth. | 1017 |

The roof elevation is about elevation 1028. At a time of a consumption rate of 10 Mil. gal. per. da. The water would rise in this building to a point 47 ft. above ground floor or just to the level of the fifth floor. At the time of a consumptive rate of 15 Mil. gal. per. da. the water would rise in the building to a point 9 feet above the ground floor, not quite to the second floor. At the time of a consumption rate of 18 Mil. gal. per. da the water would rise to a point 4 ft. below the first floor. Even under a static condition, where no flow at all would be possible, the water would rise in a piping system of the building only to a point 75 feet above the ground surface, which is about 4 feet above the seventh floor. And under these conditions it would be impossible, without some additional pumping to get water to the eighth floor.

Q = the discharge in cubic feet per second.

A = the cross - sectional area of the pipe in feet.

f = the friction factor, which with new cast iron pipes ranges from .02 to .05.

Mr. L. Arnold, City Engineer of Jackson, states that they have found that the friction factor .035 is best suited for all computations concerning new cast iron pipe.

For a rate of water consumption of 10 Mil. gal. per. da. through a 30 inch pipe for a distance of 13,750 feet, the following results are obtained.

$Q = 10,000,000 \div 646317 = 15.4$ discharge cubic feet per second.

Area of a 30 inch pipe 5.02 feet. . .

$V = 154 \div 5.02 = 3.1$ mean velocity of flow in feet per second.

$hf = f \cdot \frac{LV^2}{D2g} = .035 \cdot \frac{13,750 (3.1)^2}{2.5 \cdot 64.3} = 28$. friction loss.

For a rate of water consumption of 15 Mil. gal. per. da through a 30 inch pipe, for a distance of 13,750 feet, the following results are obtained.

$Q = 15,000,000 \div 646317 = 23.2$ discharge cubic feet per. second.

Area of 30 inch pipe = 5.02 ft.

$V = 23.2 \div 5.02 = 4.6$ mean velocity of flow in feet per. second.

$$hf = f \cdot \frac{LV^2}{D2g} = .035 \cdot \frac{13,750}{2.5} \frac{(4.6)^2}{64.3} = 66 \text{ friction loss.}$$

For a rate of water consumption of 18 Mil. gal. per. da for a 30 inch pipe, for a distance of 13,750 feet, the following results are obtained.

$Q = 18,000,000 \div 646317 = 29$ discharge cubic feet per second.

Area of a 30 inch pipe = 5.02 feet

$V = 29 \div 5.02 = 5.8$ mean velocity of flow in feet per second.

$$hf = f \cdot \frac{LV^2}{D2g} = .035 \cdot \frac{13,750}{2.5} \frac{(5.8)^2}{64.3} = 79 \text{ friction loss.}$$

For a rate of water consumption of 30 Mil. gal. per. da through a 30 inch pipe, for a distance of 13,750 feet, the following results are obtained.

$Q = 30,000,000 \div 646317 = 46.4$ discharge cubic feet per. second.

Area of a 30 inch pipe is = 5.02 feet.

$V = 46.4 \div 5.02 = 9.28$ mean velocity of flow in feet per. second.

$$hf = f \cdot \frac{LV^2}{D2g} = .035 \cdot \frac{13,750}{2.5} \frac{(9.28)^2}{64.3} = 129 \text{ friction loss.}$$

For a consumption rate of 10 Mil. gal. per. da.

1010 - 28 = 982 feet.

982 - 935 = 47 feet above ground surface.

For a consumption rate of 15 Mil. gal. per. da.

1010 - 66 = 944 feet.

944 - 935 = 9 feet above ground surface.

For a consumption rate of 18 Mil. gal. per. da.

1010 - 79 = 931 feet.

931 - 935 = 4 feet below surface.

For a consumption rate of 30 Mil. gal. per. da.

1010 - 129 = 880 feet.

880 - 935 = 55 feet below ground surface.

In a business district a desirable water pressure is about 60 lbs. per. square inch or 138 ft of pressure head. In order to provide such a pressure at ground surface of Michigan Ave. and Mechanic street, during the time when the water consumption rate reached 10 Mil. gal. per. da it would be necessary that the reservoir be located on the high hill in the park, be elevated to a point 90 feet above ground surface. And with a rate of 15 Mil. gal. per. da ,the elevation of the reservoir would have to be at least 130 feet above the ground surface. While for a consumption rate of 18 Mil. gal. per. da, which will soon be reached in the city of Jackson. The reservoir would have to be at least 142 feet above the ground surface.

In order that the reservoir can satisfactorily meet the fluctuations in consumption, its volume should be about 3 million gallons. An economically proportioned reservoir of this volume to be built at the ground surface would be 175 feet square, with a water depth of 14 feet. To construct a reservoir of this volume at an elevation of 100 feet or more above the ground surface, would be impracticable from any stand point; and the cost of such a structure would be very high, and so prohibitive.

In view of the fact that this land was given to the city of Jackson as a pleasure park and as it has already proven itself to be very valuable, it will not be feasible to construct a water supply system in Ella Sharp Park. It has also been shown by calculations, that a water supply system situated in the Park will never give satisfactory service over the whole city of Jackson.

PART V.

Recommended Plan for the Development of a New Water Works Plant.

A definite and final conclusion has been reached, that it is not practicable to consider any further development, or enlargement of the municipal water works plant at its present site, between Water Street and Grand River. An investigation of the quantity of water, which might be available from the area now partly developed by wells near Losey Avenue and from adjacent areas in this vicinity bordering on the Grand River, indicates that there can be obtained from this area, sufficient water to meet the needs of the city of Jackson. No other site, which is available to the city of Jackson, offers the possibilities approximating those, which may be had in a development in the Losey Avenue area. This being partially due to its nearness to the present plant, and the ease with which the two systems can be joined together.

General Plan.

Drawing 2. of this report shows a general plan of a possible arranging of structures, necessary in the development of a water works pumping plant in the above mentioned area. While this plan shows a definite location for the several structures comprising the plant, it is not to be understood that this particular arrangement will be final in all respects. The topography is such that the general relations of the several structures may be kept alike, even though the location and orientation of the plant as a whole be changed.

At the present time the water works structures situated in this area consist of the four 12 inch wells, and the small electrically operated low service pump station, which forces the water from the wells to the present high service plant situated along Water Street. Under the proposed development, six new 12 inch wells will be drilled in the area adjacent to existing wells already drilled. These wells will be connected with the present line leading to the existing low lift pumping station. The present pumping equipment consists of a 12 inch motor driven centrifugal pump supplemented by a new 15 inch motor driven centrifugal pump. These pumps will draw water from the wells and discharge it through appropriate piping connections into a new storage reservoir, to be located south of the New York Central tracks.

The proposed storage reservoir will be of approximately 3 million gallon capacity. This reservoir will be of sufficient size to meet the demands of the maximum hourly rate on that day of the year, which has the maximum consumption. The use of such a reservoir will make it possible

to draw on the wells at practically a constant rate during the night time, and at other periods of low demands for water, the water from the low service pumps will go into storage in the reservoir. During sprinkling hours and other periods of high demand, the water from the low service pumps will go directly to the high service pumps and this supply will be further augmented by that volume stored in the reservoir.

A new high service pump building, which when completed will replace the Water street station will be located on the land lying between the New York Central and Cincinnati tracks. This pump building with the adjacent boiler house will be given an architectural treatment, which will make these structures different from the usual factory type of construction, and which will enhance the value of any park or landscape development which may follow.

The high service pumping equipment to be housed in this building, will consist of the present 8 Mil. gal. per. da. Snow Cross compound high duty pumping engine, now in place at the Water street station; one new 8 Mil. gal. per. da. cross compound high pump engine; and one new 8 Mil. gal. per. da. turbin driven centrifugal pump. In the pump room there will also be housed two 100 K. V. A. turbo-generator sets, which will be used to supply electrical energy for the low surface station. A connection will also be made with the commercial electrical power service for use if required. Necessary switch boards and other auxiliary equipment will of course, be provided.

The boiler plant equipment will consist of 3 160 H. P. boilers with their necessary feed-water heaters, fuel pumps and other auxiliaries. The coal supply for the boilers will be brought in over a spur track from the New York Central lines. This track will be elevated from the coal pit in such a manner, that hopper cars may dump their loads directly on to the coal pile. The high service pumps will take their suction from the low service discharge line or storage reservoir. They will discharge into a supply main leading from the plant to Beldon Avenue and continued through the public streets to a connection with the existing distribution system at Milwaukee and Otsego streets.

The following tabulation presents an estimate of cost of those parts of the recommended water works development, which should soon be under taken. This amount of construction will provide a thoroughly adequate supply, equal in quality to that at present enjoyed and much less liable to contamination. It will provide pumping capacity sufficient to meet the maximum demands upon the water supply system for the next twenty years. It will provide the nucleus of a plant,

Provisions for Plant Expansion.

Chemical analysis of the water from Losey Avenue wells and from other deep wells in Jackson, show a hardness of about 275 parts per million. While it is probably true that the people of the city of Jackson are accustomed to a water of this hardness and may not at present feel the need of softening it; yet a consideration of this contingency is most important at this time. When the city of Jackson will have completed and placed in operation an adequate water works plant, supplying sufficient quantities of water, it will doubtless be found that many of the industries now obtaining their supplies from private sources, will revert to the municipal supply as being cheaper and more reliable. These consumers will demand a supply reasonably soft and suitable for steam purposes. The public in general, is taking an increasing interest in the quality of their public water supply, and it is only a question of time when the domestic consumers also will appreciate and demand the advantages of a softened and filtered water.

With these considerations in mind, the general plan has been so laid out, that it will allow of a development for softening and filtering the water when this may be desired. Drawing 2. indicates in light lines, those structures and parts of the plant, which may be developed at such time as a softened supply becomes desirable.

Under such a completed design the operation of works will be essentially as follows; The low service pumping station will take its supply, as at present, from the several wells, but will pump through a low service main to the chemical building, where the water in its flow will be treated with the required softening chemical. From this point it will continue on to a sedimentation basin, which may be located on the high - land a little way south and east of the main plant. In this basin the resulting precipitates from the chemical softening reactions, and other foreign matter will be settled out. From the sedimentation basin the supply will be carried through a pipe line into the filter building and on to the filters, where a further purification will be effected. The effluent from the filters will be carried over and stored in a large reservoir. From the storage reservoir the softened and filtered water will be drawn by suction into the high service pumps, from which it will be discharged through the pump main into the distribution system.

which may at a latter date be expanded and developed into a thoroughly complete softening and filtration works.

The time which has been available for these studies has not allowed the making of plans complete in all their details, nor as to the investigation as to the actual cost of many of the parts and pieces of equipment. It has, however, shown conclusively that these works may be constructed at a very reasonable figure. No allowance being made in these estimates for such lands, or right-of-ways as may be necessary in the development.

**Preliminary Estimate of Cost of Recommended Water Works
Improvement for City of Jackson Michigan.**

Wells.

Consisting of six new 12 inch drilled wells. The wells are approximately 400 feet deep. Total cost \$12,000.

Low Service Station Improvement.

Consisting of necessary piping connecting with wells; a new 15 inch motor driven centrifugal pump with valves and piping; and a 24 inch Class A cast iron pipe main leading to the high service pumping station. \$16,000.

Storage Reservoir.

One covered concrete reservoir of 3 million gallon capacity \$65,000.

High Service pumping Station Building.

Consisting of pump room, boiler room stack, coal storage area, spur railroad track, trestle, roadways and general grading and ground improvement. \$94,000.

High Service pumping Equipment.

Consisting of the resetting of the present 8 Mil. gal. per. da. Cross compound pumping engine; one 8 Mil. gal. per. da. turbin driven centrifugal pumping unit; two 100 K. V. A. turbin generator sets; 3-160 H.P. turbin boilers and other necessities. \$128,000.

Connecting Main.

From the high service pumping building to connect with present city distribution system. \$85,000.

The total cost of recommended immediate construction, not including rights-of-way is \$4000,000.

PART VI.

CITY OF JACKSON, MICHIGAN.

Report on

TESTING OF NEW CITY WELLS

Summary of Tests

Well No. 1 was tested Oct. 9th and 10th with the following results:

| | |
|---|------------------|
| Minimum rate of pumpage | 171,000 Gal./Da. |
| Maximum " " " | 385,000 " " |
| Average " " " | 420,000 " " |
| Lowering corresponding to min. rate pumpage | 1.18 ft. |
| " " " max. " " | 3.20 " |
| " " " Aver. " " | 1.705 " |

Well No. 2 was tested Oct. 5th and 6th with the following results:

| | |
|---|------------------|
| Minimum rate of pumpage | 522,000 Gal./Da. |
| Maximum " " " | 942,000 " " |
| Average " " " | 719,000 " " |
| Lowering corresponding to min. rate pumpage | 4.86 ft. |
| " " " Max. " " | 5.27 ft. |
| " " " Aver. " " | 4.375 " |

Well No. 3 was tested Dec. 5th and 6th with the following results:

| | |
|-------------------------|------------------|
| Minimum rate of pumpage | 502,000 Gal./Da. |
| Maximum " " " | 726,000 Gal./Da. |
| Average " " " | 662,500 " " |

| | |
|---|----------|
| Lowering corresponding to min. rate pumpage | 5.17 ft. |
| " " " Max. " " | 8.40 " |
| " " " Aver. " " | 7.08 " |

Well No. 4 was tested Nov. 2nd and 5th with the following results:

| | |
|---|------------------|
| Minimum rate of pumping | 408,000 Gal./Da. |
| Maximum " " " | 942,000 " " |
| Average " " " | 660,000 " " |
| Lowering corresponding to min. rate pumpage | 5.60 ft. |
| " " " Max. " " | 5.90 " |
| " " " Aver. " " | 4.678 " |

Well No. 5 was tested Oct. 26th and 27th with the following results:

| | |
|---|------------------|
| Minimum rate of pumpage | 464,000 Gal./Da. |
| Maximum " " " | 1,000,000 " " |
| Average " " " | 701,000 " " |
| Lowering of head corresponding to min. rate pumpage | 4.41 ft. |
| " " " " " Max. " " | 6.41 " |
| " " " " " Aver. " " | 4.10 " |

Well No. 6 was tested Nov. 21st and 22nd with the following results:

| | |
|-------------------------|------------------|
| Minimum rate of pumpage | 407,500 Gal./Da. |
| Maximum " " " | 1,031,000 " " |
| Average " " " | 690,000 " " |

Lowering of head corresponding to Min. rate pumpage 2.00 ft.

| | | | | | | | | |
|---|---|---|---|--------|---|---|------|---|
| " | " | " | " | " Max. | " | " | 8.16 | " |
|---|---|---|---|--------|---|---|------|---|

| | | | | | | | | |
|---|---|---|---|---------|---|---|-------|---|
| " | " | " | " | " Aver. | " | " | 4.285 | " |
|---|---|---|---|---------|---|---|-------|---|

COMPARISON OF PUMPING

1922 & 1925.

| | Max. Day (Pumping) | | Min. Day (Pumping) | |
|-------|--------------------|-----------|--------------------|-----------|
| | 1922 | 1925 | 1922 | 1925 |
| Jan. | 5,056,200 | 4,470,800 | 2,200,600 | 2,490,500 |
| Feb. | 4,925,100 | 5,200,000 | 2,510,000 | 2,276,100 |
| Mar. | 4,695,600 | 5,291,000 | 2,544,800 | 2,785,600 |
| Apr. | 4,780,100 | 5,715,500 | 2,560,000 | 2,627,400 |
| May | 5,174,000 | 7,162,000 | 2,282,900 | 2,216,000 |
| June | 7,528,500 | 8,222,800 | 2,861,000 | 2,874,000 |
| July | 7,884,500 | 7,267,000 | 4,420,000 | 4,019,100 |
| Aug. | 7,904,000 | 6,842,160 | 2,597,100 | 4,001,400 |
| Sept. | 6,595,600 | 7,667,400 | 2,425,900 | 2,601,000 |
| Oct. | 5,214,500 | 5,454,800 | 2,240,900 | 2,711,500 |
| Nov. | 4,751,600 | 5,566,600 | 2,166,800 | 2,466,000 |
| Dec. | 4,631,900 | 5,021,000 | 2,257,900 | 2,380,000 |

Daily Average (Month)

| | 1922 | 1925 |
|-------|-----------|-----------|
| Jan. | 4,211,250 | 4,268,800 |
| Feb. | 4,079,820 | 4,607,290 |
| Mar. | 3,946,620 | 4,776,620 |
| Apr. | 4,161,530 | 4,822,260 |
| May | 4,411,000 | 4,650,460 |
| June | 5,406,280 | 6,102,490 |
| July | 5,916,000 | 6,052,300 |
| Aug. | 5,447,000 | 5,242,990 |
| Sept. | 4,584,000 | 4,980,470 |

Daily Average (Month)

| | 1922 | 1921 |
|---------|-----------|-----------|
| Oct. | 4,267,000 | 4,965,820 |
| Nov. | 4,060,900 | 4,499,090 |
| Dec. | 4,117,000 | 4,252,710 |
| Average | 4,560,700 | 4,952,590 |

Maximum of water pumped in one day, 1922 - 7,904,000 Gal.

" " " " " " " 1921 - 8,222,800 "

Minimum amt. of water pumped in one day, 1922 2,166,800 Gal.

" " " " " " " , 1921 2,516,000 "

Average daily amount for year, 1922 4,560,700 Gal.

" " " " " 1921 4,952,590 "

Average daily increase of 1921 over 1922 391,890 Gal.

Per Capita Consumption 1922 99 Gal.

Total amt. of water pumped 1922 - 1,808,987,700 Gal. or
241,843,275 cu. ft.

Total amt. of water pumped 1921 - 1,668,947,850 Gal. or
222,720,301 cu.ft.

Increase pumpage of 1921 over 1922 - 140,039,850 Gal.

| Water Pumped 1925 | | | Coal Used | | Chlorine Used | | | |
|-------------------|-----------|-------------|-----------|--------|---------------|-------|-----|--|
| | Daily | Total | Daily | Total | Daily | Total | | |
| | Aver. | | Aver. | | Aver. | | | |
| | (Gal.) | (Gal.) | (Tons) | (Tons) | Lbs.Oz. | Lbs. | Oz. | |
| Jan. | 4,268,800 | 133,332,800 | 8.86 | 181.68 | 12 7 | 384 | 14 | |
| Feb. | 4,607,290 | 129,004,400 | 6.79 | 190.14 | 17 0 | 476 | 2 | |
| Mar. | 4,776,620 | 148,074,600 | 6.59 | 204.50 | 17 12 | 551 | 13 | |
| Apr. | 4,831,360 | 141,002,000 | 6.22 | 186.69 | 16 16 | 569 | 14 | |
| May | 4,650,460 | 144,166,600 | 6.57 | 203.80 | 19 7 | 602 | 5 | |
| June | 6,202,490 | 189,105,000 | 9.22 | 279.48 | 20 6 | 612 | 2 | |
| July | 6,053,300 | 187,652,300 | 8.81 | 273.07 | 19 12 | 611 | 15 | |
| Aug. | 5,242,990 | 162,529,900 | 7.47 | 251.47 | 19 0 | 589 | 2 | |
| Sept. | 4,980,470 | 149,416,000 | 6.63 | 199.02 | 16 1 | 481 | 4 | |
| Oct. | 4,963,120 | 153,808,600 | 6.49 | 201.37 | 15 13 | 489 | 14 | |
| Nov. | 4,499,090 | 134,972,000 | 6.59 | 197.87 | 14 0 | 436 | 8 | |
| Dec. | 4,253,710 | 131,804,700 | 6.47 | 200.44 | 18 14 | 585 | 4 | |

| | |
|---------------------------------|-----------------|
| Daily Average water pumped | 4,952,590 Gal. |
| Total Water Pumped | 1,808,987,700 " |
| Aver. coal to pump 1 Mil. Gal. | 1.41 Tons |
| Total Coal consumed | 2,549.54 " |
| Total Chlorine used | 6,392 lbs. |
| Average parts per Mil. Chlorine | .43 |

REPORT ON TESTING OF NEW CITY WELLS

The contract with The Artesian Well and Supply Co., which consisted of drilling six twelve-inch wells for the City of Jackson, has been completed. Each well, upon completion, was tested by pumping, measuring the lowering of the ground water and recording the discharge. There are two important reasons for testing the wells; first, the cleaning of the wells, and second, to determine the probable yield of the wells.

The tabulation below gives the depth of casing, the amount of uncased wall, and total depth.

| Well No. | Length Cased | Length Uncased | Total Depth |
|----------|-----------------|------------------|------------------|
| 1 | 70' - 1/2" | 329' - 11 1/2" | 400' - 0" |
| 2 | 63' - 9 1/2" | 334' - 8 1/2" | 398' - 6" |
| 3 | 58' - 1" | 325' - 11" | 384' - 0" |
| 4 | 68' - 6" | 324' - 0" | 392' - 6" |
| 5 | 73' - 1 1/2" | 312' - 10 1/2" | 386' - 0" |
| 6 | <u>63' - 9"</u> | <u>326' - 7"</u> | <u>390' - 4"</u> |
| | 397' - 3 1/2" | 1954' - 1/2" | 2,351' - 4" |

The deepest well is 400 ft. and the shallowest 384 ft. The longest casing is 73' - 1 1/2" and the shortest is 58 ft. 1 in. The source of supply of these wells is from The Marshall Sandstone strata which is first encountered about 200 ft. below the surface of the ground. The direct pumping method will be used.

From the above data it was possible to work out a head-discharge curve or to obtain a curve which would give the probable yield for one foot lowering of the ground water.

In conclusion it would seem reasonable to believe that by lowering the ground water eight feet the six wells would yield 6,000,000 Gal. in 24 hours and by lowering the ground water 10 feet, the yield of ten wells would be 7,000,000 Gal. in 24 hours.

STATISTICAL DATA
for
HEAD-DISCHARGE CURVE

| Well No. | Average Pumping | |
|----------|-----------------|--------------|
| | Lowering | Rate |
| 1 | 1.705 ft. | 420,000 Gal. |
| 2 | 4.275 " | 719,000 " |
| 3 | 7.080 " | 662,500 " |
| 4 | 4.678 " | 660,000 " |
| 5 | 4.100 " | 701,000 " |
| 6 | 4.265 " | 690,000 " |

/ Equation of Curve - $r = 162,900 \text{ h.}$

| Minimum Pumping | | |
|-----------------|----------|--------------|
| Well No. | Lowering | Rate |
| 1 | 1.18' | 171,000 Gal. |
| 2 | 4.86' | 522,000 " |
| 3 | 5.17' | 502,000 " |
| 4 | 5.60' | 408,000 " |
| 5 | 4.41' | 464,000 " |
| 6 | 2.00' | 407,000 " |

7 Equation of curve - $r = 121,850 \text{ h.}$

| Maximum Pumping | | |
|-----------------|----------|--------------|
| Well No. | Lowering | Rate |
| 1 | 2.20' | 585,000 Gal. |
| 2 | 5.27' | 942,000 " |
| 3 | 8.40' | 726,000 " |

Maximum Pumping (Continued)

| Well No. | Lowering | Rate |
|----------|----------|--------------|
| 4 | 5.90' | 942,000 Gal. |
| 5 | 6.41' | 1,000,000 " |
| 6 | 8.16' | 1,031,000 " |

DATA FOR HEAD-DISCHARGE CURVE AT VARIABLE RATES.

| Rate | Head Lowering |
|--------------|---------------|
| 240,000 Gal. | 1.08' |
| 325,000 " | 1.52' |
| 464,000 " | 2.51' |
| 502,000 " | 4.42' |
| 544,000 " | 3.00' |
| 580,000 " | 4.18' |
| 621,000 " | 5.51' |
| 671,000 " | 5.89' |
| 727,000 " | 4.25' |
| 776,000 " | 4.19' |
| 830,000 " | 4.54' |
| 885,000 " | 5.07' |

Equation of Curve, $r = 158,500 h$

DATA FOR SUPPLY HEAD-DISCHARGE CURVE

Maximum Pumping

| Well No. | Lowering | Rate |
|----------|----------|--------------|
| 1 | 5.20' | 585,000 Gal. |
| 2 | 5.27' | 942,000 " |
| 3 | 8.40' | 725,000 " |
| 4 | 5.90' | 942,000 " |
| 5 | 6.41' | 1,000,000 " |
| 6 | 8.15' | 1,021,000 " |

Minimum Pumping

| Well No. | Lowering | Rate |
|----------|----------|--------------|
| 1 | 1.15' | 171,000 Gal. |
| 2 | 4.66' | 522,000 " |
| 3 | 5.17' | 502,000 " |
| 4 | 5.50' | 406,000 " |
| 5 | 4.41' | 434,000 " |
| 6 | 2.00' | 407,500 " |

Average Pumping

| Well No. | Lowering | Rate |
|----------|----------|--------------|
| 1 | 1.705' | 420,000 Gal. |
| 2 | 4.275' | 719,000 " |
| 3 | 7.080' | 662,500 " |
| 4 | 4.673' | 660,000 " |
| 5 | 4.100' | 701,000 " |
| 6 | 4.285' | 690,000 " |

Well No. 1

(Continued)

| Discharge (h) | Elev. of Water | Discharge | Elev. |
|--------------------|--------------------|-----------|-------|
| Start at 5:30 P.M. | Start at 5:15 P.M. | | |
| .35 | 913.12 | .60 | 913.9 |
| .32 | 913.3 | .60 | 914.2 |
| .47 | 913.3 | .60 | 914.1 |
| .41 | 914.4 | .60 | 914.1 |
| - | 915.2 | .59 | 914.3 |
| - | 913.5 | .60 | 914.3 |
| .64 | 913.5 | .60 | 914.3 |
| .64 | 913.2 | .60 | 914.3 |
| .64 | 913.1 | .62 | 913.4 |
| .66 | 913.3 | .68 | 913.3 |
| .61 | 913.1 | .64 | 913.1 |
| .62 | 913.8 | .61 | 913.4 |
| .63 | 913.4 | .60 | 916.1 |
| .63 | 913.2 | .59 | 913.4 |
| .66 | 913.3 | - | 913.0 |
| .66 | 912.9 | .50 | 913.1 |
| .67 | 913.0 | .54 | 913.6 |
| .67 | 913.0 | .54 | 913.5 |
| .67 | 912.9 | .54 | 913.6 |
| .64 | 913.0 | .55 | 913.6 |
| .63 | 913.9 | .48 | 913.9 |
| .64 | 913.2 | .54 | 913.7 |
| .64 | 913.1 | .54 | 913.5 |
| .60 | 912.8 | .54 | 913.7 |

(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| .54 | 915.5 | - | 913.8 |
| .54 | 915.5 | .42 | 913.8 |
| .52 | 916.0 | .50 | 914.2 |
| .52 | 915.8 | .50 | 915.2 |
| .45 | 916.5 | .42 | 914.9 |
| .46 | 916.1 | - | 914.9 |
| .44 | 916.7 | - | 913.8 |
| - | 916.7 | - | 914.8 |
| - | 916.6 | - | 914.8 |
| - | 916.4 | .49 | 915.0 |
| - | 916.2 | - | 915.2 |
| - | 916.2 | - | 915.1 |
| - | 916.1 | - | 914.4 |
| - | 916.5 | - | 914.6 |
| - | 916.6 | - | 913.4 |
| - | - | - | 913.4 |
| - | - | .42 | 913.4 |
| - | 915.6 | .50 | 914.9 |
| - | - | .57 | 915.1 |
| - | - | .57 | 915.1 |
| - | - | .55 | |
| - | 915.4 | | |
| - | 915.4 | | |
| - | 915.4 | | |
| - | 914.2 | | |

Well No. 2

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| Start at | Start at | | |
| 10:15 A.M. | 10:00 A.M. | .62 | 911.8 |
| .77 | 916.57 | .68 | 911.7 |
| .76 | 911.7 | .66 | " |
| .76 | 911.9 | .64 | " |
| .75 | 911.9 | - | " |
| .74 | 912.0 | .68 | " |
| .74 | 912.0 | .75 | " |
| .74 | 911.9 | .74 | 915.0 |
| .74 | " | .73 | 914.2 |
| .74 | " | .74 | 912.7 |
| .71 | " | .74 | 912.6 |
| .70 | " | .72 | 912.3 |
| .71 | " | .75 | 912.0 |
| .67 | " | .74 | " |
| .67 | " | .76 | " |
| .68 | " | .73 | " |
| .68 | " | .76 | " |
| .66 | " | .76 | " |
| .67 | " | .76 | 912.1 |
| .62 | " | .72 | 912.1 |
| .67 | " | .78 | 912.0 |
| .66 | " | .78 | 911.9 |
| .65 | 911.8 | .78 | 914.2 |
| .65 | 911.8 | .76 | 916.2 |

(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| .80 | 917.0 | .75 | 912.4 |
| .77 | 916.9 | .74 | 912.3 |
| .80 | 917.6 | .73 | 912.6 |
| .79 | 917.8 | .70 | 912.5 |
| .77 | 918.0 | .74 | 912.6 |
| .77 | 917.4 | .72 | 912.6 |
| .76 | 917.4 | .73 | 912.4 |
| .75 | 915.4 | .73 | 912.7 |
| .75 | 912.8 | .72 | 912.8 |
| .75 | 912.5 | .73 | 912.4 |
| .75 | 912.4 | .73 | 912.8 |
| .73 | 912.3 | .73 | 912.3 |
| .74 | 912.2 | .72 | 912.1 |
| .74 | 912.4 | .72 | 912.1 |
| .74 | 912.2 | .72 | 912.1 |
| .73 | 912.2 | .72 | 912.1 |
| .71 | 912.1 | .74 | 911.8 |
| .74 | 912.3 | .73 | 911.6 |
| .70 | 912.2 | .73 | 911.4 |
| .74 | 912.4 | .79 | 911.3 |
| .74 | 912.1 | .76 | 911.2 |
| .74 | 912.4 | .78 | 911.5 |
| .74 | 912.3 | .72 | 911.7 |
| .74 | 912.3 | | 911.6 |
| .74 | 912.4 | | 912.1 |
| .75 | 912.4 | | 912.8 |

Well No. 5

Discharge (h) Elev. of Water Discharge (h) Elev. of Water

Start at 8:45 A.M.


| | | | |
|-----|--------------------|-----|-------|
| | | .68 | 910.0 |
| | Start at 8:45 A.M. | | |
| | | .68 | 909.4 |
| .64 | 917.4 | .68 | 909.6 |
| .62 | 912.4 | .71 | 909.6 |
| .62 | 912.4 | .70 | 910.4 |
| .62 | 911.9 | .68 | 909.9 |
| .72 | 911.9 | .68 | 909.7 |
| .72 | 911.9 | .65 | 910.8 |
| .72 | 911.9 | .69 | 909.4 |
| .72 | 911.9 | .69 | 909.0 |
| .70 | 911.9 | .69 | 909.4 |
| .70 | 911.9 | .67 | 909.4 |
| .70 | 911.9 | .66 | 909.9 |
| .70 | 909.4 | .70 | 909.2 |
| .69 | 909.1 | .69 | 909.2 |
| .70 | 909.1 | .70 | 909.0 |
| .70 | 909.3 | .68 | 909.5 |
| .69 | 909.8 | .70 | 909.1 |
| .69 | 909.8 | .68 | 909.9 |
| .69 | 909.4 | .69 | 909.2 |
| .69 | 909.7 | .67 | 909.9 |
| .69 | 909.4 | .69 | 909.4 |
| .69 | 909.5 | .68 | 910.7 |
| .69 | 909.5 | .70 | - |

(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| .70 | - | .67 | 910.7 |
| .70 | 909.4 | .65 | 911.2 |
| .70 | 909.4 | .68 | 911.9 |
| .70 | 909.9 | .69 | 910.8 |
| .69 | 909.7 | .70 | 911.1 |
| .68 | 909.6 | .70 | 910.6 |
| .64 | 910.2 | .70 | 910.9 |
| .69 | 911.4 | .71 | 910.2 |
| .69 | 910.2 | .71 | 910.7 |
| .67 | 910.1 | .71 | 910.5 |
| .67 | 910.2 | .70 | 910.2 |
| .69 | 910.6 | .70 | 910.2 |
| .69 | 909.6 | .69 | 910.8 |
| .68 | 909.6 | .69 | 910.8 |
| .69 | 910.2 | .69 | 910.8 |
| .70 | 910.4 | .69 | 910.9 |
| .69 | 910.2 | .69 | 911.1 |
| .69 | 910.2 | .67 | 910.5 |
| .69 | 910.1 | .67 | |
| .69 | 910.1 | .67 | |
| .68 | 910.8 | .67 | |
| .67 | 910.9 | .68 | |
| .69 | 911.1 | .67 | |
| .69 | 910.4 | .68 | |
| .66 | 910.6 | .67 | |
| .69 | 911.9 | .66 | |
| | | .67 | |

Well No. 4

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| Start at | Start at | - | - |
| 2:45 P.M. | 2:50 P.M. | .74 | - |
| .58 | 917.04 | .72 | 917.0 |
| .68 | 914.0 | .70 | 914.4 |
| .66 | 912.4 | .72 | 912.0 |
| .57 | 911.2 | .68 | 912.2 |
| .62 | 911.4 | .74 | 912.4 |
| .62 | 911.6 | .72 | 912.2 |
| .68 | 911.7 | .71 | 912.0 |
| .62 | 911.1 | .75 | 912.0 |
| .62 | 911.4 | .70 | 912.1 |
| .61 | 911.2 | .64 | 912.1 |
| .65 | 911.5 | .68 | 911.7 |
| - | 911.4 | .71 | 911.4 |
| - | - | .78 | 911.4 |
| - | - | .74 | 911.4 |
| - | - | .74 | 911.7 |
| .67 | - | .72 | 912.0 |
| .68 | 911.6 | .70 | 912.2 |
| .66 | 911.6 | .72 | 912.4 |
| .67 | 911.1 | .68 | 912.0 |
| - | 911.1 | .68 | 912.4 |
| - | 911.1 | .68 | 914.2 |
| - | - | .66 | 912.0 |
| - | - | .66 | - |



(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| - | - | | |
| .80 | - | | |
| .72 | 914.0 | | |
| .70 | 913.0 | | |
| .72 | " | | |
| .74 | " | | |
| .72 | " | | |
| .72 | " | | |
| .70 | " | | |
| .70 | 913.2 | | |
| .71 | 913.4 | | |
| .72 | 913.8 | | |
| .70 | 914.0 | | |
| .68 | 914.0 | | |
| .70 | 914.0 | | |
| .72 | 913.8 | | |
| .70 | 913.4 | | |
| .72 | 913.7 | | |
| .74 | 914.0 | | |
| .72 | 913.5 | | |
| .72 | 912.0 | | |

Well No. 5

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| Started at | Started at | .70 | 915.7 |
| 4:45 P.M. | 6:30 P.M. | .70 | 915.8 |
| .72 | 916.68 | .70 | 917.8 |
| .67 | 912.3 | - | 917.8 |
| - | 912.3 | .74 | 918.3 |
| .72 | 912.6 | .74 | 917.4 |
| .71 | 912.5 | .70 | 916.3 |
| .73 | 911.7 | .80 | 917.3 |
| .77 | 912.1 | .82 | 916.3 |
| .71 | 911.1 | .78 | - |
| .74 | - | .76 | - |
| .64 | 912.6 | .76 | 916.3 |
| .66 | 912.8 | .74 | 915.4 |
| .72 | 911.5 | .76 | - |
| .70 | 910.8 | .80 | 910.8 |
| .60 | 918.3 | .74 | 911.2 |
| .66 | - | .76 | 911.8 |
| .62 | 912.8 | .76 | 911.2 |
| .69 | 912.8 | .78 | 911.2 |
| .78 | 912.8 | .76 | 911.8 |
| .76 | - | .76 | 911.3 |
| .80 | - | - | - |
| .78 | 912.1 | .68 | - |
| .80 | - | .74 | 911.8 |
| .78 | 915.7 | .76 | 911.3 |

(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| .68 | 911.3 | .66 | 911.2 |
| .70 | 911.9 | .72 | 911.2 |
| .70 | 911.9 | .70 | 911.2 |
| .76 | 911.9 | .65 | 910.6 |
| .72 | 911.3 | .68 | 910.4 |
| .74 | 911.3 | .66 | 910.4 |
| .72 | 912.8 | .70 | 910.4 |
| .74 | 912.0 | .66 | 910.4 |
| .72 | 912.4 | .69 | 910.6 |
| .76 | 912.9 | .70 | 910.6 |
| .74 | 912.9 | .69 | 910.6 |
| .74 | 912.5 | .72 | 910.5 |
| .74 | 912.4 | .71 | 910.5 |
| .68 | 912.2 | .70 | 910.5 |
| .70 | 911.3 | .70 | |
| .72 | 911.1 | .71 | |
| .67 | 911.2 | .69 | |
| .66 | 911.9 | .68 | |
| .69 | 911.6 | .69 | |
| .72 | 911.5 | .69 | |
| .71 | 911.3 | .70 | |
| .61 | 911.3 | .70 | |
| .77 | 911.4 | | |
| .72 | 911.4 | | |
| .72 | 911.3 | | |
| .68 | 911.2 | | |

Well No. 6

(Readings taken every 15 minutes)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| Start at | | .69 | 913.4 |
| 5:00 P.M. | | .68 | 913.9 |
| .65 | 913.32 | .67 | 913.4 |
| .69 | 912.40 | .66 | 913.4 |
| .62 | 913.90 | .65 | 913.4 |
| .605 | - | .62 | 914.4 |
| .59 | 914.4 | .65 | 914.9 |
| .61 | 914.4 | .71 | 914.4 |
| .62 | - | .69 | 913.9 |
| .62 | 913.1 | .68 | - |
| .62 | 913.1 | .76 | 914.4 |
| .61 | 913.4 | .74 | 913.8 |
| .61 | 913.4 | .74 | 912.8 |
| .63 | 912.9 | .79 | 913.4 |
| .62 | 913.2 | .73 | 913.4 |
| .65 | 913.4 | - | 914.0 |
| .66 | 912.9 | - | 913.4 |
| .57 | 914.5 | - | - |
| .67 | 911.9 | .77 | 913.2 |
| .70 | 911.8 | .76 | 913.2 |
| .68 | 913.4 | .76 | 914.4 |
| .68 | 912.2 | .77 | 914.4 |
| .67 | - | .82 | 912.2 |
| .66 | 913.4 | .76 | 913.9 |
| .67 | 913.4 | .77 | 914.1 |

(Continued)

| Discharge (h) | Elev. of Water | Discharge (h) | Elev. of Water |
|---------------|----------------|---------------|----------------|
| - | - | .73 | 911.1 |
| - | - | .69 | 911.2 |
| .65 | - | .66 | 911.2 |
| - | - | .65 | 909.1 |
| - | 914.4 | .79 | 909.0 |
| - | 912.9 | .70 | 909.2 |
| .65 | - | .78 | 908.4 |
| .77 | 912.9 | .77 | 908.7 |
| .- | 914.4 | .77 | 908.5 |
| - | - | .77 | 908.9 |
| .74 | - | .75 | 909.5 |
| - | - | .79 | 909.4 |
| - | 914.4 | .68 | 909.5 |
| - | 912.9 | .67 | 909.6 |
| .65 | - | .67 | - |
| .67 | - | - | - |
| - | - | - | 908.6 |
| - | - | .77 | 908.6 |
| - | - | .77 | 908.5 |
| - | - | .68 | |
| - | - | .76 | |
| - | - | .77 | |
| - | 914.1 | .76 | |
| - | 910.2 | .82 | |
| .61 | 911.1 | | |
| .69 | 910.2 | | |
| .68 | 910.0 | | |

Probable Available Yield of Ground Water at Losey Avenue Site.

From the curves which have just been shown in this report, we are able to make some estimates as to the quantity of water which might be expected at the Losey Avenue site. These curves show the tests that were made upon the six new wells drilled in 1923. The following conclusions have been drawn after a study of this available data, and after a personal investigation of conditions at the new pumping station.

That the available yield of one of a number of 12 inch wells spaced 300 feet apart in the Losey Avenue area, would be at least one million gallons per day, and probably would amount to nearer one and one half million gallons per day.

In the area at the Losey Avenue site, there could be developed as many as ten 12 inch wells spaced 300 feet apart.

That such a development would have very little effect if any, upon any existing ground water development in the down town section of the city.

That such a scheme of development might be continued in adjacent areas, south of the Losey Avenue site.

That in lowering the six wells eight feet, there would be a yield of six million gallons.

It would appear that there might be developed an average daily rate of 10 to 15 million gallons of water in the immediate vicinity of Losey Avenue, and that this amount could probably be increased during the hours of greatest demand.

According to Superintendent Hatch the six new wells will be connected to the existing pumping system some time in June of this year. He also says, that contracts have been let for pumping machinery and boilers for the new plant, which will be of the latest and most efficient type. The work on the storage reservoir with a capacity of three million gallons is well under way at the present time. If there are no delays in the construction work, the new station will be in operation early in the year 1925. This will give the city of Jackson a water system, along with adequate supply of water, which will serve an estimated population of 118,000 in 1950.

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that proper record-keeping is essential for transparency and accountability, particularly in financial matters. The text suggests that organizations should implement robust systems to track every detail, from small expenses to major investments, to ensure that all data is reliable and accessible.


2. The second section focuses on the role of technology in modern record-keeping. It highlights how digital tools and software can significantly reduce the risk of human error and improve the efficiency of data management. The author argues that adopting advanced technologies is not just a convenience but a necessity for staying competitive in today's fast-paced market.

3. The third part of the document addresses the challenges of data security and privacy. It notes that as organizations collect and store more information, the risk of data breaches increases. To mitigate this risk, the text recommends implementing strong security protocols, including encryption and regular security audits, to protect sensitive information from unauthorized access.

4. The fourth section discusses the importance of regular audits and reviews. It states that periodic checks of records are crucial for identifying discrepancies, errors, and areas for improvement. The author suggests that organizations should establish a clear schedule for these audits and ensure that all relevant personnel are involved in the process.


5. The final part of the document provides a summary of the key points and offers some concluding thoughts. It reiterates that maintaining accurate and secure records is a continuous process that requires ongoing attention and investment. The author concludes by encouraging organizations to embrace best practices and stay updated on the latest trends in record-keeping technology and security.

HEAD & DISCHARGE CURVES WELL NO. 1.




HEAD & DISCHARGE CURVES WELL NO.2

Average Discharge 712,000 Gal/day
Minimum " 522,000 " "
Maximum " 947,000 " "




HEAD & DISCHARGE CURVES WELL NO.3




HEAD & DISCHARGE CURVES WELL NO. 4.

Average Discharge 669,000 gal/day
Minimum " 408,000 " "
Maximum 942,000 " "




HEAD & DISCHARGE CURVES WELL NO. 5

Average Discharge 701,000 Gal.
Minimum " 464,000 "
Maximum " 1,000,000 "




HEAD & DISCHARGE CURVES WELL NO. 6.


Average Discharge 690,000 Gal.
Minimum " 407,000 "
Maximum " 1,031,000 "




HEAD & DISCHARGE CURVE AT MINIMUM RATE




HEAD & DISCHARGE CURVE AT AVERAGE RATE




HEAD & DISCHARGE CURVE AT MAXIMUM RATE




HEAD & DISCHARGE CURVE AT VARIABLE RATE



SUMMARY HEAD & DISCHARGE CURVE





GRAND RIVER MILL POND

TO CITY DISTRIBUTION SYSTEM.

COLUMBIANA ST

NORTHERN

BELDING ROAD

MUD LAKE

BOILER HOUSE

PUMP BUILDING

FUTURE CHEM. BUILDING

WATER FILTER BUILDING

3 MG STORAGE RESERVOIR

FUTURE ADDITIONAL STORAGE

FUTURE SEDIMENTATION BASIN

12"

16" PRESENT LOW SERVICE PUMPING STATION

12"

PRESENT 12" DRILLED WELLS

30"

30"

30"

30"


30"

12"

12"

12"

12"



NO. 2

JACKSON MICHIGAN.
REPORT UPON WATER SUPPLY
GENERAL PLAN OF PROPOSED
WATER WORKS IMPROVEMENT
SCALE 1"=200' MAY 13, 1924
BY
W.C. JOHNSON, & C.M. WALTZ.

SOUTH

STREET



PUMPING STATION ON WATER STREET



MILL POND AT THE WATER WORKS.





BRICK BUILDINGS OVER CENTRIFUGAL PUMP & SETTLING WELL.



$\frac{1}{2}$ MIL-GAL. RESERVOIR ON WATER STREET



~~_____~~
Pocket has:

CONTENTS OF POCKET.

- 1. Map of Jackson with Water Mains
- 1. Tracing of Plan of Pumping Station
- 1. Map of New Pumping Station No. 2
- 1. Map of Present Wells No. 1
- 4. Negatives - 2 of 1st Map


SUPPLEMENTARY
MATERIAL

NO. 1


MAP OF
JACKSON'S WATER SUPPLY
SHOWING
WELLS AND STATIONS



- PRIVATE WELLS.
- CITY WELLS




WATER MAINS




MAP OF THE CITY OF JACKSON

~ MICHIGAN ~
BY

W.C. JOHNSON & C.M. WALTZ



CLASS
OF
1924



MICHIGAN STATE

MICHIGAN STATE UNIV



3 1293 030

113

042

TKS

Map no. 1

SUPPLEMENTARY
MATERIAL

MICHIGAN STATE UNIVERSITY LIBRARIES



3 1293 03062 3056