

LIBRORY Michiga State University

PLACE IN RETURN BOX to remove this checkout from your record. TO AVOID FINES return on or before date due. MAY BE RECALLED with earlier due date if requested.

l

DATE DUE	DATE DUE	DATE DUE	

6/01 c:/CIRC/DateDue.p65-p.15

A Complete analysis of the problem involved in the Heating and Ventilating of the R.E.OLDS HALL OF ENGINEERING

at

the

MIUHIGAN AGRICULTURAL COLLEGE

A Thesis submitted to The Faculty of MICHIGAN AGRICULTURAL COLLEGE

BY

R.D. WHITE.

Candidate for the Degree of

Bachelor of Science

June ,1916.

THESIS	1 .		
137	•	ħ	
62.2			
THE			

. .

. . .

-

-

The requirement for proper ventilation in public buildings of today has led to various methods of combined Heating and Ventilating installations.

< '

The combined system used in the following pages is known as the Attic Steam Main - Plenum Warm Air, the Attic Steam Main delivering the heat for direct radiation while the Plenum Warm air is used entirely for Ventilation The two fundamental points in view are, first; to supply the entire radiation loss from the building with heat del ivered by exhaust steam under five pounds pre-sure to each individual room by American Cast Iron Radiators, secondly; to supply the entire ventilation loss from the building by the use of force draft Plenum fans, the ventilating air to behated from the cutside temperature to the temperature required for delivery to the various rooms by means of Flenum Coils of such dimensions that the air shall enter the fair air duct fromt the Fans at a constant velcoity and a constant temperature.

The mothed usel in determining the heat loss by radiation was to obtain from standard practice constants for the rate of transmission of the heat in F.T.U. per hour per square foct of exposed area per degree difference in temperature between the inside and the outside air. To obtain the heat loss by radiation from the rooms per hour the prochedure was as follows:-

Determine the number of square feet of exposed glass area. The constant for single pane glass as taken from several authorities namely Hoffman, Hauss and Wolff who agree very closely, is one E.T.U. per hour per degree difference in temperature between the inside and the autside air per square foct of exposed area. This constant times the total exposed glass area in square feet gives the number of E.T.U. radiated from the room through the glass per hour per degree difference on temperature.

The next step was to determine the total exposed wall area in square first, deducting the glass area as found in the first step. The constants for different thicknesses of wall, as recommended by the authorities before stated are; tabulated on a following page in the computations. The total wall area in square feet times the constant for the rate of transmission through that thickness of wall, gives the total heat loss through the walls of the room in B.T.U.per hour per degree difference in temperature between the inside air and the cutside air.

The next step in the determination of the heat loss ffom the rooms is to find the exposed ceiling area in square feet. This area times the constant for the rate of transmission through the ceiling, which is .10P.T.U. per hour per square feet of exposed area per degree difference in temperature between the inside and the eutside air gives the heat loss for the room through the ceiling in B.T.U. per hour per detree lifference in temperature.

The total volume of the room was next computed. This volume times the constant for the rate of leakage and transmission of heat from the room in B.T.U. per cubic foot per hour por degree difference in temperature gives the heat loss from the room in B.T.U. per hour per degree difference in temporature.

The total wall area as computed has to have added t to it a certain percent of the exposed area, which depends on the divrection of exposure. The percentages allowed for exposure for the different rooms are given on a following page of constants for the building.

The final step in the computations for the total heat loss in P.T.U. per hour from the rooms is tomultiply the sum of the heat losses through the windows ,walls, coiling and by convection from the rooms by the degree difference in temperature between the inside and the outside air, which for the case under consideration was 70°.

The forgoing principles follow very closely the formulae recommended by Professor Carpenter for obtaining the heat losses, from a room, due to radiation,

To determine the net radiation surface required to supply the radiation losses from the different rooms the formulae recommended by Professor Holfman in his Heating and Ventilating Handbook from data used in standand practice is

 R_{3----} H/1.7(te-t)

Es---- Total radiation surface, in square feet, required for the room.

1.7--- is the number of B.T.U. given off by one square foot of radiating surface per hour. H--- Total Heat loss from the room.in B.T.U.

per hour.

t----temperature of the room. ts---temperature of the steam.

After determining the total net radiation surface required to supply the radiation loss from the rooms, it was necessary to determine the size of radiator to install in the rocms. The computed net area of the in square feet of the radiation surface , divided by the radiation surface per stack as given by the American Badiator catalogue determines the number of stacks required for the room. These stacks were then built up into the proper size of radiators for the room under consideration.

In the determination of the size of radiator for the room, the height depended on the distance from the floor to the window cill and was first considered in finding the number of stacks for the room under con-sideration. In order that the rediator would not be exce dingly long the width of the stacks and the number of columns per stack were so proportioned as to be best suited for the room in which they were to be placed.

For the ventilation of public buildings each individual requires a definite amount of Ventilating air per hour. Expressed in cubic feet per hour this value is a constant fortthe case under consideration being about 1800 cubic feet, which is considered cy authorities as sufficient for good ventilation where the occupants of of the room are not doing physical exercise. After determining the amount of air necessary for the building the total heat loss by Ventilation is found by applying hhe formulae:-

H' equals **Q(t-t')/55

H' ****Heat loss by Ventilation from the building

Q *****Total number of cubic feet of ventilating air required per hour for the building.

t ***** Temperature of the air entering the room from the register.

t' ***** Temperature of the air in the room.

55 ***** the number of degrees through which one cubic foot of air is heated by one B.T.U.

This formulae reduces to :-H'-----.3122 x Q for t---87.2° t'--70.0°

The Blenum Fans must deliver the total ventilating air required for the building. Knowing the number of cubic fift of air to be delivered to the rooms per hour the number of cubic feet delivered per minute is found. From the American Blower Companies Fan catalogue on Steel plate type of Fans the capacity of their different sizes is given in Cubic feet of air per minute. The back pressure or static pressure against which the fan delivers this air is one inch.and size Number 180 is necessary to completely ventilate the building properly.

The Plenum Coils through which the fan takes its Ventilating air to deliver it to the rooms has to be of such a depth with the air passing over the coils atea specified velocity as to raise the air from outside temperature to the temperature of delivery to the rooms. The limiting velocity of the air ,acting against a state pressure in Mheemain air duct, and passing over the coils such that upon leaving the fan it will have attained the proper amount of heat and be most edonomical in the nume ber of stacks in the heater are given in the Buffalo Forge Companies Fan an Heater Catalogue. From this data the depth of heater is obtained which will raise the ventilating air from autside to delivery temperature each section of the heater being four pipes deep. The total number of square feet of surface required forthe heater to raise the volume of air to be delivered by the fan to the building to that degree of temperature necessary to supply the ventilation loss. The formulae used in the calculation of the heating sur-

face is:-Res equals H'/7.8(ts- t plus te)

Rs***** Heat surface.

H'***** Heat Loss by ventilation from the building. 7.8 ***raye of transmission of heat to the air

passing through the coils.

t***** temperature of air entering the room at the register.

ts **** temperature of the steam in the heater.

t's *** temperature of the room.

This total radiating surface required in the heater divided by the number of coils deep the heater must be to obtain the proper temperature of delivery, gives the number of square feet of surface per stack in the heater. The Buffalo Forge catalogue value for the depth of heater required to obtain the proper temperature for the ventilating air,87.2° in thes case checks the value for the depth of heater as taken from the J.D.Hoffman Handbook on Heatigggand Ventilating and the requirement in a depth of twenty pipes or four sections of four pipes to a section The size of heater is then obtained by referring to the table on the sizes of Buffalo Standard Heaters.

For the quantity of air to be delivered by the fan per minute the free air space is determined by dividing the number of cubic feet supplied by the velocity of the air over the coils in feet per minute. This value should check the value found for the free air space in the heater determined upon and does within seventy one hundredths of a square foot.which is as close a value as can be obtained.

The size of air ducts required for the delivery of the ventilating air to the various rooms is found by :-

A-----144Q/60V

A ***** Area of the duct.

Q ***** Quantity of air to be supplied by the duct, in cubic feet per hour.

V ***** Velocity of the air in the duct at the point at which the section is to be determined, Velocity in feet per minute.

144/60 a factor which reduces the area of the duct to square-fnches of cross-sectional area.

The above formulae applies to any portion of the ventilating air duct and gives a result in square inches from which the dimensions of the duct are determined.

All radiators are to be of Cast Iron and of the American Fadiator Companies make.

Radiator connections and piping including the steam main and return equipment are to be of the Crane Companies make and to be of standard Cast Iron material threaded and reamed and ready for assembly.

Heater connections and piping to be of the Puffalo Forge make and of the kind specified in the Heater equipment accessary for the heater determined upon. Window Scheduel and sizes for:-

Basement:-

West side:-(54-42) 2(26-34)***-----28.03 square feet. ------28.03 square feet. ------30.13 Square feet. ------27.22 square feet. East side:-(54-42) 2(26-34) North side-(58-42) 2(28-34)South side (48-42)2(28-34)First floor:-West side:-(54-50) East side:-(54-50) North side-(58-50) 2(26-42)----- 33.90 square feet. 2 (26-42) 2 (28-42) 2 (28-42) 2 (28-42) ------33.90 square feet. ----- 36.50 square feet. South side-(58-50)----- 36.50 square feet. Second floor:-West side: - (54-48) 2(26-40) -----33.8 square feet. East side: -(54-48)2(26-40) ----- 33.80 square feet. -----34.90 square feet. North side (58-48)2(28-40) South side-(58-48)2(28-40)----- 34,90 square feet. Third floor:-West side: - (54-46) 2(26-36) ----- 30.25 square feet. East side: -(54-46)2(26-36) ----- 30.25 square feet. 2 (28-36) North side-(58-46) South side-(58-46) 2(28-36) Fourth floor:-West side:-(2(26-34) -----I2.30 square feet. *-----I2.30 square feet. East side: - 2(26-34) North side-2(28-34)-----I3.22 square feet. South side-2(28-34)-----I3.22 square feet. South side center windows above Mechanical Laboratory. Second floor:-(40-40) I(40-48) ------24.44 square feet. Third floor:-(40-36) I(40-46) -----22.77 square feet. Fourth floor: -(2(20-34))----- 9.44 square feet. West windows in East wing above Mechanical Laboratory. Second Floor:-(58-48) 2(28-40) -----34.90 square feet. Third floor :(58-46) 2(28-36) -----32.53 square feet. Fast windows West wing above Mechanicl Laboratory. Second floor:-(none) Third floor:-(58-40) 2(28-36) -----32.53 square feet. Fourth floor: -(2(28-34))-----I3.22 square feet.

Heating and Ventilating Calculations for the Basement of the New R.E.Olds Mechanical Building.

Basement.

Window scheduel:-

West side	1(54x42)	2(26x34)	28.03	square feet
East side	1(54x42)	2(26x34)	28,03	square feet
North side	1(58x42)	2(28x34)	30.13	square feet
South side	1(48x42)	2(28 x34)	27.22	square feet

Wall and window constants :-

Heat transmission	.222 for 20 " wa	11
Heat transmission	1.000 for gla	58
South exposure	5 percent	
East exposure	15 percent	
North exposure	25 percent	
West exposure	25 percent	
Height of ceiling	13 feet 6 inches	
Height of window cill from floor	2feet 10 inches	

Radiator heights except for corrid**prs** 32inch. American Radiators used of Cast Iron , two colmmn, eight inches wide three inches thick with a total radiating surfaceof 3.33 square feet per stack.

Formulae:-

Total Heat loss by radiation:- H: (Gplus ktimes W plus.O2nC) tx H ----Total Heat loss in B.T.U.per hour. G ----Total Glass area in room. k ----Constant on heat transmission through the walls. W ----Total wall area exposed minus the glass area. n ----Total wall area exposed minus the glass area. n ----Cubic contents of the room. tx ----Cubic contents of the room. tx ----difference in temperature between the inside air and the outside air.

Quantity of air required per hour for ventilation Q:1800 n 1800 cubic feet required per person per hour. n --- the number of person requiring air.

Total heat loss by ventilation H': $Q(\underline{t-t'})$

Q---ventilating air required. t---temperature of the air at the register. 87.20 t'--temperature of the air in the room. 70 55 --a constant denoting that one cubic foot can be heated through 55 degrees by one B.T.U. (of air) With t at B742 and t' at 70 this formulae develops into H' equals D.3122times Q the air required for ventilating purposes. Basement .

Formulae continued:-

RsRadiator surface--Rs- H equals.004 H 1.7(220-70)

I.7 --represents the rate at which the radiator surface gives off heat in B.T.U. per square foot per degred difference between the temperature of the air surrounding the radiator and the a average temperature of the heating medium which is taken at 220° for exhaust steam at five pounds gage at which this system receives it .The temperature of the surrounding air being room temperature 70 degrees.

In calculating the radiation surface the actual amount as found by the preceeding formulae is increased by twenty five percent to take care of ventilating losses.

This formulae reduces to .005 H.

With a given quantity of air passing through the main air duct, the calculations for which are shown under the Plenum and Ventilating side of the problem for the size of main duct required and the branch ducts, the velocities of air entering the different rooms for ventilating purposes was taken depending on the use of the room and the number of occupants between hhe limits of One hundred and Five hundred feet per minute holding close to standard practice.

Assuming an air velocity for the register with a known amount of air to be furnished to the room per hour the formulae for the area of the gross register is :-

A equals Q' the ventilating air times 144/60V The fraction 144/60 converts the Quantity of air per hour to the quantity per-minute for the use of V in feet per minute, while the term 604 makes the final answer in square inches of groes area of register. This formulae takes the form of

A equals 2.4 times Q'/V which is applicable for any part of the ventilating ducts in determining its sectional area.

From the gross area of the register the size of the opening is determined, the width of the opening being recorded first and the depth second in my tabulations.

The temperature of the steam under five pounds pressure as supplied to the heating system has a temperature of 220°

The temperature of the ventilating air leaving the registers is 87.3.

The temperature of the rooms is to be kept at 70 degrees with an outside temperature of zero degrees thus allowing for the worst possible condition.

The preceeding formulae apply to each room individually in determining the several items enumerated. These apply through out the building and are used for each room separately in the salculations.

Radiation losses plus twenty five percent of the se losses are supplied by direct radiation, while the Plenum Fan furnishes all Ventilation loss in the building. Constants for Heat Transmission through the Walls, Windows and Doors, in B.T.U. per square foot per hour per degree difference of Temperature.

Percentages allowed for exposures :-

South	exposure		.05
East	exposure	****	- 15
West	exposure	∰an (an ân ân ân ân ân an ân ân ân ân ga ga ga ga ga ga ga ga an	25
North	exposures		25

In the use of these constants the percentages of exposure were used in determining that amount of area of exposed surface sufficient to transmit from each room as calculated a greater number of B.T.U. than would adtually be radiated by the wall exposure which the room actually has. In this way sufficient heat is found by the formulae for total radiation loss to overcome twenty five percent more radiation area, in the case off north or west exposure, than it would seem necessary but due to the high velocity of the wind over exposed surfaces, it literally wipes off that excess twenty five percent of heat which these constants supply in the total heat loss.

By the constants of heat transmission the actual rate of passage of the heat Brom the room to the exposed surface in B.T.U. per square foot per hour per degree of difference of Temperature is allowed for in the total heat loss formulae.

The formulae used in determining the total heat loss from each room by radiation is:-in B.T.U. per hour.

Heat loss equals-(Glass area (plus) the constant of Heat transmission for that thichness of wall exposed, times the wall area exposed with the percentage of expossure added (plus) .02 times the number of changes of air required in the room times the total volume of the room in cubic feet) all multiplied by the difference in temperature between the inside and outside air which was taken as seventy degrees for this locallity.

All area in this formulae is in square feet and all voluma in cubic feet. For fourth floor losses there has to be added to this formulae, before multiplying by the temperature, the constant for Heat transmission through the ceiling times the number of square feet of exposed roof area, also I.2 times the total square area of exposed roofing has to be used instead of the actual roof area in order to take sare of the exposure. losses Calculations for the Heat Losses in B.T.U. per hour per degree difference in Temperature, Square inches of net register area for ventilating the rooms, Square feet of net radiator surface required to supply the radiation loss, The amount of Ventilating air required for each room in Cubic feet per hour.

BASEMENT.

Constants for the basement:-Height of windows from the floor---- 2'10" Height of Radiator used ----- 32" Number of column to each radiator section----2 ROOM(I). DIMENSIONS of ROAM -(22'6"x17'x13'6") -(6'6"x3'6"x13'6") Dimensions of stack - (2 x4 x13'6") - (4x8'6"x13'6" Windows -- Two north @ 30;13 square feet--- 60.26 TOTAL (17x13,5) plus.25(17x13.5) minus 60.26--227.20 TOTAL Walls (22.5x17x13.5) plus(6.5x3,5x13.5) ----4721.62 TOTAL Volume Heat Loss-- (60.26 plus. 222 (227.2) plus. 02x1x4722) 70--Radiation Loss--14,357 B.T.U. per hour. 5 1800 Cubic feet of air required per hour 5x1800-----9000 Heat Loss by ventilation 9000x.3122 ----- 2810 B.T.U. Radiator surface required for the room 14357x.005----- 73 1/3 square feet Number of sections to a raddator -----11 Number of radiators -----2 ROOM (2) DIMENSIONS of ROOM--(11'6"x22'6"x13'6") Dimensions of Stack-(2'x7'g13'6") Windows-- One north @30.13 square feet 30.13 TOTAL Walls __11.5x13.5)plus(.25(17.513.5)-30.13-163.9 TOTAL Volume--11.5x22.5x13.5)-(2x7x13.5) ----- 3304.00 TOTAL Heat Loss--(30.13 plus.222(163.9)plus.02x1x3304)70-----Radiation Loss--9280 B.T.U. per hour. Number of people to be accomodated ------ 4 Number of Cubic feet per person ----- 1800 Number of Cubic feet of air per hour 4x1800----- 7200 Heat Loss by Ventilation 7200x.3122-- 2252 B.T.U. Radiator surface required for the room 9280x.005-----46 2/3square feet Number of radiators ----- 1 Number of sections to a radiator -- 14

The constant used in determining the Ventilation loss.3122 is the temperature of the air entering the room from the fan(87.2) minus the room temperature (70) divided by the number of degrees through which one cubic foot of air can be raised by one B.T.U. This constant times the number of cubic feet of air supplied to the room for ventilating purposes gives the number of B.T.U. lost by the ventilating air

ROOM(3)DIMENSIONS of room (22'6"x29'x13'6") Dimensions of stack(28'x2'x13'6") Windows-- Swo North @3013 -----60.26 square feet Walls (22.5x13.5) plus (22.5x13.5).25 -60.26--319.43 Volume (22.5x29x13.5) -----minus 7569 --8053 Cubic feet Heat Loss ----- (60.26plus.222(319.4)plus.02x1x8053)70 Radiation loss--20454 B.T.U. per h Number of people to be accomodated 15 Number of Cubic feet per person 1800 Cubic feet of air required per hour----27000 Heat loss by Ventilation 27000x.3]22--8450 Radiator surface required for the room ---20454x.005 -----103 1/3 square feet Number of Sections to a Radiator ---15 ---16 Number of radiators installed 2 ROOM(4)DIMENSIONS of room(22'6"x40'x13'6") Windows --- Four East @28.03----- 112.12 Two North @30.13---- 60.26 Total-172.38 Walls ((22.5plus 40)13.5 plus.4(22.5plus40)-172.38-705.00 Volume22.5x40x13.5) ------12150 Heat Loss----(172.38 plus.222(705)plus.02x1x12150)70 Heat Loss by radiation--- 40033 B.T.U. Number of people to be accomodated -----10 Number of cubic feet of air per person---1800 Number of Cubic feet to be supplied per hr- 18000 Heat Loss by Ventilation --- 18000x.3122--5630 Radiator Surface required for the room--203 1/3 40033x.005--Number of Radiators installed 3 Number of stacks per radiator 2(20) 1(21) ROOM(5)DIMENSIONS of Room (29x26'6"x13'6") Dimensions of stack(16x1'6"x13'6") Windows----Three South@ 27.22--81.66 square feet Three East @28.03---84.09 . 11 Total 165.75 Walls ((29plus 26.5)13.5 plus. (29plus26.5)13.5-165175--598.5 Volume(29x26.5x13.5)-(16x1.5x13.5)---10057.0 Heat Loss (165.75 plus.222(598.5) plus.02x1x10057) 70---Heat Loss by radiation--35112 B.T.U. per hr. Number of people to be accomodated---10 Number of Cubic feet to be supplied per person 1800 Number of Cubic feet of air per Hour----10x1800--18000 Heat Loss by Ventilation 18000x.3122--5630 Radiation surface required per room---35112x.005----176 2/3 Number of Raddators installed 2 Number of Sections per Radiator 1(26) 1(27)

1 1 - 1 · · · · ·

٠.

Room(6)DIMENSIONS of Room(10x29x13.5) Windows -- One South @27.22-----27.22 square feet Walls (10x13.5)plus.05(10x13.5)-27.22--114.53 Volume ---(10x29x13.5) 3915 c cubic feet Heat Loss-(27.22plus.222(114.53)plus.02x1x3915)70 Heat Loss by Radiation Number of peoplle to be accomodated 9170 B.T.U. 3 Number of cubic feet to be supplied per person 1800 per hous Number of Cubic feet to nbe supplied per hour 5400 Heat Loss by Ventilation (5400x,3122)--1690 Radiator surface required for the room--9170x.005--46 2/3 Number of Radiators installed 1 Number of Stacks per Radiator 14 ROOM (B) Dimensions of Room(26'6"x38'6"x13'6") Dimensions of stack(15'x1'6"x13'6") Windows-- Three South@27.82---81.66 square feet Walls----(26.5 x13.5)plus.05(26.5x13.5)-81.66---294 Volume of the Room (26.5x38.5x13.5)-15x1.5x13,5)--13472 Cu. Ft Heat Loss -- (81,66plus.222(294) plus.02x1x13472)70 Heat Loss by Radiation--29848 Number of people accomodated Number of cubic feet of air per person 10 1800 Number of Cubic feet of air per hour (10x1800)--18000 Heat Loss by Ventilation -- (18000x.3122) -- 5630 Radiator surface required for the room:-29848x.005 --150 Number of Radiarors installed 1(23) 1(22)Number of stacks per Radiator ROOM(8)DIMFNSIONS of Room (This Room is the Mechanical Laboratory and has sufficient Heat developed in it to supply its heat loss so does not have to be considered in the calculations. ROOM(9)DIMENSIONS of Room(17'x10'6"x13'68) Dimensions of the Stack(10'6"x1'6"x13'6") Windows ----none Walls exposed none Volume(17x10.5x13.5) - (10.5x1.5x 13.5)Heat Loss -- (VOLUME) x. 02x1x70----- 3076 B.T.U. Number of people accomodated Number of cubic feet of air per person 3 1800 Number of Cubic feet of ait per hour 5400 Heat Loss by Ventilation (5400x.3122) 1690 Radiator surface required for the room 16 2/3 3076x.005 Number of Radiators installed 1 -5 Number of stacks per Radiator

ROOM(10)DIMENSIONS of Room (28x27x13'6") Dimensions of stack None Windows--Three South @27.22 ---82186 SQ. Ft (28x13.5) plus.05(28x13.5)-81.88-- 315.2 " (28x27x13.5)--- 10206 Cu Walls Volume Cu.Ft Heat Loss by Radiation:-(81.66 plus.222 (315.2) plus.02x1x10206)70 Heat Loss------ 24976 B.T.U. per Hour. Number of people to be accomodated 20 Number of Cubic feet of air per person 1800 Number of Cubic feet of air per hour(20c1800)---36000 Heat Loss by Ventilation(36009.3122) ---- 11270 Radiator surface required for the room:-24976x.005 -----126 2/3 Number of Radiators installed 2 Number of Stacks per Radiator 2 (19) ROOM(11) DIMENSIONS of Room (36'6"x38'6"x13'6") Dimensions of Stack (31'6"x1'6"x13'6") Windows-- Four West @ 28.03 112.12 Four South @ 27.22 108.88 221 To Walls (36.5plus38.5)13.5plus.25 (75x13.5)-221---- 1044.6 Windows--Four West @ 28.03 112.12 221 Total. Volume(36.5x38.5x13.5)-(21.5x1.5x13.5)---18535.4 Heat Loss by Radiation (221 plus.222(1044.6) plus.02x1x18535.4)70 Heat Loss ----- 57653 B.T.U. per hows Number of people to be accomodated Number of Cubic feet of air per person 30 1800 Number of Cubic feet of air per hour 54000 Heat Loss by Ventilation (54000x.3122) 16900 Radiator surface required for the Room 276 2/3 57653x.005---Number of radiators to be installed 4 3 (20) Number of stacks per Radiator 1(23) ROOM(12)DIMENSIONS of Room(34x29x13'6") Dimension of Stack(23'x1'6"x13'6") Windows---Three Northe 30;13-----90.39 Three West @ 28.03-----**84.0**9 174.48 Total Walls--(34 plus 39)13.5 plus25%(63x13.5)-174.48--888.60 Volume = -(34x29x13.5) - (23x1.5x13.5)12793.50 Heat Loss by Radiation:-(174.48plus.222 (888.6)plus .02x1x12793.5)70 Heat Loss ----- 43,960 B.T.U. per howr Number of people to be accomodated 30 Number of cubic feet of air per person 1800 Number of cubic feet of air per hour 54000 Heat Loss by Ventilation 54000x.3122 16900 Radiator surface required for the room 43,960x.005----220 Number of Radiators installed 3 3 (22) Number of stacks per radiator

• 1 •

.

1 • • • • • •

[.]

[•]

ROOM(13)DIMENSIONS OF Room (12x29x13'6")plus5'6"x5'x13'6") Dimensions of stack(6x8x13'6") Outer dimensions of a closet Windews----One North @30.13---30.13 sq.Ft Walis (12x13.5) plus. 25 (12x13.5) minus 30.13--172.3 Volume -- (12x29x13.5) plus6x8x13.5)-5.5x5x13.5--4422 cu.Ft. Heat Loss by Radiation:-(30.13 plus.22²2(172.3) plus.02x1x4422) 70 Heat Loss---10976 B.T.U. per hour Number of people to be accomodated 5 Number of Cubic feet of air per person Number of Cubie feet of air per hour 1800 9000 Heat Loss by Ventilation (9000x.3122)--2815 Radiator Surface required for the room 10976x.005 56 2/3 1 Number of Radiators installed 17 Number of Stacks per radiator ROOM(14)DIMENSIONS OFRoom (22'6"x20'x13'6") Dimensions of stack(llx2xl3'6") Windows----(Two North @30.13 60.26 square feet Walls -- (20x13.5) plus.25 (20x13.5) - 60.26--277.20 Volume --22.5x20x13.5)-11x2.13.5)------5778.00 Heat Loss by Radiation:-(60,26plus .222(277.2)plus .02x1x5778)70 Heat Loss-----16618 B.T.U. per hour Number of people accomodated 10 Number of Cubid feet of air per person Number of cubic feet of air per hour 1800 18000 Heat Loss by Ventilation (18000x.3122) 5630 Radiator surface required for the room 83 1/3 16618x.005) ____ Number of Radiators installed 2 1(12) Number of Stacks per radiator 1(13) ROOM(15) DIMENSIONS OF Room(8'6"x32'6"x13'6") Dimensions of stack\$4x3x13'6") Windows --One North @30.13 30.13 Sa.Ft Walls -- (8.5x13.5) plus .25(8.5x13.5)-30.13--113.3 SQ.Ft. Vojume -- (8.5x32.5x13.5) - (4x2x1#35) -----2473.9 Cu/Ft. Heat LOSS by Radiation r (30.13 plus.222(113.3) plus .02x1x2473.9) 70 Heat Loss----7334 B.T.U.per hour Number of people to be accomodated Number of Cubic feet of air per person 6 1800 Number of Cubic feet of air per hour 10800 Heat Loss by Ventilation (10800x.3122)--3380 Radiation Surface required for the room 36 2/3 7334x.005----Number of Radiators installed 1 11 Number of stacks per Radiator

FIRST FLOOR. Room air to be heated to 70° by direct radiation , the Ventilating air to be supplied to the rooms as a separate unite at a temperature of 87.2°. The Constants for the first floor are :-For Heat Transmission through 20" wall:- .223 For Heat Transmissionnthrough single Glass--1.00 Window Scheduel :-West Side----Fast Side----North Side ----33.9 square feet 33.9 square feet 36.5 square feet 36.5 square feet Sou th Side-----Room heat Losses figured individually as numbered on the Floor design. Height of windows from the floor--- 2'6" Height of Radiators installed 26" Number of column per stack 3 Number of column per stack 3 Square feet of heating surface per stack--- 3.75 sq.ft Cast Iron Radiators (BEERLESS) installed. ROOM (101) DIMENSIONS of Room(9x20'6"x13'6")minus(2x4.5x13'6") Dimension of stack(2x4x13'6") Windows -- One North @36.5 36.5 sq.ft. (9x13.5)plus 25%(9x13.5)-36.5----- 115.3 * * Walls Volume (9x20.5x13.5)-(2x4x13.5) 2613 Cu.Ft Heat Loss br radiation:-(36.5plus.222(115.3plus.02(Lx2613))70--Heat Loss-----8008 B.T.U. per howr. Number of people accomodated 2 Number of Cubic feet of air per person Number of Cubic feet of air per hour 1800 3600 Heat Loss by Ventilation 3600x.3122 1125 Radiator surface required for the room:-41 1/4 8008x.005 ---Number of Radiators installed 1 11 Number of Stacks per Radiator ROOM (102) Dimensions of Room(20x20'68xx13'6")plus(4x7'6"x13'6") Dimensions of Stacks(2'x4'6"x13'6") Windows-- Two North @ 3615" square feet ---- 98.0sq ft. Walls - (20x13.5) plus.25 (20x13.5) - 75.6 --- 210.5" " Volume (20c20.5x13.5) plue (4x7'6"x13.5) - (2x14.5x13.5) -- 6051.5 cuft Heat Loss by Radiation:-(73plus.222(210.5)plus .02(1x6051.5))70 Heat Loss ----- 16283 B.T.U. per Hour. Number of people to be accomodated 3 Number of cubic feet of air to be supplied per person 1800 Number of **U**ubic feet of air to be supplied per hour 5400 For Toilet Number of persons to-be-accomodated with air Number of cubic feet per hour 3 5400 Radiation Surface required for the Two rooms16849x.005--86 1/4 Number of Radiators installed 2 1(11) 1(12) Number of stacks per radiator Heat Loss by Ventilation----- (5400x.3122)--- 1690 B.T.U.

RCOM (103) DIMENSIONS OF Room(12x15'3"x13'6")plus(5'9"x3'6"x13'6") Dimensions of the Stacks None. Windows one North @ 36.5 ----- 36.5 sq; Walls (12x13.5) plus .25(12x13.5) - 36.5---- 166.0 " 36.5 sq;ft. Volume (12x15.25x13.5)plus5.75x3.5x13.5)plus Toilet(4.5x6.5x13.5) 3136 Cubic feet. Heat Loss By Radiation:-(36.5 plus.222(166) plus.02x1x3136)70 Heat Loss----9536 B.T.U. per hour 2 Number of people to be accomodated 1800 Number of cubic feet of air per person Number of cubic feet per hour 3600 Heat Loss by Ventilation (3600x.3122) 1125 Radiator surface required for the rooms 48 3/4 9536x.005 1 -Number of Radiators installed 13 Number of stacks per radiator ROOM(104)DIMENSIONS OF Room:-(10x21x13'6") Dimensions of stack sease (9x2.5x13.5) -----One North @36.5 --36.5 square 🛢 t Windows:-Walls (10x13.5)plus (10x13.5).25-36.5---Volume--(21x10x13.5)-(9x2.5x13.5) ----105.3 * 1 2519.0 Cu.Ft. Heat Loss by Radiation: + (36.5plus.222(105.3) plus.02x1x2519)70 Heat Loss-----7714 B.T.U.per hour. Number of people to be accomodated Number of cubic Feet of air per person 3 1800 5400 Number of cubic feet of air per hour Heat loss by Ventilation (5400x.3122) 1690 Radiator surface required for the room 37 1/2 7714x,005----1 Number of radiators installed 10 Number of stacks per radiator ROOM (105) DIMENSIONS OF Room (40x22'6"x13'6") 135.6 Windows -- Four East @ 33.9----Two North @ 36.5----73.0 Total--208.6 Walls40plus 22.5)13.5plus .4(859.4)-208.6----1034.6 squareft. 12377 ctbic" Volume (22.5x40x13.5)-----Heat Loss by radiation---(208.6 plus .222(1034.6) plus.02x1x12377)70 Heat Loss -----48013B.T.U.per hour. Number of people accomodated-----Number of subic fect of air per person Number of cubic fect of air per hour 15 1800 27000 Radiator surface required for the room 240 square fest 48013x.005 Heat loss by Ventilation (27000c.3122)----8450 4 Number of radiators installed 4(16)Number of stacks per radiator

ROOM(106) DIMENSION Room (22'6"x9'6"x13'6") Windows lEast @ 33.9----- 33.9Sq ft Walls (9.5x13.5) plus(9.5x13.5)x15%-33.9-----113.6 sq ft Volume - (22, 5x9, 5x13, 5) -----2942.0 Cu ft Heat Loss by radiation (33.9plus.222(113.6)plus.02x1x2942).70 Heat Loss -----8267 B.T.W per hour Number of cubic filet of air per person Number of Cubic feet of air per hour Heat Loss by Ventiletion (5400- 5500) 3 1800 5400 Heat Loss by Ventilation (5400x.3122)---- 1690 Radiator surface required for the room 41 1/4 (8267x.005)-----Number of radiators installed 1 -Number of stacks per radiator 11 ROOM (107) DIMENSIONS of the Room (29'x27'3"x13'6") 109.5 sq.ft Windows--Three South @36.5-- -----Three East @33.9 -----101.7 sq.ft. Total-211.2 Soft Walls (29plus 27.25)13.5 plus .20(759)-211.2---690.4 Sq. Ft Volume - (29x27.25x13.5)------10665 Cubic Ft Heat Loss by radiation ---(211.2plus.222(690.4) plus.02x1x10665)70 Heat Loss ----- 40446 B.T.V.per hour Number of people to be accomodated ---Number of cubic feet of air per person Number of cubic feet of air per hour 15 1800 27000 Heat Loss by Ventilation (27000x.3122)---- 8450 B.T.U. Radiator surface required for the room 202 1/2 (40446x,005)------Number of Radiators installed 3 3(18) Number of stacks per radiator ROOM (108) DIMENSIONS of Room (11x22'6"x13'6") Windows One South @ 36.5 ----- 36.5 square fee Walls (11x13.5)plus .05(11x13.5)-36.5 119.4 " " Volume (11x22'6"x 13.5) ----- 2005 cub&c " 36.5 square feet Heat Loss by Radiation (36.5plus.222(119.4) plus .02x1x2005)70 Heat Loss -----7217 B.T.U. per hour. 2 Number of people to be accomodated Number of Cubic feet of air per person . Number of cubic feet of air per hour 1800 3600 Heat Loss by Ventilation _____(3600x.3122)-1125 Radiator surface required for the room 37 1/2 (7217x.005)---p Number of radiators installed Number of stacks per radiator 1 •-10

ROOM1109)

DIMENSIONS of Room (38'6"x26'6"x13'6") Dimensions of Stack (15'x1,5'x13'68) Windows-- Three South @ 36.5 ********* 109.5 sq.ft Walls -- (26.5x13.5) plus .05(26.5x13.5)-109.5*266.0 Ħ 11 Volume --(38,5x26,5x13,5)-(15c1,5x13,5) ******13390Heat Loss by radiation (109.5 plus .222(266) plus .02x1x13390) 70 Heat Loss ******* 30562 B.T.U. loss per hour Number of people to be accomodated 25 Number of cubic feet of air per hour Number of cubic feet per person 45000 1800 Heat Loss by ventilation (45000x .3123) 14050 Radiation surface required for the room (30562x.005) 153 3/4 square feet Number of radiators installed -Number of stacks per radiator 2(13) 1(15)ROOM (110) DIMENSIONS of Room (44x27x13'6") Ceiling exposure (44x 27 x13.5) ********* 1425 Sq.ft. Volume of Room (44 x27 x13.5) ********16050 Cubic Ft. Heat Loss by Radiation (1435 X1 plus16050x3x.02)65 -- 50993 Number of people to be accomodated ----- 20 Number of Cubic feet of air per person 1800 Number of cubic feet of air per hour Heat Loss by Ventilation (36000x.3122) 36000 11250 Radiation Sossace required for the room (50992x .005) -----258 3/4 Number of Radiators to be installed 3(15) 1(24)Number of stacks per radiator ROOM (111) DIMENSIONS of Room (48 x38'6" x13.5) Dimensions of Stack (20x1.5x13.5) Windows Two South @ 36,5 ***** 73 sq.ft. Walls (48z13.5) plus .05(13.5x48) -73 **** 607.4 sq. ft Volume (48x 38.5 x13.5)-(20x1.5x13.5) ****24249 cu ft Heat Loss by Radiation ----(73plus.222(607.4)plus .02xlx 24249)70 Heat Loss -- 48496 B.T.U.per hour Number of people accomodated 150 Number of Cubic feet of air per person 1800 Number of cubic feet of air per hour 270,000 Heat Loss by Ventilation (270,000x.3122) 84500 Radiation surface required for the Room (48496x.005)--243 3/4 square feet Number of Radiators installed 3 -2(22)1(21)Number of stacks per Radiator

8.

ROOM (112) DIMENSIONS of Room (36'6"x17'x13'6") Dimensions of Stack(7'6"x1'6"x13'6") One south @36.5 **36.5 Windows **Twor wosth@ 33.9 square feet ****** 135.6 (38 plus 17)x13.5 plus .25(842.5)-172.1*** Walls 881.0 Volume(36,5x17x13,5)-(7,5x1,5x13,5)----- 8528,7 cubicft Heat Loss by radiation (172.1plus .222(881) plus .02x1x8528.7) 70 Heat Loss ****** 37680 B.T.U. per hour Number of people to be accomodated 5 Number of cubic feet per person 1800 Number of cubic feet per hour 9000 Heat Loss by Ventilation (9000x.3122) 2810 Radiation surface required for the room (37680x.005) ****** 187.5 squaré feet Number of radiators installed 2 2 (25) Number of stacks per radiator ROOM(113) DIMENSIONS of Room (34x27⁶*x13⁶) Dimensions of Stack(5'6"x2'x13'6")2 Windows** Three North @ 36.5 109.5 square ft Three West @ 33.9 101.7 8 Walls(34 plus 29.5)13.5 plus.4(857.2)-211.2** 989.0 11 Volume(34x 27.5x13.5) -2(5.5x2x13.5) 12652 Cubic ft. Volume(34x 51.04200) Heat Loss by Padiation (211.2plus .222(989) plus .02x1x12652)70 Heat Loss ***** Per hour 47866 B.T.U. Number of people to be accomodated 30 Number of Cubic feet of air per person Number of cubic feet of air per hour 1800 54000 Heat Loss by Ventilation (54000x.3122) 16900 Radiation surface required for the room (47866x.005)240 Number of Radiators installed 3 2(21)1(22)Number of stacks per Radiator ROOM(114) DIMENSIONS OF ROOM (12x21'4"x13'6") Dimensions of closets(8x6x13'6") plus(5'6"x5'x13'6") *****One North @ 36.5 36.5square ft Windows walls (12x13.5)plus,25(162)-36.5 166.0 11 Volume (12x13.5x21.3) plus (8x6x13.5) plus (5.5x5x13.5) VOLUME_ ***** 4590 cubic ft. Heat Loss by Radiation (36.5plus .222(166) plus.02x1x4590)70 Heat loss***** per hour 11557 B.T.U. Number of people to be accomodated Number of cubic feet per person 3 1800 Number of cubic feet of air per hour 5400 Heat Loss by Ventilation (5400x.3122) 1690 Radiation surface required forrthe room 11557x.005 + + (60)60 Number of Radiators installed 1 16 Number of stacks per Radiator

RCOM(115) DIMENSIONS of Room(30'3"x20'6"x13'6") Dimensions of Stacks(2x5x13.5)2---(2x4.5x13.5) 109.5 Sa.Ft Windows----Three North @36.5----Walls (30.25x13.5) plus.25(378.4) -109.5 364.0 " Volume (30.25x20.5x13.5) - 2(2x5x13.5) - (2x4.5x13.5)8149 Cu.Ft. VOLUME ****** Heat Loss by Radiation (109.5plus.222(364) plus.02x1x8149)70 Heat Loss per hour 24731 B.T.U. 25 Number of people to be accomodated Number of cubic feet of air per person 1800 Number of cubic feet of air per hour 45000 Heat Loss by Ventilation (45000x.3122) 14050 Radiation surface required for the Room 123 3/4 (24731x.005)Number of Radiators installed 3 3(11) Number of Radiators, sections to a radiator

SECOND FLOOR.

Room aor to beheated to 700 by direct radiation, the Ventilating air to be supplied to the rooms as a separate unite at a Temperature of 87.2°. The Constants for the second floor are:-For Heat Transmission through 14" wall---.272 For Heat Transmission through single glass 1.000 Window Scheduel:-West Side---- 33.8 square feet East Side----33.8 square feet North Side----34.9 square feet South Side----34.9 square feet Centre of main floor South--24.44 Sq.Ft East Side of west wing West Side of East Wing none 34.9 Sq.Ft Allowances for exposure:-5% South North 25% 25% Test 15% East Constants for the Rooms on the Second Floor Height of Windows from the floor--Height of Radiator used 215" 26" Number of Columns per stack--3 Square feet of Heating surface per stack--3,75 Cast Iron PEERLESS installed. Number of Cubic feet of Ventilating air per person ***** per hour 1800

Calculations for the separate rooms taken as follows according to Floor Plans.

Seconds Floor ROCM(201) DIMENSIONS of Room: -10x23x13'6") Dimensions of stack (5x2x13'6") 34.9 Sq. Ft. 134.1 " " Windows One North @34.9 sq.ft. Walls (10x13.5) plus .25(135)-34.9---Volume (10x23x13.4)-5x2x13.5) -----2970.0 Cu. Ft Heat Loss by Padiation (34.9plus.272(134.1) plus .02x1.5x2970)70 Heat Loss ---- per hour 10297 B.T.U. Number of people to be accomodated 4 Number of cubic feet of air per hour Heat Loss by Ventilation (7200x.3123) 7200 2250 Radiation Surface required for the room 52 1/2 10397x.005----- square feet Number of Radiators installed 1 Number of stacks per radiator 14 RCOM(202) DIMENSIONS of Room:-19'6"x23'x13'6") Dimensions of stack(10' 6"x2'x13'6") Windows -----Two North @34.9 square feet 69.8 SQ.FT. Walls (19.5x13.5) plus.25(19.5x13.5)-69.8 259.3 " " Volume (19.3x23x13.5)-10.5x2x13.5) 5772.4 Cu.Ft Heat Loss by Radiation (69.8plus .272(259.3)plus.02x1.5x5772.4)70 21945 B.T.U. Heat Loss per hour Number of people to be accomodated Number of Cubic feet of air per hous 20 36000 Radiation surface required for the Romm 21945x.005----- square feet 108 3/4 Heat Loss by Ventilation (36000x.3122) 11250-Number of Padiators installed Number of Stacks per radiator 2 (14) (15) ROOM(203) DIMENSIONS of Room (23x29g13 6") Dimensions of stack(31'6"x2x13'6") Windows ---- Two North @ 34.9 69.8 Sq.Ft Walls(23x13.5Lplus .25[23x13.5)-69.8 318.9 " " Volume 23x29x13.5)-31.5x2x13,5) 8168.5 Cu. Ft Heat Loss by padiation (69.8plus .272(318.9)plus .02x1.5x81685) 70 Heat Loss---- per hour 28112B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 25 45000 Heat Loss by Ventilation (45000x.3122) 14050 Number of square feet of radiation required for the Room (28112x.005)146 1/4 Number of Radiators instabled 2 (19) (20)Number **CC** of Stacks per radiator

ROOM (204) DIMENSIONS of Room(40'x22'6"x13'6") Windows Four East @33.8 135.2square feet Two North @34.9 49.8 = . Total Glass--205 Walls (22.5xplus 40) 13.5plus .40 (62.5x13.5)-205 976.3 Volume (40x22.5x13.5) 12150 Heat Loss by Radiation (205plus .272(976.3) plts .02x 2x 12150)70 Heat Loss per hour 66962B.T.U. Number of people to be accomodated 25 Number of cubic feet of air per hour 45000 Heat Loss by Ventilation (45000x .3122) 14050 Number of square fest of radiation surface for the Room 333 3/4 $(66962 \times .005)$ Number of radiators installed 4 3(22)1(23)Number of stacks per radiator ROOM(205) DIMENSIONS of Room (26'6"x40'6"x13'6") Dimensions of stacks(16x1.5x.3'6")(9'5"x3'6"x .3'6") Three South @34.9 Windows 104.7 Sq. Ft. Walls Four East 11 @33.8 135.2 11 11 Total Glass 239,9 Volume (26.5x 40.5x13.5)-16x1.5x13.5)-(9.5x3.5x13.5) VOLUME-----13685.4 Cu. Ft Walls (26.5plus 40.5) **pl3**.5plus .2(67x13.5-239.9) Walls-----846.1 Sq.Ft Heat Loss by Padiation (239.9plus .272(846.1)plus .02x2x13685.4)70 Heat Loss per hour 65028B.T.U. Number of people to be accomodated 25 Number of cubic feet of air per hour Heat Loss by Ventilation(45000x.3122) 45000 14050 Radiation surface required for the Room (65028x.005) ---- sqyare feet 326 1/4 Number of Radiators installed 4 Number of stacks per radiator 3(21) 1(24)ROOM(206) DIMENSIONS of Room(11x22'6"x13'6") Windows one south @34.9 34.9square feet Walls(llx13..5)plus ,05x11x13,5)-34.9 121 Volume(11x22.5x13.5)3341.25 cu.Ft. Heat Loss by Radiation (34.9 plus.272(121)plus .02x2x 3341. 25)70 Heat Loss----per hour 14102B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 3 5400 Heat Loss by Ventilation 1690 Radiation surface required for the room (14102x.005)71 1/4 Number of Radiators installed 1 Number of stacks per radiator 19

ROOM(207)DIMENSIONS of Room (26'6"x 38'6"x 13'6") Dimensions of stack(15x1.5x13.5) Windows Four West in East Wing @34.9--139.6 Sq. Ft. 104.7 " Three South @34.9---Walls (26,4plus 38.5)13.5Plus.25(64.9)-244.3--852.8 Ħ Volume (26.5x 38.5x13.5)-(15x1.5x13.5)--13459.5 Cu. Ft Heat Loss by radiation (244.3plus.272(852.8)plus.02x2x13459.8) 70 71309 B.T.U. Heat Loss----per hour Number of paoble to be accomodated 30 Number of Cubic feet per hour of air 54000 Heat Loss by Ventilation(54000x.3122) Radiation surface required for the room 16900 (71309x.005)356 1/4 Number of radiators installed 4 3(23) 1(26)Number of stacks per radiator RCOM(208)DIMENSIONSof Room(34x29x13'6") Dimensions of stack(22'6"xl'6"xl3'6") Windows--Three Notth 104.7 **@**34**.9--**-101,4 Three West **9**33**.8**---Total Glass 206.lsquare feet 1069,7 " Walls (34 plus 29) 13.5 plus.5 (63) 13.5 - 206.1 11 Volume (34x29x13.5)-22.5x1.5x13.5)---12856 Cubic feet Heat Loss by radiation (206.1plus.272x1069.7plus.03x2x 12856)70 70791B.T.U. Heat Loss per hour Number of people to be accomodated 35 Number of cubic feet of air per hour 63000 Heat Loss by Ventilation(63000x.3122) 19700 Radiation Surface required for the room (70791x.005)356 1/4 Number of radiators installed 4 Number of stacks per radiator 3(23) 1(26)RCOM(209) DIMENSIONS of Room (12x29x13'6") Cuter dimensions of closet(6x8x13'6") Inner dimmensions of closet(5x5x13'6") Windows One North @34.9 34.9square feet walls (12x13.5) plus ,25(12x13.5)-34.9 167.6 " " Volume (38x29x13.5)-(6x8x13.5) plus(5x5x13.5) 5562.5 Cubic feet Heat Loss by radiation (34.9plus .272(167.5) plus .02x2x5562.5)79 Heat Loss per hour 21210 B.T.U. Number of people to be accomodated 4 Number of cubic feet of air per hour 7200 Heat Loss by Ventilation (7200x.3122) 2250 Radiator surface required for the room (21210x.005)105 Number of radiators installed 1 . 28 Number of stacks per radiator

: · · :

· · · · · ·

· · · · · 1. • • • • •

•

· · · · · · · · · · ·

. •

RCOM(210) DIMENSIONS of Room(30x23x33.5) Dimensions of stack(15'6"x1'6"x13'6") 104.7 square feet Windows ---- Three North @ 34.9 Walls30x13.5plus .25(405) p-104.7 Volume(30x23x13.5) -(15.5x1.5x13.5) 401.5 9002.9 cubie feet Heat loss by radiation (104.7plus .272(401.5 plus.02x2x9002)70 Heat Loss per hour 40180 B.T.U. Number of people to be accomodated 30 Number of cubic feet of air per hour 54000 Heat Loss by Ventilation (54000x.3122) 16900 Radiator surface required for the room 202 1/2 (40180x.005)Number of radiators installed 3-3(18) Number of stacks per radiator ROOM(211) DIMENSIONS of Room(66'x38'6"x13'6") Dimensions od stack(30'6"xl'6"xl3'6") Windows Four West @33.8 135.2 seven South @34.9 244.3 Total Glass 379.5 Square feet Walls (66plus2 (38.5)) 13.5plus .25 (66plus2 (38.5) 13.5) -379.5 Total Wall exposed Volume(66x38.5x13.5)-(30,5x1.5x13.5) 2043.6 SQ.FT. 33685.2 Cubic feet Heat Loss by radiation (379.5plus .272(2043.6) plus.02x2x33685.2)60 Heat Loss per hour 136956 B.T.U. Number of people to be aucomodated 250 Number of cubic feet of air per hour 450,000 Radiation Surface required for the room allowing 50000B.T.U per hour frok the occupants of the room (136956-50000) .005 412 1/2 Heat Loss by Ventilation(450000x.3122)14050Q0 B.Y.U. Number of radiators installed 5 5(22) Number of stacks per radiator THIRD FLOOR . Rooms to be heated to 70° by direct radiation, the ventilation loses to be supplied to the rooms as a separate unite at a temperature of 87.2°. The constants for the Third floor are :-For Heat Transmission through 16" wall-_26 For Heat Transmission through 14" wall .27 For Heat Transmission through single Glass 1.00 Window schaduel:-Wast side 30.25 square feet East Side 30.25 square feet North Side South side 32.53 square feet 32.53 square feet West windows East Wing 32.53 square feet East windows West Wing 32.53 square feet South windows center 22.77 square feet

• • • · · · · . . .

·

- - • - • •

.

.. •

•

• • • •

THIRD FLOOB CONTINUED:-

Allowances for exposures:-25% North South .05% 15% East 25% Weat 215" Height of Windows from the floor Height of radiators installed 26" Number of columns per stack 3 Square feet of radiation surface per stack 3.75 Number of cubic feet of air per person per hour 1800 Cast Iron Radiators PEERLESS installed. ROOM (301) DIMENSIONS of Room (30x23x13'6") Dimensions of stack(20x2x13'6") Dimensions of closet(5x6x13.5) Windows Three North @32.53 Walls (30x13.5) plus .25(30x13.5)-97.59 97.59 square feet 1 408.7 Volume (30x23x13.5)-(20x2x13.5) plus(5x6x13.5)--8370 Cubic feet Heat Loss by Radiation (97.59plus.26(408.7) plus .02x1.5x8370) 70 Heat Loss per hour 31847 B.T.U. Number of people to be accomodated Number of cubic feet of air per hour **25** 45000 Heat Loss by ventilation (45000x.3122) 14050 Number of radiators installed 3 Radiation surface required for the room (31847x.005)161 1/4 2(14) 1(15)Number of stacks per radiator ROOM(302)DIMENSIONS OF Room (23x29x13.5) Dimensions of stack (31'6"x2'x13.5) Windows Two North @ 32.53 Walls (23x13.5) plus .25(23x13.5) -65.06 Volume (23x29x13,5mphus (31.5x2x13,5) 65.06 Sq Ft. 323**.0**0 8154 Cubic feet Heat Loss by radiation (65.06plus .26(323)plus .02x1.5x8154)70 27556 B.T.U. Heat Loss per hour Number of people to be accomodated Number of cubic feet of air per hour 25 45000 Heat Loss by Ventilation(45000x.3122) 14050 Radiation surface required for the room (27556x.005) 138 3/4 Number of radiators installed 2 Number of stacks per radiator 18 19 $R \cap OM(303)$ DIMENSIONS OF Room(40x22'6"x13'6") 121,00 Two North @32**.**53 65,06

 Windows Four East
 030.25
 121.00

 Two North
 032.53
 65.06

 Total Glass
 186.06 Square feet

 Walls
 (40 plus 22.5)
 13.5 plus .40 (62.5x15.5)-186.06

 Walls
 995.20 Square feet

 Volume
 (40x22.5x13.5)
 12150 Cubic feet

 Heat Loss by radiation
 .02x1.5x12150)70---57351B.T.U.

ROCM(303) continued Number of people to be accomodated Number of Cubic feet of air per hour 30 54000 Heat Loss by Ventilation (54000x.3122)--16900 Nadiation surface required for the room (57351x.005)285 Number of radiators installed 4 Number of stacks per radiator 4(19)ROOM (304) DIMENSIONS of Room (26'6"x40'6"x13'6") Dimensions of stack[2x16x13'6") Windows Three South @ 32.53 97.59 Four East @ 30,25 Total Glass 121.00 218.59 Square feet Walls (26.5plus 40.5) 13.5plus .20(67)13.5-218.59 866,8 Walls Volume(26.5x 40,5x13.5) -(2x16x13.5) 14056 Cubic feet Heat Loss by radiation (218.59plus .27(863.8) plus.02x2x14056.)70 Heat Loss per hour 71044B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 30 5400**0** Heat Loss by Ventilation (54000x.5122) 16900 Radiation surface required for the room (71044x.005)356 1/4 Number of radiators installed 4 3(23) 1(26) Number of stacks per radiator ROOM(305) DIMENSIONS OF ROOM(11x23x13.5) Windows One South @ 32.53 32.53 Square feet Walls(11x13.5)plus_05(11x13.5)-32.53 123.39 11 Volume (11x23x13.5)3415.5 Cubic feet Heat Loss by radiation (32.53plus .27(1234) plus .02x1.5x3415.5)70 Heat Loss---- per hour Number of people to be accomodated Number of cubic feet of air per hour 11782B.T.U. 4 7200 Heat Loss by Ventilation(7200x.3122) 2250 Number of radiators installed Number of stacks per radiator 1 16 Radiation surface required for the room 60 (11782x.005)ROOM(306) DIMENSIONS OF Room (26'6"x38'6"x13'6") Dimensions of stauk(15'x1.5x13'6") Windows Three South @32.53 97.59 Four West @32.53 13**9.1**2 Total Glass 227.71 Square feet Walls (26.5 plus 38.5) 13.5 plus .25(65) 13.5 - 227.71 Walls 869.8 square feet Volume(26.5x38.5x13.5)-(15x1.5x13.5) 13470 cubic feet Heat Loss by radiation (227.7plus.27(869.8) plus.02x1.5x13470)70 Heat Loss----- per hour 60662 B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 30 54000

. •

· · · · · ·

•

•

. • • •

• ·

••••••••• • · · · · · ·

ROOM(306) continued:-Heat Loss by Ventilation (54000x.3122) 16900 B.T.U. Number of radiatovs installed 4 Radiation surface required for the room (60663x, 005)303 3/4 3(20) - 1(21)Number of stacks per radiator ROOM(307) DIMENSIONS OF Room(19x9'6"cl3.5) Windows One East of west wing @ 32.53 32,53 Square fed Walls 9.5x13.5) plus .15(9.5x13.5) -32/53 11 102.3 Volume (19x985x13.5) 2437 cubic FT. Heat Loss by radiation (32.53 plus .27(102.13) plus .02x1.5x2437)70 Heat Loss per hour 9327 Number of people to be accomodated Number of cubic feet of air per hour Heat Loss by Ventilation (7200x.3122) 4 7200 2250 Number of Radiators installed 1 Number of stacks per radiator 13 Radiation surface required for the room 48 3/4 (9327x.005)RCOM**3508)** DIMENSIONS of Room (28x28x13.5) 97,59 Windows Three south @ 32.53 West winghree East @32,53 97,59 Tolal Glass 195.18 Square fet Wall (28 plus 28) 13.5 plus.2(56)13.5-195.18--713.00 10594 cubic feet Volume(28x28x13.5) Heat Loss by radiation (195.18 plus .27 (712) plus .02x1.5x10584)70 Reat Loss per hour 49346B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 15 27000 Heat Loss by Ventilation (27000x.3122) 8450 Number of radiat ors installed 3 Radiation surface required for the room 247 1/2 49346x.005 3(22)-Number of stacks per radiator ROOM(309)DIMENSIONS of Room(36'6"x38'6" x13!6") Dimensions of stack(21'6" x186"x13'6") Windows Four West @ 30,25 121.00 Four South @ 32.53 130.12 251.12 Square Ft. Total Glass Walls (36.5 plus 38.5) 13.5plus .3(75) 13.5-251.12 . 11 11 Walls 1065 Volume(36.5x 38.5x13.5) -(21.5x1.5x13.5) 18536 cu.ft. Heat Loss by radiation (251.12plus .26(712) plus .02x1.5x10584)70 Heat Loss per hour 75922 B.T.U. Number of people to be accomodated 20 Number of cubic feet per hour 36000 Heat Loss by Ventilation (36000x.3122) 11250 Number of radiators installed 4 Radiation surface required 412 1/2 75922x.005 Number of satacks per radiator 3(27) - 1(29)
• · · · • •

· · · •

• • • • •

•

RCCM(310) DIMENSIONS of Room (22'6"x10'x13'6") Windows One West @30,25 30.25 square feet 138.5 Walls(10x13.5) plus .25(135) -30.25 Volume (22.5x10x13.5) 3038.00 cubic feet Heat Loss by radiation (30.25plus .27(138.5) plus .02x1.5x3038)70 Heat Loss per hour 11116 B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 4 7200 Heat Loss by Ventilation(7200x.3122) 2250 Radiation surface required for the room (11116x.005)56***** 56 1/4 Number of radiators installed 1 Number of stacks per radiator 15 ROOM (311) DIMENSIONS of room(47x29x13'6") Dimensions of stack(29'6" x1'6" x13'6") Four North 130.12 Windows 6 32.53 90.75 Three West 6 30.25 220.87 Square Ft. Total Glass Walls(47plus 29)x13.5plus.40x76(13.5)-220.87**1215.6 Volume (47x29g13.5)-(29,5x1.5x13.5) 17803.0 Ħ . 17803.0 Cubic Ft. Heat Loss by radiation (220.9 plus .27(1215.6) plus.02x2x17803)20** Heat Loss per hour Number of people to be accomodated 98214 B.T.U. 30 Number of cubic feet of air per hour Heat Loss by Ventilation (54000x.3122) 54000 16900 Radiation surface required for the room (98214x,005) **** 477 1/2 Number of radiators installed Number of stacks per radiator 5 5(26) ROOM #312) DIMENSIONS of Room(12x23x13'6") Dimensions of stack(7x1.5x13'6") Windows One North @ 32,53 32.53 square Ft. Walls (12x13.5) plus .25 (12x13.5) -32.53--Volume (12x83x13.5)-(7x1.5x13.5)----170 3588 cubic feet Heat Loss by radiation (32.53 plus.26(170)plus .02x1.5x3588) 70 Heat Loss per hour 13649 B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 5 9000 Heat Loss by Ventilation (9000x.3122) 2810 Radiation surface required for the room (13649x.005)67 1/2 Number of radiators installed 1 Number of stacks per radiator 15

. .

· · .

. . . .

ROCM (313) DIMENSIONS of the Room(17'6"x23x13'6" DIMENSIONS of stack (4'6" x8'6" x1 (4'6" x8'6" x13'6") Windows Two North @32.53 65.66 square Ft. Walls(17.5x13.5)plus 17.5x13.5)x.25- 65.66** 236.25 Ħ Volume(17.5x23x13.5)plus(4.5x8.5x13.5) 4917.4 cubic Ft. Heat Loss by radiation (65.06plus.26(230.25)plus .02x1.5x4917.4)70 Heat Loss per hour 19071B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 8 14400 Heat Loss by Ventilation [14400x]3122) 4500 Radiation surface required for the room (19071 x.005) *****93 3/4 Number of radiators installed 2 ***** Number of stacks perradiator 13 --- 12 FOURTH FLOOR. Room air to be heated to 70 degrees by direct radiation, the Ventilationair to be supplied as a separate unite to the rooms at a temperature of 87.2 degrees. The constants for the fourth floor are:-Heat transmission through 12" wall .313 Heat transmission Heat transmission through single gaass 1.00 through joist with Number of columns per stack 2 single floor-.10 Window scheduel:-West side 12.3 square feet 12.3 square feet 13.22 square fee East Side North side South side 13.22 square feet South side East side west wing West side East Wing South eide center South eide center South eide center South side 13.22 square feet Allowances for exposure:-South 5% 25% North East 15% 25% West 3110" Height of windows from the floor---Height of radiators installed 32" Number of columns per stack 2 81 Width of radiator Thickness of stack 2 1/2 " Number of cubic feet of air per person per hour-1800 3 1/3 Square feet of heating surface per stack Cast Iron Radiators PEERLESS installed. **ROOM(401)** DIMENSIONS OF Room (30x23x11) Dimensions of stack(20x2x11) Windows Three North @ 13.32 13.22 square feet 27.00 11 Skylights Nine North@ 3 8 27.00 Ħ 11 Nine south @ 3 11 11 Total Glass 93.66 11 11 Walls(30x11)1.35 -93.66 351.84 . 11 11 Ceiling (30x23)1.2 828.00 Volume(30x23x11) - (20x2x11)7150.00 Cubic feet Heat Loss by radiation (93.66plus .313(351.8)plus.10(828) plus .02x2x7150) 70 40080 B.T.U. Heat Loss per hour

ROOM(404)Room (404) was calculated with the heat loss of the Fourth Floor Corridor so is not considered in the calculations. ROOM (405) DIMENSIONS OF Room (26'6"x40'6"x11') Dimensions of stack(16x1'6"x11)

 ¹/₆"x11)

 ¹/₆"x11)

 ³9.66 Sq. Ft.

 ⁰ 13.3

 ³9.66 Sq. Ft.

 ³9.66 Sq. Ft.

 ⁰ 13.3

 ⁴9.20

 ⁿ

 ⁰ 3

 ⁵4.00

 ⁿ

 ⁰ 3

 ⁵4.00

 ⁿ

 ¹ Total Glass

 ¹96.86

 ⁿ

 Windows Three South @ 13.22 Four East @ 12.3 Skylights 18 South @ 3 18 North @ 3 Walls (26.5plus40.5)11plus (26.5plus40.5)11x.2-196.86--

 Walls - 687.6
 "

 Ceiling(26.5x40.5)1.2--- 128799
 "

 Volume(26.5x40.5x11)-(16x1.5x11)
 11541.75
 Cubic feet

 Heat Loss by radiation (196.86plus.313(687.6) plus128739x.10 plus .02x2x11541,75)70 Number of cubic feet of air per hour Heat Loss by Ventilation (File) Heat Loss per hour 70179 B.T.U. 30 54000 Heat Loss by Ventilation (54000x.3122) Radiation surface required for the room 16900 (70179x.005)366 2/3 Number of radiators installed 4 3(27) 1(29) Number of stacks per radiator ROOM(406)DIMENSIONS OF Room(11x22x10) 13.22 Sq Ft. 102.28" " Windows One South @13.22 Walls (11x10)1.05 -13,22 Cealing (22x11)1.2-----290.4 " " 2420.0Cu.Ft. Volume (11x22x10)Heat Loss by radiation (13.22plus .313(102.28)plus .10(290.4) plus .02x1.5x2420)70 Number of people to be accomodated Number Of cubic feet of air per hour Heat Loss by Ventilation(7200x.3132) Radiation surface required for room (10282x.005) Heat Loss per hour 102816 B.T.U. 4 7200 2250 53 1**/3** 1 -Number of Radiators installed 16 Number of stacks per radiator ROOM(407) DIMENSIONS of Room(27x39x11) Stack(15x1.5x11)

 DIMENSIONS of Room(27x39x11)
 Stack(15x1.5x11)

 Windows Three South
 ©13.22
 39.66 square feet

 Test wing Four West
 ©13.22
 52.98
 "
 "

 Skylighted
 15North
 ©
 3
 45.00
 "
 "

 IsSouth
 ©
 3
 45.00
 "
 "
 "

 Walls(27plus39)11
 Pimesl.3 -181.54
 763.2
 "
 "
 "

 Volume(27x39x11)-15x1.5x11)---- 1263.6
 "
 "
 "

 Heat Loss by Radiation (181.54 plus .313 (762.2) plus .10 (1263.6) plus .02x2x11336) 70 Heat Loss--per hour69923B.T.U.Number of people to be accomodated30Number of cubic feet of air per hour54000Heat Loss by Ventilation(54000x.3122)16900

•

! { ! { - · · · •

· · · · · · · ·

· · · · · · · ·

FOCM(407) continued:-Radiation surface required for the room (69923x.005) 366 2/3 Number of radiators installed 4 Number of stacks per radiator 3(27) 1(29)ROOM(408)DIMFNSIONS of Rocm \$128 6"x9'6"x10) Windows One East side West wing @13.22 13.22 Square feet 13.55 ~~~ 100.80 " 142.50 " Wall(9.5x10)1.2 -13.22---11

 Ceiling (12.5x9.5)x1.2 -- 142.50 " "

 Volume (12.5x9.5x10)
 -- 1187.50 " "

 Heat Loss by radiation
 1187.50 " "

 (13.22plus .313(100.8) plus .10(142.5) plus .03x2x1187.5) 70

 Ħ Heat Loss per hour 7456 Number of people to be adcomodated Number of cubic feet of air per hour Heat loss by Ventilation (7200x.3122) - 4 7200 2250 Number of Radiators installed in the room 1 Radiation surface required for the room (7456x, 005)36 2/3 Square ft 11 -Number of stacks per radiator ROOM(409) DIMENSIONS of Room (19x28x10) **25.44** <u>39,66</u> 66.10 square ft. Windows Two South @ 13.22 East of West Wing Three@ 13.22 Total Glass Total Glass Walls (19plus28) 16 x1.25 -66.1 ----Ceiling (19x28) 1.2 ****** Volume (19x28x10) ---521.40 " 638.40 " 11 Ħ 5320.00 Cubic Ft Heat Loss by radiation (66.1plus .313(521.4) plus .10(638.4) plus .02c2x5320) 70 Heat Loss per hour 35413 P.T.U. Number of people to be accomodated 15 Number of cubic feet of air required per hour 27000 Heat Loss by Ventilation (27000x.3122) 8450 Radiation surface required for thr room (35413×0.005) 180 Sq.Ft. Number of radiators installed 2 Number of stacks per Radiator 2(27) ROOM(**&LO**) DIMENSIONS of Room-(46x38'6"x11) Dimensions of stack(21'6"x1'6" x11) Windows--Four West @ 12.3 Five South @ 13.22 Skylights 30 North @ 3.00 30 South @ 3.00 49.2 square ft. 11 66.1 11 90.0 " 90.0 " 295.3 " 11 Ħ Total Glass 11 Walls(46 plus 38'6")11x1.3-295.3 ----Ceiling(46x38.5x1.2 -----Π 913.3 11 n 2125.2 11 Volume (46x38.5x11) - (21.5x1.5x11) 19126.2 Cubic Ft. Heat Loss by Radiation (295.3plus .313(913.1) plus .10(2125.2) plus .02x2x19126.2) 70 Heat Loss per hour 109102.7B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 60 108000 Heat Loss by Ventilation(108000x.3122) 33800

ROCM(410) continued:-Square feet of radiation surface required 533 1/3 (109103x.005)Number of Radiators installed 6 Number of stacks per radiator 5(26) 1(30).ROOM(411) DIMENSIONS of Room(23x10x10) Windows Cne west @12.3 12.3 Square Ft. Walls (10x10)1,25 -12.3-----102.7 " " 11 Ceiling (23x10)1.2 -----Volume (23x10x10) 11 276.0 2300.0 Cubic Ft. Heat Loss by radiation (12.3plus.313(102.9)plus276x.10plus .62x1.5x2300) 70 Heat Loss per hour 9877 B.T.U. Number of people to be aucomodated 4 Number of cubic feet of air per hour 7200 Heat Loss by Ventilation (7200x.3122) 2250 Radiation surface required for the room 50 (9877x,005)Number of Radiators instabled 1 15 Number of stacks per radiator ROOM(412) DIMENSIONS OFRoom(47x29x11) Dimensions of Stacks (29'6" x1'6" x11) Windows Four @13.22 42.88 square Ft. 36**.9 "** Three West@ 12.3 11 69.0 " <u>69.0</u> " Skylights 23 North @ 3 23 South @ 3 Total Glass 11 6**9.0** 11 217.78 " 11 Walls(11(47plus 29)1.4 -79.78 1090.6 " 11 Ceiling (47x29)1.2 -138 11 11 1497.6 Volume(47x29x11) -(29.5x1.5x11) 14506.2 Cubic ft. Heat Loss by Radiation (217.78plus .313(1090.6) plus .10(1497.6) plus.02x2x14506.2)70 Heat Lossper hour 90240 B.T.U. Number of people to be accomodated Number of cubic feet of air per hour 40 72000 Heat Loss by ventilation (72000x.3122) 22500 Radiation surface required for the room (90240×0.005) 466 2/3 Number of radiators installed 5 5(28) Number of stacks per radiator? ROOM(413) DIMFNSIONS of Room(23x12x10) Stack (7x1.5x10) WindowsOne North @ 13.22 13.22 Square Ft. 142.8 " " Walls(12x10)1,3 013.22 n 11 Ceiling(23x12)1.2 331.2 Volume (23x12x10)-7x1.5x10) 2655.0 Cubic feet Heat Loss by Radiation (13.22plus .313(142.8)plus.10(331.2) plus .02x2.5 x2655)70 Heat loss per hour 11948 B.T.U. Number of people to be accomodated Number of cubic feet **of** air per hour 3 5400 Heat Loss by Ventilation (5400x.3122) 1690 Radiation Surface required for the rocm(11948x.005)-63 1/3 Number of radiators installed Number of stacks per radiator 19

ROOM(414)		
Dimensions of Rocm(17'6"x23'x10'6") Stac	k(12'x2'x10'6")	
Windows Two North @ 13.22	26.44 Square F	t,
Walls (17.5x10.5)1.35-26.44	157.31 "	Ħ
Ceiling (17.5x23)1.2	483.00 ^m	Ħ
Volume(130x23x10)51-(12x2x10.5)	3974.25 "	11
Heat Loss by radiation		
(36.44 plus.313(157.31) plus.10(483) plus	.02x2x3974.3)70	
Heat Loss per hour	19779 B.T.U.	
Number of people to be accomodated?	15	
Number of cubic feet of air per hour	27000	
Heat Loss by wentilation (27000x.3122)	8 4 5 9	
Radiation Surface required for the room		
(19779x.005)	100 square fee	t
Number of radiators installed	2	-
Number of stacks per Radiator	15	

CORRIDCRS .

BASEMENT:-Dimensions to obtain the exposed areas and the Total volume of the Corridor. (9'x37'x13'6") plus(3x5x13.5) plus(140x10x13.5) plus(10x20'6 x13'6")plusl'x7'6"x13'6") plus(11'x14'x13'6") Staircase: - (22x21x13'6") - (22x5'3"x5') - (9x10x9'6") Total Volume of Corridor:-33361.8 Gu.Ft. Glass :-Main entrance 2(24"x78")--26 sq.ft. East Entrance2(16"x62")---13.78 sq. ft. West Entrance2(16"x62")---13.78 sq.ft. Transoms East and West338"x24"0 6134 sq.ft. 66,24 " Total Glass:-Walls (9g13.5)2 plus (22x8)-66.24-----271.20 " Heat Loss by radiation:-(66.24plus.222(271.2)plus .02x1x33361.8)70---55558 B.T.U. Heat Loss per hour--First Floor:-Dimensions to obtain the exposed areas and the Total Volume of the Corridor. (11x6x13.5)plus(28x14x13.5)plus(140x10x13.5) Stack (10'6''x2'x13'6'')Total Volume ----24800 Cu. Ft. Windows One West @33.9 TotalGlass---33.9 Sq.Ft. 128.2 " Walls((10x13.5)plus2(10x13.5)-33.9------Heat Loss by Radiation:-(33.9plus.222(128.2)plus.02x1x24800)70-- 40088 B.T.U. Staircase: - (21x7x6'9") plus(15X21x6'9") Windows One North @36.5 Square Feet 36.5 Square feet Walls (21x13.5) plus. 25(21x13.5)-36.5 -----317.9 " Volume (**21x7x6'3**")plus(15x21x6.75)---3118.5 Cubic Feet Heat Loss by radiation:-(36.5plus .222(318)plus .02x1x3118.5)70-- 11865 B.T.T. Total Heat Loss in B.T.U. per hour for the floor 51953 B.T.U.

· · · , , , , , ,

· .

• . **.** .

. · , · ,

· · · ·

. . . ---• • •

COERIDORS:-SECOND FLOOR:-Dimensions to obtain the exposed areas and the volume of the Corridor:-(llx15x13.5)plus(8'6"x2x13.5) plus(152'6"x10x13.5) Di, mensions of staircasa:-(21x4x13.5)plus 21x7'6"x6'3") plus(21x12x6'3") Tindews Six South @ 34.9 One West @ 33.8 Two North @ 34.9 209.4 53.8 39.8 Total Glass 313.0 S quare fest Talls:-(10x13.5)plus(135).25 pluso4x13.5) plus(10x13.5) rlus 10x13.5).25 lus (34x13.5).05 plus (34x13.5) lus (D1x10.5)1.25-313--------- 791.9 Volume:-(11x15x13.5)plus(8.5x2x13.3)plus152.5x10x13.3) plus (21x4x13.5)plus(21x7.5x0.25)plus(21x12x6.25) Total Volume-----26248 Cu.Ft Heat Los: by radiation ---(313plus791. Sx. 272plus. 02x1. 5x26248)70-----Heat Los per hour 92124B.T.U. THIRD FLOOR:-Dimensiond to obtain the exposed area and the volume of the cooridor :-(8x12x13,5)plus(11x13x13.5)plus(3.5x7.5x13.5)plus(1.3,5 x10x1".5) South exposure:-(34x13.5) Timensions of theStairpase:-(21x4x10.5)plus(01x7.5x6'3")plus(21x10x6'0") Win 'ows:-Six south @02.77 Two Verth @02.53 106.63 55.03 201.69 square Ft Total Glass Walls(34x13.5) **plus**(34x1.5).05 plus(21x10.5) plus(21x13.5).25 minus 201.69 6347 souare ft Volume(21273.1plus2692.4) 24966.5 Cu.Ft. Neat Los by radiation:-(201.69plus.263(6 4.7)plus.02x1.5x24008.5)70 Heat Loss per hour 78341 D.T.U. FOWRTH FLCOR:-Dimensions to obtain the exposed area and the volume of the Corridor :-((17x11x10)plus 2.5x7.5x10)plus(123.5x10x10)plus(6x12x10) Plus(Exposure south --- (34x1 0) Dimensions of the Statre se:-(21x24x10)Windows: - Six south @9.44 56.64 26.44 83.085 quare ft. Two North 212.33 Total Glass 546.9 Walls:-34x10)1.05; lus21x10)x1.3-85.08 - 11 11 Volume: - (17x11x10)plus2.5x7.5x10)plus(128.5x10x10)plus (6x1^x10)plus(21x^4x10) 18508 Cubic Et. Ceiling ((17x11)plus2.5x7.5)plus 128.5x10)plus3x12))times1.2 plus (51x24x1.2)----- 2479.8 Square Ft Heat Loos by Radiation:-(87.08plus.313(546.9)plus.10(2479.8)plus.02x2x10508)70 Heat Loss per hour 86979B.T.U.

· · · ·

• · · ·

• • • • • •

Complet for the with th Tabulat	te tabulatio individual ne size of R tions made b	n for the squ rooms for th adiators inst y Floors.	are fee le R.E.O alled .	t of Ra ld s En g	diatic gineeri	on required Ing Hall
Height Height Number Width o Thickne	of windows of radiator of columes of Radiators ess of secti	from the floo s used per stack ons		3110 33 8 8 10 8 10 10		
Square ROOM**P NO.	feet per se ADIATION**S LOSS R	ction QUARE FEET**N AD.SURFACE F	UMBEROF ADIATOR	3 1/3 ** SIZE S NUM	E OF RA	ADIATORS LENGTH OF
1 2 3 4 5 6 7 8 9 10 11 12 13 14	14357 9280 20544 40033 35112 9170 29848 ****** 3076 24976 57653 43960 10976 16618	73 1/3 46 2/3 103 1/3 203 1/3 176 2/3 46 2/3 150 - **** 16 2/3 126 2/3 276 2/3 230 - 56 2/3 83 1/3	& l & 3 & l & * l & 4 3 l &	ST (11) (14) (15) 2 (20) (26) (14) (23) (14) (23) (14) (23) (23) (14) (23) (23) (13) (22) (17) (13)	(11) (16) (31) (23) (23) (23) (19) (12)	RADIATORS $(27\frac{1}{2})(27\frac{1}{2})$ (35) $(37\frac{1}{2})(40)$ $2(50)(52\frac{1}{2})$ $(65)(67\frac{1}{2})$ (35) $(57\frac{1}{2})(55)$ ******** $(12\frac{1}{2})$ $(47\frac{1}{2})(47\frac{1}{2})$ $3(50)(57\frac{1}{2})$ (35) $(42\frac{1}{2})$ $(42\frac{1}{2})$ $(32\frac{1}{2})(30^{1})$
15 TOTAL P NUMBER	7334 RADIATION SU OF RADIATOR	36 2/3 RFACE****** S ******	1 1616 2 27	(11) /3 sque	are fee	(27 2)
Height Height Number Width of Thicknes Square ROOM**F NO.	of windows of radiator of columes of Radiators ess of secti feet per st ADIATION**S LOSS R	FIRST FLOOP from the floo s used per stack on ack QUARE FEET**N AD.SURFACE R	UMBER O	2'6" 6" 3 9 ¹ 3.75 F**SIZE S NUMBE S TAC	E OF RA ER OF EKS	ADIATORS LENGTH OF RADIATORS.
101 102 103 104 105 106 107 108 109 110 111 112	8008 16849 9536 7714 48013 8267 40446 7217 30562 50992 48496 37680	$\begin{array}{r} 41 \ 1/4 \\ 86 \ 1/4 \\ 48 \ 3/4 \\ 37\frac{1}{2} \\ 240 \\ 41 \ 1/4 \\ 202 \ 1/2 \\ 37 \ 1/2 \\ 153 \ 3/4 \\ 258 \ 3/4 \\ 243 \ 3/4 \\ 187 \ 1/2 \end{array}$	181141313438	$(11) \\ (11) \\ (13) \\ (10) \\ 4 (16) \\ (11) \\ 3 (18) \\ (10) \\ 2 (13) \\ 3 (15) \\ 2 (22) \\ 2 (25) \\ (25) \\ (11) \\ (12) \\ (1$	(12) 1(15) 1(24) 1(21)	$ \begin{array}{c} (27\frac{1}{2}) \\ (27\frac{1}{2}) \\ (32\frac{1}{2}) \\ (32\frac{1}{2}) \\ (35) \\ 4(40) \\ (27\frac{1}{2}) \\ (45) \\ (25) \\ 3(32 1/2) 1(37\frac{1}{2}) \\ 3(37\frac{1}{2}) - 1(60) \\ 2(55) 1(52\frac{1}{2}) \\ 2(67\frac{1}{2}) \end{array} $
113 114 115	47866 11557 24731	240 - 60 123 3/4	3 1 3	2(21) (16) 3(11)	1(22)	2(52) 2(52) (40) 3(27)

- . . •

•

· · · · · ·

.

.

•

•

1 __ u

•

. เกิ

Tabulation of square feet of radiation required for the rooms with the sizes of radiators and heat losses.

_

		SECOND	FT.OOP		
Und ahd	t of mind	are from the	floor	2158	
neagu		OWB IFOM THE	11001	2·2·	
Heigh	t of radi	ators used		20"	
Number	r of colu	m es p er stack		3	
Width	of Radia	tors		9 <u>1</u> "	
Thickr	ness of s	ections			
Square	e feet pe	r stack		3.75	
R00W##	*RANTATTO	N**SONARE FFF	T**NIMBEROF	T**STZE OF	RADIATORS
NO	TOOO	N - DOUNILS FAL			E I ENCEUCE
NO	T022	RAD . SURFAG	E RADIATOR		F LENGINOF
-			_	STACKS	RADIATORS
291	10297	52 1/2	1	(14)	(35)
202	21945	108 3/4	2	(14) (15)	(35) (37 5)
203	28112	146 1/4	2	(19) (20)	(47 5)(50)
204	66963	333 3/4	4	3(22)1(23)	3(55)1(57+)
205	65028	326 1/4	Ā	3 (21) 1 (23)	3(52+)1(52+)
206	14102		1		
000	14100		Ť,		
SU 7	71309	330 174	4	3 (23/1 (26)	3 3 3 2 1 65
208	70791	356 1/4	4	3(23)1(26)	3(57 2)1(65)
209	21210	105 -	1	(28)	(70)
210	40180	203 1/2	3	3(18)	3(45)
211	86956	412 1/2	5	5(22)	5 (55)
			•	- (/	- (,
		Thind T			
Uniahi	<i></i>	IIIIQ F			
neign		ows from the	1100I	5'D"	
Height	t of radi	ators used		26"	
Maama la a					
Numbel	r of colu	mes per stack	3	5	
Width	of Radia	mes per stack tors			
Width Thickr	of Radia ness of r	mes per stack tors adiators sect	3 9 ions	5) 1 n 2 1 n	
Width Thickn Square	of Radia of Radia ness of r	mes per stack tors adiators sect r stack	3 9 ions	5 2 2 2 2 2 1 3 2 7 5	
Width Thick Square BOOM*	of Radia of Radia ness of r s feet pe *RADIATIO	mes per stack tors adiators sect r stack N**SQUARE FEF	3 9 10ns T**NUMBER (5 2 2 2 2 3 7 5 5 5 5 5 5 5 5	RADIATORS.
Width Thickn Square ROOM*	of Radia of Radia ness of r e feet pe *RADIATIO	mes per stack tors adiators sect r stack N**SQUARE FEE FAD SUBFAC	3 9 10ns9 T**NUMBER (F BADIATOR	5 2 3 3 7 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS.
Width Thickn Square ROOM*' NO.	of Radia ness of r s feet pe *RADIATIO LOSS	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC	ions T**NUMBER C E RADIATOF	3.75 SF**SIZE OF S NUMBER	RADIATORS. OF LENGTH OF BADIATORS
Width Thickn Square ROOM** NO.	of Radia ness of r e feet pe *RADIATIO LOSS	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC	ions T**NUMBER C E RADIATOF	3.75 STACKS	RADIATORS. OF LENGTH OF RADIATORS
Width Thickn Square NO.	of Radia ness of r s feet pe *RADIATIO LOSS 31847	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4	3 9 ions T**NUMBER C E RADIATOF 3	3.75 3.75 F**SIZE OF S NUMBER STACKS 2(14)1(15	RADIATORS. OF LENGTH OF RADIATORS 2 (35)1 (37)
Width Thickn Square NO. \$91 302	of Radia ness of r s feet pe *RADIATIO LOSS 31847 27556	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4	3 9 ions T**NUMBER C E RADIATOF 3 2	3.75 3.75 SF**SIZE OF S NUMBER STACKS 2(14)1(15 (18) (19	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$
Width Thickn Square ROOM*: NO. \$91 302 303	r of Colu of Radia ness of r s feet pe *RADIATIO LOSS 31847 27556 57351	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 -	3 9 ions T**NUMBER C E RADIATOF 3 2 4	3.75 3.75 DF**SIZE OF S NUMBER STACKS 2(14)1(15 (18) (19 4(19)	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$
Width Thickr Square ROOM*' NO. \$91 302 303 304	r of Colu of Radia ness of r s feet pe *RADIATIO LOSS 31847 27556 57351 71044	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4	3 9 ions T**NUMBER C E RADIATOF 3 2 4 4	5 2 3.75 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$
Width Thickr Square ROOM*' NO. \$91 302 303 304 305	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 -	3 9 ions9 T**NUMBER C E RADIATOF 3 2 4 4 4 1	5 2 3.75 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)
Width Thickr Square ROOM* NO. \$91 302 303 304 305 3066	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 37556 57351 71044 11782 60662	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4	3 9 ions T**NUMBER C E RADIATOF 3 3 4 4 4 1 4	3.75 3.75)F**SIZE OF S NUMBER STACKS 2(14)1(15 (18)(19) 3(23)1(26 (16) 3(20)1(21)	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307	r of Colu of Radia ness of r feet pe RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4	3 9 ions T**NUMBER C E RADIATOF 3 3 4 4 4 1 4	3.75 3.75)F**SIZE OF S NUMBER STACKS 2(14)1(15 (18)(19) 3(23)1(26 (16) 3(20)1(21 (17)	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ 4 $(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4	3 9 ions T**NUMBER C E RADIATOF 3 3 4 4 4 1 4 1	3 3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ 4 $(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2})$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2	3 9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 4 1 4 1 3	3 3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ 4 $(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$) 3(55)
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308 309	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2	3 9 ions T**NUMBER C E RADIATOF 3 3 4 4 1 4 1 3 4	5 2 3 3 7 5 5 5 7 5 7 5 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ 4 $(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$) 3(55)) $3(67\frac{1}{2})1(72\frac{1}{2})$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308 309 310	r of Colu of Radia ness of r s feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 4 1 3 4 1 3 4 1	5 2 3 3 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$)) $3(55)$) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2}$)
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308 309 310 311	r of Colu of Radia ness of r s feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4 477 1/2	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 4 1 3 4 1 5	5 2 3 3 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$) 3(55)) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2}$) 5(65)
Width Thickr Square ROOM** NO. \$91 302 303 304 305 304 305 3066 307 308 309 310 311 312	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649	mes per stack tors adiators sect r stack N**SQUARE FEE FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 477 1/2 67 1/2	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 4 1 3 4 1 5 1	3 2 3 3 7 5 5 5 5 5 5 5 5 5 5 5 5 5	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2})$) $3(55)$) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2})$ 5(65) (37 $\frac{1}{2})$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308 309 310 311 312 313	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071	mes per stack tors adiators sect r stack N**SQUARE FEF FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 477 1/2 67 1/2 93 3/4	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 3 4 1 5 1 2	3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2})$ 5(65) (37 $\frac{1}{2})$) $(37\frac{1}{2})$) $(37\frac{1}$
Width Thickr Square ROOM** NO. *91 302 303 304 305 3066 307 308 309 310 311 312 313	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071	mes per stack tors adiators sect r stack N**SQUARE FEF FAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 3 4 1 5 1 2	3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2}$)) $(32\frac{1}{2})(30)$
Width Thickr Square ROOM** NO. *91 302 303 304 305 3066 307 308 309 310 311 312 313	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071	mes per stack tors adiators sect r stack N**SQUARE FEF RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4	3 9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 3 4 1 5 1 2	3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ (32 $\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ (37 $\frac{1}{2}$)) $(32\frac{1}{2})(30)$
Width Thickr Square ROOM** NO. \$91 302 303 304 305 3066 307 308 309 310 311 312 313	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 477 1/2 67 1/2 93 3/4	3 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 4 1 3 4 1 5 1 2	3 3 7 3 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ ($32\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ ($37\frac{1}{2}$)) $(32\frac{1}{2})(30)$
Width Thickr Square ROOM** NO. *91 302 303 304 305 3066 307 308 309 310 311 312 313	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4	3 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 3 4 1 3 4 1 5 1 2 5 1 2 5	3 3 3 5 1 3 <td< td=""><td>RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)(40)$) $3(50)1(52\frac{1}{2})(32\frac{1}{2})(37\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})(37\frac{1}{2})(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet</td></td<>	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)(40)$) $3(50)1(52\frac{1}{2})(32\frac{1}{2})(37\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})(37\frac{1}{2})(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet
Width Thickr Square ROOM** NO. #91 302 303 304 305 3066 307 308 309 310 311 312 313 313 Total Total	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 93 3/4 n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 4 1 3 4 1 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 5 1 2 5 5 1 2 5 5 5 5	3 3 3 75 0F**SIZE OF STACKS 2(14)1(15 (18) (19 4(19) 3(23)1(26 (16) 3(20)1(21 (13) 3(27)1(29 (15) 5(26) (15) (13) (12 0R***** 200	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ ($32\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ ($37\frac{1}{2}$)) $(32\frac{1}{2})(30)$ 2 square feet 3
Width Thickr Square ROOM** NO. #91 302 303 304 305 3066 307 308 309 310 311 312 312 312	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 93 3/4 n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 3 4 1 3 4 1 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 2 5 1 5 5 1 2 5 5 5 5	3 3 3 5 1 3 <td< td=""><td>RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ ($32\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ ($37\frac{1}{2}$)) $(32\frac{1}{2})(30)$ 2 square feet 3</td></td<>	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$) $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ ($32\frac{1}{2}$)) $3(67\frac{1}{2})1(72\frac{1}{2})$ ($37\frac{1}{2}$)) $(32\frac{1}{2})(30)$ 2 square feet 3
Width Thickr Square ROOM** NO. #91 302 303 304 305 3066 307 308 309 310 311 312 313 312 313 Total Total Total	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11783 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o radiatio	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 56 1/4 412 1/2 56 1/4 477 1/2 93 3/4 n surface for f radiators i n surface for	ions9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 3 4 1 5 1 2 FIRST FLOC nstalled SECOND FLOC	3 3 3 5 1 3 <td< td=""><td>RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 3 1.25 sq.feet</td></td<>	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 3 1.25 sq.feet
Width Thickr Square ROOM** NO. #91 302 303 304 305 3066 307 308 309 310 311 312 313 312 312 312 Total Total Total Total	r of Colu of Radia ness of r feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o radiatio	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4 n surface for f radiators i n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 3 4 1 5 1 2 FIRST FLOC nstalled SECOND FLO nstalled	3 3 3 75 0F**SIZE OF STACKS 2 (14)1 (15 (18) (19 3 (23)1 (26 (16) 3 (20)1 (21 (13) 3 (27)1 (29 (15) 5 (26) (15) 0R***** 20R****	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 3 1.25 sq.feet 1
Width Thickr Square ROOM** NO. #91 302 303 303 304 305 3066 307 308 309 310 311 312 313 312 313 Total Total Total	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o radiatio	mes per stack tors adiators sect r stack N**SQUARE FEF RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4 n surface for f radiators i n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 3 4 4 1 3 4 1 5 1 2 FIRST FLOC nstalled SECOND FLO nstalled	3 3 3 75 0F**SIZE OF STACKS 2 (14)1 (15 (18) (19 3 (23)1 (26 (16) 3 (23)1 (26 (16) 3 (23)1 (21 (13) 3 (27)1 (29 (15) 5 (26) (15) 0R***** 20R***** 20R***** 20R***** 20R****	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $4(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 1 1.25 sq.feet
Width Thickr Square ROOM** NO. #91 302 303 303 305 3066 307 308 309 310 311 312 313 312 313 Total Total Total Total	r of Colu of Radia ness of r efeet pe *RADIATIO LOSS 31847 27556 57351 71044 11782 60662 9337 49346 75922 11116 98214 13649 19071 radiatio number o radiatio	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4 n surface for f radiators i n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 3 4 1 5 1 2 FIRST FLOO nstalled SECOND FLO nstalled THIBD FLOO	3 3 3 75 0F**SIZE OF STACKS 2 (14)1 (15 (18) (19 3 (23)1 (26 (16) 3 (23)1 (26 (16) 3 (20)1 (21 (13) 3 (27)1 (29 (15) 5 (26) (15) 0R***** 0OR**** 20R***** 0OR**** 20R**** 0OR**** 30R****	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $4(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 1 .25 sq.feet
Width Thickr Square ROOM** NO. #91 302 303 303 304 305 3066 307 308 309 310 311 312 313 Total Total Total Total Total	r of Colu of Radia ness of r e feet pe *RADIATIO LOSS 31847 37556 57351 71044 11783 60663 9337 49346 75933 11116 98214 13649 19071 radiation number of radiation	mes per stack tors adiators sect r stack N**SQUARE FEE RAD.SURFAC 161 1/4 138 3/4 285 - 356 1/4 60 - 303 3/4 48 3/4 247 1/2 412 1/2 56 1/4 477 1/2 67 1/2 93 3/4 n surface for f radiators i n surface for f radiators i	ions9 ions9 T**NUMBER C E RADIATOF 3 4 4 1 3 4 1 5 1 2 FIRST FLOO nstalled SECOND FLO nstalled THIRD FLOO	3 3 3 75 0F**SIZE OF STACKS 2 (14)1 (15 (18) (19 3 (23)1 (26 (16) 3 (23)1 (26 (16) 3 (23)1 (21 (13) 3 (27)1 (29 (15) 5 (26) (15) 0R***** 0OR**** 20R***** 0OR**** 30R*****	RADIATORS. OF LENGTH OF RADIATORS) $2(35)1(37\frac{1}{2})$) $(45)(47\frac{1}{2})$ $4(47\frac{1}{2})$) $3(57\frac{1}{2})1(65)$ (40)) $3(50)1(52\frac{1}{2})$ $(32\frac{1}{2})$) $3(67\frac{1}{2})1(72\frac{1}{2})$ $(37\frac{1}{2})$) $(32\frac{1}{2})(30)$ 2 square feet 1 .75 sq.feet



r

,

· .

. .

.

Complete tabulation for the square feet of radiation required for the individual rooms for the R.E.Olds Engineering Hall with the size of radiators installed.

		FOUF	RTH FLOOD	2		
Height	of windo	ows from t	he floor	r31	10"	
Height	of radia	itors used		32	3 11	
Number	of colum	nes per st	ack	8	3	
Width	of Radiat	tors		81	II .	
Thickn	ess of or	ne stack		2	<u>,</u> ,2 n	
Square	feet per	r stack		3	5 ⁻ 1/3	
ROOM**	RADIATION	N**SQUARE	FEET **N	MBER OF	S*SIZE OF RAD	IATORS
NO.	LOSS	RAD.SUF	RFACE R	DIATORS	B NUMPER OF	LENGTHOF
					STACKS	RADIATORS
401	4008 0	203	1/3	3	S(SO)1(SI)	2(50)1(52)
402	34725	176	2/3	2	(26) (27)	(65) (67 支)
403	47287	240	-	3	3(24)	3 (60)
404	****	***		*	****	****
405	70179	366	2 /3	4	3(27)1(29)	$3(67\frac{1}{2})1(72\frac{1}{2})$
406	10282	53	1/3	1	(16)	(40)
407	6992 3	366	2/3	4	3(27)1(29)	$3(67\frac{1}{2})1(72\frac{1}{2})$
408	7456	36	2/3	1	(11)	(27 1)
409	35413	180	-	2	2(27)	2(67 2)
410	109103	533	1/3	6	5(26)1(30)	5(65)1(75)
411	9877	50	-	1	(15)	(37 2)
412	90240	466	2/3	5	5(28)	5(70)
413	11948	63	1/3	1	(19)	(47 2)
414	19779	100	-	2	2(15)	2(37 1)
Mat = 7			A			
Total	radiation		IOT FOUL	RTH FLOC	R ***** 8846	,666 sq.feet
Total	number of	radiatoi	s insta.	Llea	***** 35	
					•••	
ምርምል፣			T እ ፣ ም ፣ ም ፣			
TOTAL	RADIATINO	3 SURFACE	IN THE P	BUILDINE	} *****by fl	oors
TOTAL	RADIATINO	G SURFACE	IN THE I BASI	BUILDINE	<pre>3 *****by fl 1616.66 Squar 2002.00 Squar</pre>	oors e feet
TOTAL	RADIATINO	G SURFACE	IN THE I BASI FIRST FI	BUILDINE EMENT:	*****by fl 616.66 Squar 8002.00 Squar	oors e feet e feet
TOTAL	RADIATINO	G SURFACE Se	IN THE I BASI FIRST FI MEOND FI	BUILDINE EMENT:I LOOR: * 2 LOOR:- 2	<pre> *****by fl 616.66 Squar 3002.00 Squar 471.25 Squar 75 Squar </pre>	oors e feet e feet e feet
TOTAL	RADIATINO	G SURFACE	IN THE I BASI FIRST FI COND FI THIRD FI FOURTH 1	BUILDINE EMENT:-1 LOOR:* 2 LOOR:- 27 LOOR:-27	<pre>*****by fl l616.66 Squar 3002.00 Squar 3471.25 Squar '08 .75 Squar 2836 66 Squar</pre>	oors e feet e feet e feet e feet
TOTAL	RADIATINO	G SURFACE Se	IN THE BASI FIRST FI COND FI THIRD FI FOURTH 1	BUILDINE EMENT: - 1 LOOR: * 2 LOOR: - 2 LOOR: - 27 FLOOR: - 27	*****by fl 616.66 Squar 002.00 Squar 471.25 Squar 08.75 Squar 836.66 Squar	oors e feet e feet e feet e feet e feet
TOTAL FOR BU	RADIATINO	G SURFACE Se	IN THE P BASI FIRST FI CEOND FI THIRD FI FOURTH P	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27	*****by fl 616.66 Squar 002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar	oors e feet e feet e feet e feet e feet e feet
TOTAL FOR BU TOTAL	RADIATINO VILDING · NUMBER ON	G SURFACE SP *********** F RADIATOP	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H S INSTA	BUILDINE EMENT:-1 LOOR:* 2 LOOR:-27 LOOR:-27 LOOR:-27 LOOR:-27	*****by fl 616.66 Squar 002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar	oors e feet e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO VILDING ' NUMBER OI	G SURFACE SE *********** F RADIATOP	IN THE BASI FIRST FI MOND FI THIRD FI FOURTH B RS INSTAT BASE	BUILDINE EMENT:-1 LOOR:* 2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-	*****by fl 616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 635.32 Squar 1635.32 Squar ****** BY flo 27	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO VILDING * NUMBER CI	G SURFACE SP *********** F RADIATOP	IN THE H BASI FIRST FI MOND FI THIRD FI FOURTH H SINSTA BASE FIRST FL	BUILDINE EMENT:-1 LOOR:*2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 MENT:-20 COR:-27	*****by fl 616.66 Squar 3002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar ****** BY flo 27 33	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO ILDING · NUMBER ON	SURFACE SE TRADIATOR SEC	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H SINSTAN BASE FIRST FLO	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 COR:-27 MENT:-27 COR:-27	*****by fl 616.66 Squar 3002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar ****** BY flo 27 33 31	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO VILDING · NUMBER OI	G SURFACE SE *********** F RADIATOP SEC	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H RS INSTAT BASE FIRST FLO COND FLO	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- DOR:- DOR:- COR:-	*****by fl 616.66 Squar 002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar ****** By flo 27 33 31 35	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO VILDING ' NUMBER O	G SURFACE SE *********** F RADIATOP SEC J	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H RS INSTAT BASE FIRST FL COND FLO FURTH FI	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 DOR:-27 COR:	*****By fl 616.66 Squar 002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar 635.32 Squar .27 33 31 35 35	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO VILDING * NUMBER CI	G SURFACE SP *********** F RADIATON SEC J H	IN THE BASI BASI FIRST FI MOND FI THIRD FI FOURTH B SINSTAL BASE FIRST FL COND FLO THIRD FL FOURTH FI	BUILDINE EMENT:-1 LOOR:*2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 COR:	*****by fl 616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 635.32 Squar 1635.32 Squar ****** BY flo 27 33 31 35 35 161	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL	RADIATINO	G SURFACE SE TION LOSS	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H SINSTAL COND FLO COND FLO COND FLO COND FLO COND FLO COND FLO	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- COR:- COR:- COR:- LOOR:- LOOR:- COR:-	<pre>*****by fl 616.66 Squar 3002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161</pre>	oors e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL FOR BU CORRIJ	RADIATINO VILDING * NUMBER ON	G SURFACE SE F RADIATOR SEC TION LOSS	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H RS INSTAL BASE FIRST FLO COND FLO FHIRD FLO FOURTH FI FOURTH FI FOURTH FI FOURTH FI FOURTH FI FOURTH FI	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- DOR:- DOR:- COR:- LOOR:- LOOR:- SIZE OF	*****By fl 616.66 Squar 002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar :***** BY flo 27 33 31 35 35 161 RADIATORS IN	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL FOR BU CORRIN BASEMI	RADIATING	SURFACE SE TION LOSS	IN THE H BASI FIRST FI CAOND FI THIRD FI FOURTH H RS INSTAL BASE FIRST FLO COND FLO FURTH FI FOURTH FI FOURTH FI FOURTH FI FS WITH BB.T.U.	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 DOR:-27 DO	*****By fl 616.66 Squar 3002.00 Squar 471.25 Squar 2836.66 Squar 635.32 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN	oors e feet e feet e feet e feet e feet ors
TOTAL FOR BU TOTAL FOR BU CORRIN BASEMI 1st f: 3nd f	RADIATING	SURFACE SE SE F RADIATOR F RADIATOR SEC TION LOSS 5195 9212	IN THE H BASI FIRST FI MOND FI THIRD FI FOURTH H SASE COND FLO THIRD FLO COND FLO THIRD FLO FOURTH FI SES WITH BB.T.U. 3	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:-27 COR:-27 CO	*****by fl 616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal39967	oors e feet e feet e feet e feet ors NSTALLED
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI lst f: 3nd f: 3nd f:	RADIATING	SURFACE SE F RADIATOR F RADIATOR SEC TION LOSS 51953 9212 P CREC	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H SASE FIRST FLO COND FLO THIRD FLO FOURTH FI SOURTH FI SB. T.U. 3 " 4 "	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- COR:- COR:- COR:- COR:- COR:- SIZE OF	<pre>*****by fl l616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 1635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347</pre>	oors e feet e feet e feet e feet ors NSTALLED
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI 1st f 3rd f 3rd f 4th f	RADIATING	SURFACE SE SE FRADIATOR SEC TION LOSS TION LOSS 5195 9212 n care of n care of	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H SASE FIRST FL COND FLOO THIRD FLOO THIR	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- COR:- COR:- COR:- COR:- SIZE OF SIZE OF	<pre>*****by fl 616.66 Squar 3002.00 Squar 471.25 Squar 08 .75 Squar 836.66 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347 7244 Total1</pre>	oors e feet e feet e feet e feet ors ISTALLED 5 B.t.U.
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI 1st f: 3rd f: 3rd f: 4th f: Radia	RADIATING VILDING NUMBER ON VILDING NUMBER ON VILDING NUMBER ON NUMBER ON NU	G SURFACE SE SE SE F RADIATOR SEC TION LOSS S1955 9212 n care of n care of ace recut	IN THE H BASI FIRST FI COND FI THIRD FI FOURTH H SASFI FIRST FLO COND FLO THIRD FLO THIRD FLO THIRD FLO THIRD FLO THIRD FLO THIRD FLO SURTH FI BB.T.U. 3 " 4 " by plen by plen	BUILDINE EMENT:-1 LOOR: * 2 LOOR: - 27 FLOOR: - 27 FLOOR: - 27 FLOOR: - 27 MENT: - 27 MENT: - 27 COR: - 27	*****By fl 616.66 Squar 3002.00 Squar 3471.25 Squar 208 .75 Squar 336.66 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347 7244 Total1 .005998.18	oors e feet e feet e feet e feet ors NSTALLED 5 B.t.U. 65591 B.T.U. souare feet
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI lst f: 3rd f: 3rd f: 4th f: Radia Two re	RADIATING VILDING NUMBER OF VILDING VILDING NUMBER OF VILDING NUMBER OF NUMBER OF NUMB	SURFACE SE SE SE SE F RADIATOR F RADIATOR F SEC J SEC SEC SEC SEC SEC SEC SEC SEC SEC SEC	IN THE H BASI FIRST FI MOND FI THIRD FI FOURTH H SASE RS INSTA BASE FIRST FL COND FLO THIRD FL FOURTH FI SB.T.U. 3 " 4 " by plen by plen red	BUILDINE EMENT:-1 LOOR: * 2 LOOR: - 2 FLOOR: - 2 COR:	<pre>*****by fl l616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 1635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347 7244 Total1 .005998.18 in each side</pre>	oors e feet e feet e feet e feet ors NSTALLED 5 B.t.U. 65591 B.T.U. square feet e ntrance
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI lst f: 3rd f: 3rd f: 4th f: Radia Two ra of (2)	RADIATING ILDING NUMBER ON NUMBER	SURFACE SE SE SE SE SE SEC SEC SEC SEC SEC SE	IN THE H BASI FIRST FI MOND FI THIRD FI FOURTH H ***********************************	BUILDINE EMENT:-1 LOOR: * 2 LOOR: - 27 FLOOR: - 27 FLOOR: - 27 FLOOR: - 27 FLOOR: - 27 MENT: - 27 COR: - 2	<pre>*****by fl l616.66 Squar 3002.00 Squar 3471.25 Squar 3836.66 Squar 1635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347 7244 Total1 .005998.18 in each side e 10 square f</pre>	oors e feet e feet e feet e feet ors STALLED 5 B.t.U. 65591 B.T.U. square feet e entrance feet per stack
TOTAL FOR BU TOTAL FOR BU CORRII BASEMI 1st f: 3rd f: 3rd f: 4th f: Radia Two ra of (3: with 5:	RADIATING VILDING *** NUMBER OF VILDING*** DOR RADIA ENT****** loor loor take loor take loor take stion surf adiators 5 stacks 3" width	SURFACE SE SE SE SE SE F RADIATOR SEC SEC SI95 9212 n care of a care of care of a care of care of a care of care of a care of care	IN THE H BASI FIRST FI MOND FI THIRD FI FOURTH H ***********************************	BUILDINE EMENT:-1 LOOR: * 2 LOOR:-27 FLOOR:-27 FLOOR:-27 FLOOR:-27 MENT:- COR:	<pre>*****by fl 616.66 Squar 3002.00 Squar 3471.25 Squar 336.66 Squar 635.32 Squar ****** BY flo 27 33 31 35 35 161 RADIATORS IN tal 19963 8347 7244 Total1 .005998.18 in each side e 10 square f h of radiator</pre>	oors e feet e feet e feet e feet ors ISTALLED 5 B.t.U. 65591 B.T.U. square feet e entrance feet per stack c.Length of

-

STEAM PIPING AND CONNECTIONS for the instalation of Radiators.

No. of Pieces.	BASEMENT. Size of Pieces.	Kind of equipment.	length per piece	Total .length.
3 31 27 2 1 27	(3) (3) (3) (3) (3) (3) (3) (3) (3) (3)	Elbows Tees Risers Riser Arm Total 3"	132feet 16 feet 15 feet 5 1 foot piping	364.5 feet 32.0 feet 15.0 feet
	First Floor	•		
1 35 31 1	(3) (3x3) (3) (3)	Elb ows. Tees Risers	13 <u>2</u> 13 <u>2</u> feet 1 8 feet	445.5 feet 18.0 feet
33	(2)	Riser Arms	1 foot	33.0 feet
		Totad 2	" piping -	496.5 feet.
	Second Flo	or.		
1 31 31	(2x2) (2x3x2) (2) (2)	Elbows. Tees Risers,	13½ feet 17 f e et	418.5 feet. 17.0 feet.
31	(2)	Riser Arms	. 1 foot	31.0 feet.
		Total 2	2" piping	466.5 feet.
	Third Flo	or.		
38 36	(2x2x2) (2)	Elbows. Tees Risers	13 1 feet	406.0 feet
36		Riser Arms	l foot	36.0 feet
		Total	2" piping	442.0 feet
	Fourth	Floor.		
40 34 36	(3x3) (3x3x2) (3x3	Elbows Tees Risers	9 feet	324 feet
35	(2)	Riser Arms	l foot	35 feet

Total 2" piping 359.0 feet

.

Attic Steam Main Piping.

Number of required.	pieces Size of piping.	Kind of equipment.	Length of one piece	Total length of piping.
1 2 3 2 1 1 1 2 36		Steam Main.	24 feet 20 feet 8 foet 14 feet 16 feet 13 feet 18 feet 4 feet	24 feet 40 feet 24 feet 28 feet 16 feet 13 feet 18 feet 144 feet
1 1 2 4 1 1 1 1	3 " 3 " 3 " 3 " 3 " 3 " 3 " 3 "		25 feet 2 feet 19 feet 4 feet 20 feet 12 feet 21 feet	25 feet 2 feet 38 feet 16 feet 20 feet 12 feet 21 feet
4 3 2 1 1 1 2 1	41 41 41 41 41 41 41 41 41 41		3 feet 15 feet 10 feet 4 feet 16 feet 9 feet 17 feet 26 feet 6 feet	12 feet 60 feet 30 feet 8 feet 16 feet 9 feet 17 feet 52 feet 6 feet
The length 2 2	of piping lead: 6" 6"	ing to Attic	c Steam M áin 20 feet 21 feet	:- 40 feet 42 feet
1 1 1	6" 6" 6"		5 f eet 18 feet 20 feet	5 feet 18 feet 20 feet
Total $2\frac{1}{2}$ in Total 3 in Total 4 in Total 6 in Total 3 in Total 2 in Total (2x2) Total (2x2x Total (4x2) Total (4x2)	nch piping requir nch piping requir ch piping requir ch piping requir 900Elbows requir 2) Tees required x4) Tees required	ired red red red red i i ed	315 144 218 125 2202 - 4 169	feet feet feet. 5 feet.

Attic acd Eadiator Eisers and Connections:-

Total (4x4) Flbows required -----Total (4x3x $2\frac{1}{2}$) Tees required -----Total (3x $2\frac{1}{2}$ x3) Tees required -----Total (3x $2\frac{1}{2}$ x $2\frac{1}{2}$) Tees required -----Total ($2\frac{1}{2}$ x $2\frac{1}{2}$) Tees required -----Total ($2\frac{1}{2}$ x $2\frac{1}{2}$) Tees required -----Total ($2\frac{1}{2}$ x $2\frac{1}{2}$) Tees required ------6 2 8 2 9 Total(2 x2) Elbows required ----- 39 Total $(2\frac{1}{2}x3x2\frac{1}{2})$ Tees required ----- 1 Total $(3x2\frac{1}{2})$ Elbows required ----- 1 Total $(2\frac{1}{2}x2\frac{1}{2})$ Elbows required ----- 3 Total number of Radiator Valves ----- 165 Victor Auto type All Radiator valves to be of the Victor Automatic type No 7. All Riser pipes to be of wrought iron threaded and reamed for assembly. All Riser Arms to be threaded and reamed for assembly. All Radiators to be tapped at two thirds(2/3) the distance from the bottom for air valvess and threaded to one quarter (1/4) inch for value connections. All-fittings to be threaded for Radiators and Steam line with sufficient pitch to insure tight joints. All radiator s to be equipped with female connection witha enough pitch to insure good drainage. All Tees and Elbows to be of cast iron and threaded for connection. Steam Headers and branches to top of Risers on the fourth floor and leading to fourth floor mains to be covered with Asbestos Cement Felting recommended by the Crane Co. Number eight grade to be used on all steam headers. Steam headers to be provided with Expansion Pipe Hangers or Ring Hooks as recommended by the Crane Company . Hangers to be placed at TEN foot intervals along the Header with sufficient distance between the hanger and the end of the pipe when making a turn to allow for the free expansion of the pipe --- three feet at least between the end of the pipe and the hanger. The number of Hangers required of the different sizes of pipe are:-

For 4 inch pipe26For 3 inch pipe10For 2½ inch pipe10Each Hanger to be provided with :-0ne Plate, One button, and one ring.One hundred (100) feet of one half, (1/2) inch pipeinten foot length, for use in hangers.Twenty4feet (24) of one half(1/2) inch pipe in twelvefoot lengths, for use in hangers.

Risers are to be provided with Crane's Patent Ceiling Plates for wrought iron pipe. One Hundred and sixty five(165) Ceiling plates required.Also I floor plate is required for each riser Making (165) required for the building. Determination of the size of Plenum fan required for the Ventilation of the New R.E.Olds Mechanical Building and the size of Heater to deliver the ventilating air at the required Temperature of 87.2°.

With a velocity of air over the coils at 1000 feet per minute the number of sections of four pipes deep required to deliver air with the outside temperature of the air at zero degrees and the temperature of the air leaving the coils at 87.2 degrees, is four sections making a total depth of the heater sixten pipes deep.

The total air to be delivered for ventilating purposes in cubic feet per hour is 2,717,600.

The heat necessary in B.T.U. per hour to raise this air from zero ° to 87.2 ° is:-

H equals Q times the difference between the air from the coils and the room temperature to be kept constant divided by 55(the number of degrees through which theone cubic foot of air can be raised by one B.T.U.)

H equals 2,717,600 x 87.2-70/55 -----850,000 B.T.U. Total heat loss by ventilation is 850,000 plus

25% (850,000) the excess air required for leakage losses equals 1,062,500 B.T.U.

Atfour pipes with four section heater of the Buffalo Heater return bend type of heaterwith a velocity of 1000 feet per minute over the coilseach lineal foot of pipe will deliver 661 B.T.U. at 87.2° F. The total lineal feet of pipe required to deliver 1,062,500 B.T.U. per hour are:-

1,026,500/ 661 equals------1610 feet The free air space in a 1651 lineal foot ,four sections four pipes deep is 46 square feet.

The free air space required for the delivery of 2,717,600 cubic feet of air per hour which is needed for ventilating purposes at a velocity of 1000 feet per minute over the coils at 87.2°F is:-

2,717,600/ 60x1000 equals 45.29 square feet. Heater@ -

R.B. manufactured by the Bulfalo Fan Company with 170 pipes,

Length of section	9feet 6 inches
width of base	10 inches
Extreme height	l0feet 4 inches.
Total weight	3770 pounds.

Plenum Fan.

With the fan delivering againsta static pressure of One inch and required to deliver 2,717,600 cubic feet per hour or 45,290 cubic feet per minute:-

Fan number required to deliver this necessary air is :-

Number --- 1860 delivers 48,900 cubic feet per minute. Number --- 180 delivers 60,300 cubic feet per minute both running ay full rated capacity.

For mease of necessity Fan number 180 is the best instalation with a full rated capacity of 60, 300 cubic feet per monute running at 185 R.P.M. with 27.55 B.H.P. required for operation. The Fan speed can be cut down when delivering the required air but in case of necessity can be operated at full rated capacity and deliver air at the necessary velocity and temperature with live steam supplied to the heater at a higher pressure and temperature. · · ·

• •

Fan number 180 is manufactured by the American Blower Company And listed in their Steel Plate Fan Catalogue . The diameter of the wheel is:-----108 inches

Cubic Feet per minute -----60,300 R.P.M. ----- 185 B.H.P ----- 27.55

Fan must be placed at least 36 inches from the inner surface of the Heaterto insure good draft and no increase in friction due to short bend onthe air entering the main air duct . The Heater shall be equipped with the necessary

The Heater shall be equipped with the necessary connections for the steam drip and the steam mains or headers with steam at b five pounds gage and of sufficient strength to withstand a pressure of 30 pounds of live steam when it is required to. These connections will be as stipulated by the Buffalo Fan Company for the size heater which I have determined, of the Buffalo Return Bend Type . DETERMINATION OF THE SIFE OF AIR DUCTS AND THE Registers for the individual rooms, with a complete tabulation of the cubic feet of air required for the ventilation of the room ,the velocity of the air leaving the register ,thenet area of the register in square inches, the dimensions of the registers and the size of uptake for each room.

The velocity of the air in the main amr duct after leaving the Fan.--1600 feet per minute.

FORMULAE USED IN THE COMPUTATION OF THE SIZE OF NET Register. This formulae applies to the air ducts or register openings as well as any part of the main air duct.

AREA IN SQ.IN.EQUALS**144xQ'/60xV Q'-- the ventilating air supplied per hour. V -- the velocity of the air leaving the register. 144/60 puts the area in square inches ,NET.

ROOM	4**CU.FT.	*VEL.OF*	*NET AREA*	** SIZE OF ***	*** SIZE OF
	AIRPER	AIR '	CF	REGISTERIN	UPTAKE IN
	HOUR	FTZIIN.	FEGISTER	INCHES	INCHES.
1	9000	200	108	(10 z10)	(10x10)
2	7200	150	115	(10x10)	(10x10)
3	27000	3 50	186	(10x18)	(10x18)
4	18000	200	216	(16x14)	(16x14)
5	18000	200	216	(16x14)	(16x14)
6	5400	150	86.5	(8x12)	(8x12)
7	1 800 0	200	216	(16x14)	(16x14)
8	* * * *	* * *	* * *	*****	*****
Ş	5400	150	86.5	(8x12)	(8x12)
10	36000	250	345	(18x20)	(18x20)
11	54000	350	361	(18x20)	(18x20)
12	54000	300	432	(18x24)	(18x24)
13	9000	200	108	(10x10)	(10x10)
14	18000	150	288	(12x12)(12x12)	(12x12)(12x12)
15	10 80Q0	250	104	(none)	(10x10)
101	3600	90	96	(10×10)	(10×10)
102	54.00	150	90 96 5	$\left(\begin{array}{c} 10 \times 10 \end{array} \right)$	$(2^{+})^{2}$
102	3600	100	00.0		(10×10)
104	5400	150	86 5	(8x12)	(8x12)
105	27000	150	432	(10x12)(16x20)	(16x14)(16x20)
106	5400	150	8 6.5	(8x12)	(8x12)
107	27000	150	432	(18x24)	(16x26)
108	3600	90	96	(10x10)	(8x12)
109	45000	200	538	(16x34)	(16x34)
110	32000	150	432	(12x18)(12x18)	(12x18)(12x18)
111	270000	450	1440	(24x30)(24x30)	(10x10)(18x74)
112	9000	200	108	(10x10)	(10x10)
113	54000	250	518	(20x26)	(18x24)
114	5400	150	86,5	(8x12)	(8x12)
115	45000	200	538	(30x18)	(18x 3 0)

Calculations and tabulation of the size of registers on the Second, Third and Fourth Floors.

ROOM	**CU.FT**	*VEL.OF#	*NFTAREA	*****SIZF OF***	*** SIZE OF
201 202 203 204 205 206 207 208 209 209 210 211	AIR PER HOUR 7200 36000 45000 45000 5400 5400 5400 5400 540	AIR FTAMIN 150 250 150 250 150 250 250 150 300 500 2	OF PEGISTE 115 192 432 720 360 86.57 518 608 115 432 160	BEGISTER IN R INCHES (lox10) (lox10) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lox20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx20) (lbx24) (lbx24) (lbx24) (lbx24)	UMTAKE IN INCHES (10x10) (10x10) (10x10) (16x24) (16x24) (18x24) (18x24) (10x10) (18x34) (20x26) (10x10) (10x34) (10x10) (18x24)
301 302 303 304 305 306 307 308 309 310 311 312 313	45000 54000 54000 7200 54000 7200 27000 36000 7200 36000 7200 9000 14400	250 250 250 250 150 150 150 150 150 150 200 350	432 518 518 115 518 115 518 115 518 115 578 115 578 108 99	(18x24) (18x24) (20x26) (20x26) (10x10) (20x26) (10x10) (18x24) (24x24) (10x10) (18x24) (18x24) (10x10) (10x10)	(18x24) (18x24) (16x32) (20x26) (10x10) (20x26) (8x13) (18x24) (24x30) 10x10) (20x20) (18x24) (10x10) (10x10) (12x12)
$\begin{array}{c} 401\\ 402\\ 403\\ 404\\ 405\\ 406\\ 406\\ 407\\ 408\\ 409\\ 410\\ 412\\ 413\\ 413\\ 414 \end{array}$	36000 36000 45000 **** 54000 7200 54000 7200 27000 108000 72000 72000 5400 27000	300 375 *** 300 150 300 150 250 450 150 250 150 450	288 288 288 288 432 115 432 115 259 576 115 576 115 259 576 115 259 576 114	(12x24) (20x18) (12x24) ****** (18x24) (16x10) (18x24) ****** (13x20) (24x24) (10x10) (12x18) (18x18) (8x18)	(18x24) (12x25) (20x26) ****** (20x26) (10x10) (20x26) (10x10) (12x32) (24x24) (10x10) (18x24) (18x24) (18x24) (18x24) (10x12) none opens to hall

CORFIDORS:-BASEMENT---27000 First floor 36000 Second floor 36000 Fourth floor 36000 Fourth floor 36000

Total Air required for the Cor idors 171000 cubic feet per h ur Allow 71000 " " " " Adr to be supplied by register on the second floor at west edd of corritor "elocity of air leaving register--300 ft/min Area of Pegister NET---- 965 sq.inches Dimensions on register(24x40) This air supplies the Ventilating heat loss for the Second, Third and Foutth Floor Corridors. DETERMINATION of the size of ducts leaving the fan and the auxiliary ducts leading the air to the room stacks.

With a Velocity of 1800 feet per minute of the air leaving the Fan with the fan delivering 2,717,600 cubic feet per hour the sectional area of the duct at the fan is: sq. Area ---144x2,717600/60x1800----- 3622inches The dimensions of the duct at this point are:- 60x60" The cross section of the duct under the basement corridor with the air at a velocity of 1400 feet per minute is:-Area ---144x2,717600/60x1400----- 4650 sq. inches. The dimensions of the duct at this point are:- 98x48"

•

TOTALS	FOR THE BUILDING BY	FLOORS.	
RADIATION	LOSS**AIR SUPPLIED VENTILATION.	FOF**NET AREA OF PADIATORS.	FLOORS.
318947	316800	1616.58	BASEMENT
397935	571400	20 98.60	FIRST FLOOR
546893	847800	2475.25	SECOND FLOOR
525 771	444800	2708.75	THIRD FLCOR
5464 1 5	576 800	2836.66	FOURTH FLOOR

Total radiation loss per hour from the Ruilding-2,335,961 B.TU. Total air supplied for Ventilation per hour -2,717,600 cu.ft Total Net radiator surface required for building- 11635.32 sqft



REOLDS MECHANICAL BVILDING BASEMENT PLAN FOR HEATING AND VENTILATING EQVIPMENT



١

REOLDS MECHANICAL BUILDING FIRST FLOOR PLAN FOR HEATING AND VENTILATING EQVIPMENT

. ٠ , .



REOLDS MECHANICAL BVILDING SECOND FLOOR PLAN FOR HEATING AND VENTILATING EOVIPMENT



R.E.OLDS MECHANICAL BVILDING THIRD FLOOR PLAN FOR HEATINGANDVENTILATING EQVIPMENT





REOLDS MECHANICAL BVILDING FOURTH FLOOR PLAN FOR HEATING AND VENTILATING

RECENT USE DELLA

.

•

.




















