



114
253
THS

LIBRARY
Michigan State
University



RETURNING MATERIALS:
Place in book drop to
remove this checkout from
your record. FINES will
be charged if book is
returned after the date
stamped below.

--	--	--

This thesis was contributed by

Mr. C. W. Knapp

under the date indicated by the department stamp, to replace the original which was destroyed in the fire of March 5, 1916.

TEST ON A HOT-BLAST

HEATING SYSTEM.

In the

Engineering Laboratory of the

MICHIGAN STATE COLLEGE.

by

C. W. Knapp. D. M. Bennett.

1912.

THESIS

In the installation of a hot blast heating system, one of the most important factors to take into consideration is the amount of air to be delivered per unit of time, or the velocity of the air.

It is customary to take the manufacturers rating of the fan to be used, with consideration for the losses due to friction in the conductor pipes, neglecting any losses that might occur due to friction of the coils in the heater.

Our object in performing this test has been to determine to what extent these losses due to the heater coils will affect the rated output or velocity of air delivered by the system, and, incidentally, obtain other data on the performance of a system of this type.

DESCRIPTION OF SYSTEM.

The complete system consists of five sections of four row coils, the long coils being 3'6" in length, and the short coils 3'3" in length. The pipe used in the coils is one inch pipe. The dimensions of the coils correspond to the standard No. 412 A type sections as manufactured by the Massachusetts Fan Co. There are twelve pipes in each row, with a spacing of 2.75 inches center to center. The fan is a No. 30 steel plate made by The American Blower Co. A 10 H.P. motor was used to drive the fan. The speed was varied by changing the pulleys on the fan shaft. The discharge pipe of the fan is 25 inches in diameter.

METHOD.

Six runs were made; the first with all five sections in the heater, the second with four sections, and so on, removing a section before each run, the last being run with all sections removed. Each run consisted of four tests, each at a different fan speed. The length of tests was 1 1/2 to 2 hours each.

The velocity of the discharge air was measured in the outlet pipe with a Pitot tube connected to a differential manometer, filled with a special solution, which read directly in inches of water. The mean velocity was obtained by raking manometer with the Pitot tube inserted midway between the circumferences of imaginary concentric circles which divided the discharge pipe into small areas in the cross-section, as shown by blueprint. The average velocity of the air passing thru each small area of the cross-section was then obtained from the application of the average manometer reading of the area in the formula for reducing the av. reading to velocity in feet per sec. The sum of all these average velocities multiplied by the area in which the velocity was measured was then divided by the whole area of the cross-section and the mean velocity of the discharge air was the quotient thus obtained. Having obtained the mean velocity the volume of air passing thru the outlet was obtained by multiplying the mean velocity by the cross sectional area of the discharge pipe. All velocities and volumes were corrected for a standard temperature and pressure of 70 degrees Fahr. and 29.92 In. of mercury. All curves plotted are based on the corrected velocities and volumes.

The pressure loss due to the coils in the heater was measured by means of a manometer attached to a series of 3/8" pipe so as to give the average drop, as shown in a blue print herewith.

The condensation from each coil was collected in large tanks and weighed at the end of each test.

Temperatures were taken of the air, as it entered, in the duct out of doors, and in the outletpipe where the Pitot tube readings were taken. The room temperature was also taken at the same time.

Barometer readings were recorded, also R.P.M. of motor and fan, and input of motor.

The steam pressure in the heater was maintained at 5 Lbs. guage.

The thermometers and steam guages were calibrated at the beginning of the test, and all thermometer readings were corrected from calibration curves.

A steam separator was placed in the main above the heater, and the quality of the steam used measured with a separating calorimeter.

The manner of computing the velocities by both the Pitot tube method and the condensation method are shown herewith for Test A-1.

PITOT TUBE METHOD OF MEASURING VELOCITIES.

Referring to tabulated data sheet of test A-1, the Av. of manometer readings No. 12 was taken as h-1, and the Av. of readings No. 1 and No. 11, 2 and 10, 3 and 9, etc. were taken as h-2, h-3, etc. No. 6 was taken as h-7. This arrangement was necessary as the Pitot tube could not be brought closer than 3" on one side of the outlet on account of its construction. These readings reduced to velocity in ft. per sec. correspond to v-1, v-2, etc. on blue print B.

The formula for reducing the manometer readings to velocity readings is $V = V \sqrt{\frac{2gh}{12} \times \frac{D}{d}} = 2.316 V \sqrt{\frac{hD}{d}}$

Where h equals Av. velocity head in inches of water.

D equals density of water at room temp. Kent-638.

d equals density of air at outlet temp. Kent-534.

TEST NO. A-1. RESULTS.


$$D = 62.14 \quad d = .067119 \quad V = 2.316 V \sqrt{h \times \frac{62.14}{.067119}} = 70.4 V \sqrt{h}$$

v-1 = 70.4 $\sqrt{.453}$ = 47.4	ft. per sec.	a-1 = 1.004	sq. ft.
v-2 = 70.4 $\sqrt{.513}$ = 51.1	" " "	a-2 = 0.829	" "
v-3 = 70.4 $\sqrt{.503}$ = 50.0	" " "	a-3 = .654	" "
v-4 = 70.4 $\sqrt{.509}$ = 50.2	" " "	a-4 = .480	" "
v-5 = 70.4 $\sqrt{.548}$ = 52.0	" " "	a-5 = .3054	" "
v-6 = 70.4 $\sqrt{.556}$ = 52.5	" " "	a-6 = .131	" "
v-7 = 70.4 $\sqrt{.550}$ = 52.2	" " "	a-7 = .0054	" "


a-1 x v-1 = 47.600
a-2 x v-2 = 42.400
a-3 x v-3 = 32.700
a-4 x v-4 = 24.030
a-5 x v-5 = 15.870
a-6 x v-6 = 6.870
a-7 x v-7 = .282
<u>169.752</u>

$$\text{Average velocity thru outlet} = \frac{169.752}{3.400} = 49.7 \text{ ft. per sec.}$$

$$\text{Cross sectional area of outlet} = 3.400 \text{ sq. ft.}$$





(A)



SHOWING METHOD OF
DIVIDING CROSS-SECTIONAL
AREA OF DISCHARGE
PIPE TO DETERMINE
AV. VELOCITY OF AIR
Velocity head read
for mid-point of
concentric circles
each 2" wide and
also in centre of
small inner circle
1" in diam.

(B)



METHOD OF MEASURING
PRESSURE DROP THRU COILS

(C)

CONDENSATION METHOD.

TEST A-1.

1. Atmospheric pressure = 14.12 Lbs. per sq. in.
2. Absolute steam pressure = 19.12 Lbs. per sq. in.
3. Quality of steam (see formula) = 93.30%
4. Latent heat of steam at 19.12 Lbs. per sq. in., = 961 B.T.U.
5. Latent heat of steam as used = 896 ".5.7.
6. Temperature of steam used.
7. Heat available per Lb. of steam = 896 ± (225.6 - 212) = 909.6 B.T.
8. Total condensation per hr. = 592.18 Lbs.
9. Total heat given up by steam = 592.18 x 909.6 = 5383647 B.T.U. hr
10. Total heat given up by steam = 8,977 B.T.U. per min.
11. Temperature rise of air = (108.5 - 37.3) = 71.2 degrees.
12. Pounds of air passing thru heater per min. = $\frac{8977}{71.2 \times .2375} = 532$ Lbs
13. Vol. of 1 Lb. of air at 108.5 degrees = 14.4 sq. ft.
14. Volume of air passing over heater = 532 x 14.4 = 7650 cu. ft. min
15. Area of outlet pipe = 3.409 cu. ft.
16. Free area thru heater = 5.47 sq. ft.
17. Velocity thru outlet = $\frac{7650}{3.409} = 2242$ ft. per min.
18. Velocity thru heater = $\frac{7650}{5.47} = 1400$ ft. per min.

Formula for quality of steam $q = \frac{\frac{APa}{42} \sqrt{\frac{3(P - Pa)}{Pa}}}{\frac{APa}{42} \sqrt{\frac{3(P - Pa)}{Pa}} + W}$

A = Area of orifice in sq. in.

Pa = Absolute pressure of atmosphere.

P = Absolute steam pressure.

W = Weight of separated water in Lbs. per second.

PERFORMANCE CURVES.

Curve sheet A shows the average friction loss in inches of water for different depths of sections, with fan delivering air at different velocities (in ft. per min. obtained from the condensation method). The curve was plotted from the data in Table A.

Curve sheet A-1 shows the curves from sheet A plotted logarithmically. The abscissae represent velocity in ft. per Min. starting at 1 on the sheet, for values of 1000, 1100, 1200 etc. with the corresponding pressure losses in inches of water as ordinates of the curves (1 representing a pressure loss of .1", 2 represents .2" etc.). Curve 1-1 is for a depth of one section, 2-2 for a depth of 2 sections etc. The points for curves 1-1 2-2 and 5-5 do not give a curve with an exact slope for which the exponent $n = 2$ in the equation $y = Bx^n$, but since curves 3-3 and 4-4 do, and since curves 1-1 and 2-2 give a greater slope and curve 5-5 gives a lesser slope than one for which $n = 2$, this value was taken as the average for all the curves. For an explanation of logarithmic curves see Kent 8th edition pg. 85,

Curve sheet B shows the average friction loss in inches of water for different depths of sections, for different fan speeds. These curves are plotted from data in table A.

Curve sheet C shows the average friction losses for different depths of sections for the same fan speed. This curve is plotted from values taken from curves on curve sheet B.

Curve sheet D shows the velocities in ft. per min. produced for different depths of sections, by different fan speeds. The velocity is that thru the free area in heater, as measured by Pitot tube method. The points for curve are taken from table A.

Curve sheet E shows the condensation per sq. ft. per hr. for various section depths for different velocities of air in ft. per min thru the heater, as calculated by the condensation method.

Curve sheet F shows the different velocities produced for different consumptions of power. From table A.

Curve sheet G shows the power necessary to drive the fan at various speeds with five sections in the heater. The depth of sections does not alter the power required at low speeds, and only very slightly at higher speeds, so the curve shown may be assumed as that for any depth of sections for speeds shown.

These curves show, in general, that for a constant fan speed the pressure loss varies approximately as the depth of sections, and the square of the velocity, (curve A) and with the fan speed in a ratio of 3:2. (Curve B), calculations base on the condensation method of measuring velocity.

The relative velocity loss is found to vary directly both as the fan speed and as the depth of sections. (Curve sheet D).

Curve sheet E is probably only approximately correct, owing to trouble in collecting condensation. However it shows that the condensation per sq. ft. per hour increased at a much more rapid rate for five sections as the velocity increases, than for a lesser depth of sections, or in other words the condensation per sq. ft. increases more rapidly the greater the depth of sections.

We find that taking all friction losses into consideration the power input increases gradually in a uniform manner, up to a fan speed of about 500 R.P.M. and a delivery of about 1000 ft. of air per min. after which the input increases at a rapid rate.

A glance at the curves will give quite complete information as to the performance of the system. For instance, taking the sheets in order, if we desire to know the performance of the system, under the standard conditions calculated, for a depth of five sections and a fan speed of 500 R.P.M., we find the pressure loss is .36 inches of water, the velocity of the air thru the heater is 755 ft. per min. (Condensation Method) or 1125 ft. per min. (Pitot tube method), The condensation per hour is 1.37 Lbs. per sq. ft. of heating surface, and it takes 3.5 horse power to drive the fan.

GENERAL DISCUSSION OF RESULTS OBTAINED.

We used the condensation method results for obtaining the velocity of the air thru the heater, because this method is supposed to be more accurate than the Pitot tube method. The velocity heads in this latter method should be multiplied by a coefficient to obtain the correct velocity heads, and this coefficient is difficult, if not impossible, to obtain accurately.

The system we used was not provided with air valves on the inlet side of the coils, so the results, in all probability, are affected by the coils becoming air-bound towards the latter part of each test. We let the steam blow thru the coils before we began each test, until we judged all the air was expelled, but during the test the air, coming over in the steam had no means for escape. This air settled in the bottom manifold and extended some distance up the pipes, air being heavier than steam.

In our tests we kept the coils as free from air as possible, yet we believe the small amount of condensation collected in the first two tests of runs C & D was due to air-binding. We can easily imagine the affect of this air-binding, and its consequent reduction of effective heating surface, in commercial installations where no attention is paid to the coils whatever.

The results of the condensation method must be also affected by the radiation of heat from the sheet iron casing of the heater and fan housing, and air leakage thru the casing. We could not determine nor estimate these losses, so we made no allowance for them.

There may, also, be some error from the evaporation of the collected condensation in the tanks during the test.

CONCLUSIONS.

We have found that the fan runs most efficiently at a speed of about 500 R.P.M. and consuming about 3.5 H.P. and delivering air at a velocity of 1000 ft. per min. These conclusions are drawn from curve sheet 6; which takes into consideration all friction losses.

From curve sheet A, we find that the pressure loss due to the coils varies directly as the number of sections, and approximately as the square of the air velocity. As the number of coils increase, the pressure drop comes to vary almost directly as the velocity. The velocity referred to is the velocity thru the heater.

Curve sheet D shows that the velocity drop caused by the friction of the coils, varies directly as the number of sections and directly as the fan speed.

Public buildings require air furnished at a velocity of about 1200 ft. per minute. Referring to table C, we find that the air supplied when the entire five sections are in the heater is 23% less than when the coils are all removed. Now, since the pressure loss varies directly as the number of sections in the heater, and approximately as the square of the air velocity thru the heater, we are able to derive a formula from the curves on curve sheet A-1.

$$p = 8nv^2$$

The general equation for the curves is $p = Bx^n$. (Kent pg. 35) or in logarithmic form; $\log y = \log B + \log x$, in which B represents intercept with the vertical axis, and "n" the slope. These curves are shown on curve sheet A-1, and we find that they are all straight lines from which we obtain:

$$n = 2 \quad B = .0000000018$$

The value of B is an average value for one four row section and is found to vary as the number of sections. Substituting in the original formula we obtain:

$$p = .0000000018nv^2.$$

p = pressure loss in inches of water.

n = number of sections.

v = air velocity thru heater in ft. per min.

If it is desired to find "p" in ounces per sq. inch the formula becomes:

$$p = .00000000356nv^2.$$

Mr. E.M. Shealy, in the Heating and Ventilating Magazine for Nov. 1911, obtains the following formula for a two row section:

$$p = .00000000nv^2.$$

p = ounces per sq. in.

The system upon which his tests were run consisted of two row sections 3 ft. high and 5 ft. wide, and the fan used was 43 inches in diameter, making it rather difficult to compare results.

From the results obtained in these tests, we are lead to believe, that in the installation of a heating system of this type, if the system is to give entire satisfaction, the friction loss due to the heater coils must be calculated and allowed for.

TESTS OF 5 No. 112 Hot Blast Coils. MICHIGAN STATE COLLEGE,
 TEST No. A-1. EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3". DATE 4-18-12.

TOTAL HEATING SURFACE 277.5 sq. ft. FROM 1:25 P.M. to 3:25 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	1:25	1:55	2:25	2:55	3:25	Av.
Barometer	28.72	28.72	28.74	28.75	28.75	28.73
Steam pressure in heater						5 Lbs.
Temp. of steam in heater						226
Temp. of entering air	38.2	38.5	37	37	37	37.3
Temp. of leaving air	110	109.5	107.5	107.5	107.5	108.5
Temp. rise						71.2
Temp. test room						89.1
R.P.M. of fan	764	766	770	771		767.75
R.P.M. of motor	772	775	778	778		775.75
Friction loss thru heater	.79	.78	.79	.80	.80	.703
Calorimeter readings	.072 Lbs. in 25'		.055 in 20'			

MANOMETER READINGS.

READINGS (In. of water.)

1.	.455	.465	.465
2.	.455	.465	.465
3.	.465	.480	.480
4.	.505	.505	.505
5.	.540	.530	.540
6.	.550	.550	.550
7.	.575	.575	.575
8.	.590	.590	.590
9.	.610	.610	.610
10.	.625	.625	.625
11.	.530	.565	.565
12.	.450	.450	.455

No. of section.

Condensation in Lbs. per hr.	1.	2.	3.	4.	5.	
	149.5	129.13	115.3	103.6	94.8	592.1
" per sq. ft. per hr.						2.14
Quality of steam	93.3%					
B.T.U. of steam used	909.6					
Wt. of cu. ft. of air in blast	.037119	Lbs.				
Velocity of air (ft. per min.) from Man. readings	2983'	Outlet pip				
Volume of air (cu. ft. per Min)	10178'	" "				
Equivalent velocity of air at 70 F. & 29.92 Hg.	2675'	Free area				
" volume under above conditions	9125'	" "				
Velocity thru heater from condensations	1499	" "				

TESTS OF 5 No. 112 Hot Blast Coils. MICHIGAN STATE COLLEGE,

TEST No. A-2.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3"

DATE 4-19-12.

TOTAL HEATING SURFACE 377.5 Sq. ft. FROM 1:40 P.M. to 3:40 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	1:40	2:10	2:40	3:10	3:40	Av.
Barometer	29.13	29.12	29.12	29.12	29.12	29.12
Steam pressure in heater						5 Lbs.
Temp. of steam in heater						226
Temp. of entering air	52	51.5	51.0	51.2	50.0	50.4
Temp. of leaving air	121	118	117.5	118	117.5	118.9
Temp. rise						68.5
Temp. test room						82.8
R.P.M. of fan	554	560	552	502	560	557.6
R.P.M. of motor	804	800	800	808	805	803.4
Friction loss thru heater	.474	.482	.48	.475	.48	.475
Calorimeter readings	.092 Lbs, in 20'			.09 Lbs. in 22'		
	.091 " " 22'			.09 " " 20'		

MANOMETER READINGS.

READINGS. (In. of water)

1.	.125	.130	.125
2.	.235	.240	.235
3.	.235	.245	.235
4.	.250	.255	.250
5.	.265	.275	.260
6.	.275	.280	.275
7.	.280	.280	.280
8.	.290	.300	.290
9.	.305	.310	.205
10.	.315	.315	.310
11.	.285	.285	.285
12.	.230	.230	.230

No. of sections.

Condensation in Lbs. per hr.	109.1	94.0	36.45	59.2	49.50	378.25
" per sq. ft. per hr.						1.37
Quality of steam	89.7%					B.T.U. of steam used 960.7
Wt. of cu. ft. of air in blast	.06673					Lbs.
Velocity of air (cu. ft. per min.) from Man. readings					2230'	Outlet
Volume of air (cu. ft. per min.)	B	B		B	7600	"
Equivalent velocity of air at 70 F & 29.92 Hg.					1986	Free area
" volume under above conditions					6775	" "
Velocity thru heater from condensation					1460	" "

TESTS OF 5 No. 112 Hot Blast Heating Sections.

TEST No. A-3.

MICHIGAN STATE COLLEGE,

LENGTH OF PIPES 3'6" & 3'3".

East Lansing, Mich.

TOTAL HEATING SURFACE 277.5 Sq. ft.

DATE 4-19-48.

FREE AREA THRU HEATER 5.47 " "

FROM 7:30 P.M. TO 9:30 P.M.

Time	7:30	8:00	8:30	9:00	9:30	Av.
Barometer	29.14	29.15	29.16	29.16	29.16	29.15
Steam pressure in heater						5 Lbs.
Temp. of steam in heater						226
Temp. of entering air	43	39.2	39.2	40.0	40.0	39.90
Temp. of leaving air	130	119.7	117.0	114.5	115.0	117.40
Temp. rise						74.50
Temp. test room						86.00
R.P.M. of fan	448	457	456	459	458	455.60
R.P.M. of motor	803	838	848	841	840	834.00
Friction loss thru heater	.333	.342	.344	.348	.344	.306
Calorimeter readings	.117 Lbs. in 21'			.039 Lbs. in 18'		
	.114 Lbs. in 25'			.095 Lbs. in 20'		

MANOMETER READINGS.

READINGS (In. of water)

1.	.145	.150	.150	.150
2.	.145	.150	.150	.150
3.	.155	.150	.150	.150
4.	.160	.155	.150	.150
5..	.170	.170	.170	.170
6.	.180	.180	.170	.180
7.	.185	.180	.180	.180
8.	.190	.185	.185	.185
9.	.195	.190	.190	.190
10.	.200	.200	.200	.200
11.	.170	.170	.170	.170
12.	.140	.140	.140	.140

No. of section.

	1	2	3	4	5	Total
Condensation in Lbs. per sq. in. per hr.	91.1	72.9	60.5	51.5	42.5	319.5
" per sq. ft. per hr.						4.1
Quality of Steam 88.7% E.T.U. of steam used	857.5					
Wt. of cu. ft. of air in blast	8073					
Velocity (ft. per min.) from Man. readings	1690					Outlet pipe
Volume of air (cu. ft. per min.)	5760					" "
Equivalent velocity of air at 70 F. & 29.92" Hg.	947					Free area
" volume under above conditions	5180					" "
Velocity thru heater from condensation	620					" "

TESTS OF 5 Hot Blast Heater Sections. MICHIGAN STATE COLLEGE,
 TEST No. A-4. EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3". DATE 4-19-12.

TOTAL HEATING SURFACE 277.5 Sq. ft. FROM 10:00 P.M. TO 11:30 P.M.

FREE AREA THRU HEATER 5.42 " "

Time	10:00	10:30	11:00	11:30	Av.
Barometer	29.16	29.16	29.16	29.16	29.16
Steam pressure in heater					5.00 Lbs.
Temp. of steam in heater					226.00
Temp. of entering air	36.50	36.80	35.50	36.00	36.10
Temp. of leaving air	118.00	116.00	116.00	116.00	116.70
Temp. rise					77.60
Temp. test room					86.80
R.P.M. of fan	353.00	352.00	353.00	353.00	353.00
R.P.M. of motor	857.00	857.00	859.00	854.00	856.75
Friction loss thru heater	.222	.222	.222	.222	.222
Calorimeter readings	.115 Lbs. in 22'		.965 Lbs. in 11'		
	.105 " " 26.5'				

MANOMETER READINGS.

READINGS 2In. of water)

1.	.07	.07	.07
2.	.07	.07	.07
3.	.07	.07	.07
4.	.08	.08	.08
5.	.08	.085	.085
6.	.085	.085	.085
7.	.085	.09	.09
8.	.09	.095	.095
9.	.095	.100	.100
10.	.100	.100	.100
11.	.095	.095	.095
12.	.075	.065	.065

No. of section.

	1.	2.	3.	4.	5.	Total
Condensation in Lbs. per hr.	73.27	71.80	69.15	48.90	40.40	293.52
" per sq. ft. per hr.						1.06
Quality of steam 88.6%						852
Wt. of air in blast per cu. ft.	.0373					
Velocity of air (cu. ft. per min.) from Man readings	1180	outlet				
Volume of air (cu. ft. per min.)	4025	"				
Equivalent velocity of air at 70 F. & 29.92" Hg.	661	free area				
" volume under above conditions	3619	"				
Velocity thru heater from condensation.	547	"				

TESTS OF 4 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,
 TEST No. B-1. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 4-25-12.
 TOTAL HEATING SURFACE 222 Sq. ft. FROM 9:15 A.M. TO 11:15 A.M.
 FREE AREA THRU HEATER 5.47 " "

Time	9:15	9:45	10:15	10:45	11:15	Av.
Barometer	29.47	29.42	29.42	29.42	29.42	29.42
Steam pressure in heater						5 Lbs.
Temp. of steam in heater						223.30
Temp. of entering air	57.00	58.20	60.00	60.00	60.00	57.90
Temp. of leaving air	105.00	105.00	106.20	105.00	105.00	102.60
Temp. rise						44.70
Temp. test room						77.00
R.P.M. of fan	738.00	761.00	765.00	761.00	760.00	753.00
R.P.M. of motor	752.00	773.00	771.00	772.00	773.00	768.00
Friction loss thru heater	.6	.63	.63	.62	.61	.574
Calorimeter readings,	.14 Lbs. in 16'		.13 Lbs. in 20'			
	.13 " " 20'		.035 " " 13'			

Manometer readings.

Readings (In. of water)

1.	.485	.485
2.	.485	.485
3.	.505	.505
4.	.530	.530
5.	.580	.580
6.	.600	.600
7.	.625	.625
8.	.650	.650
9.	.670	.670
10.	.615	.615
11.	.505	.505
12.	.505	.505

No. of section.

	1.	2.	3.	4.	Total
Condensation in Lbs. per hr.	149.75	129.00	110.25	108.00	497.00
B per sq. ft. per hr.					2.24
Quality of steam	85.05				
B.T.U. of steam used				813	
Wt. of cu. ft. of air in blast	.06937				
Velocity of air (ft. per min.)	X from Man. readings				3100 Outlet
Volume of air (cu. ft. per min.)	" "				1056 "
Equivalent velocity of air at 70 F. & 29.92" Hg.					1786 Free &
" volume under above conditions					919 "
Velocity thru heater from condensation					1515 "

TESTS OF 4 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

Test No. B-2.

EAST LANSING, MICH.

LENGTH OF PIPES. 3'6" & 3'3".

DATE 4-25-12.

TOTAL HEATING SURFACE 222 sq. ft.

FROM 12:45 O.P.M. TO 2:45 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	12:45	1:15	1:45	2:15	Av.
Barometer	29.40	29.40	29.37	29.36	29.38
Steam pressure in heater					5.00 Lbs.
Temp. of steam in heater					226.50
Temp. of entering air	65.20	63.00	65.00	64.60	63.50
Temp. of leaving air	116.00	115.60	116.00		115.80
Temp. of rise					49.70
Temp. test room					81.70
R.P.M. of fan	570.00	573.00	570.00	571.00	571.00
R.P.M. of motor	822.00	827.00	822.00	822.00	823.00
Friction loss thru heater	.42	.374	.42	.40	.359
Calorimeter readings	.16 Lbs. in 20'	.092 " " 17'		.11 Lbs. in 20'	

MANOMETER READINGS.

READINGS (In. of water)

1.	.260	.260
2.	.260	.260
3.	.270	.270
4.	.280	.280
5.	.300	.300
6.	.315	.315
7.	.325	.325
8.	.335	.335
9.	.345	.345
10.	.355	.355
11.	.325	.310
12.	.255	.255

	No. of section				Total
	1.	2.	3.	4.	
Condensation in Lbs. per hr.	130.2	108.5	86.3	79.7	404.7
" per sq. ft. per hr.					1.83
Quality of steam	87.3%	B.T.U. of steam used			842
Wt. of cu. ft. of air in blast	.0671				
Velocity of air (ft. per min.) from Man readings				2300	Outlet Pipe
Volume of air (cu. ft. per min.) " " "				7850	" "
Equivalent velocity of air at 70 F. & 29.92" Hg.				2090	Free Area
" volume under above conditions				7125	" "
Velocity thru heater from condensation				2132	" "

Tests of 4 Hot Blast Heating Sections. Michigan State College,
 Test No. B-3. East Lansing, Mich.
 Length of Pipes 3'6" & 3'3". Date 4-25-12.
 Total Heating Surface 222 Sq. ft. From 2:32 P.M. To 4:02 P.M.
 Free Area Thru Heater 5.47 " "

Time	2:32	3:02	3:32	4:02	Av. Cor.
Barometer	29.35	29.34	29.34	29.34	29.34
Steam pressure in heater					5.00 Lbs,
Temp. of steam in heater					226.5
Temp. of entering air	64	65	64	63	63.4
Temp. of leaving air	120.5	120	118	117.5	116.2
Temp. rise					53.1
Temp. of test room					85.5
R.P.M. of fan	443	453	457	454	452
R.P.M. of motor	383	840	359	851	843
Friction loss thru heater	.276	.280	.278	.282	.252
Calorimeter readings	.12 Lbs. in 24'				.13 Lbs. in 24'

Manometer readings.

Readings (In. of water)

	1.	2.	3.	4.
1.	.150	.155	.155	
2.	.150	.155	.155	
3.	.155	.160	.160	
4.	.165	.170	.170	
5.	.175	.180	.180	
6.	.180	.185	.185	
7.	.190	.195	.195	
8.	.195	.200	.200	
9.	.200	.205	.205	
10.	.205	.210	.210	
11.	.130	.135	.135	
12.	.150	.155	.155	

No. of section.

	1.	2.	3.	4.	5. Total
Condensation in Lbs. per hr.	115.3	88.5	72.4	61.3	337.5
B per Sq.ft per hr.					4.58
Quality of steam 83.4%	B.T.U. of steam used 849				
Wt. of cu. ft. of air in blast	.03747				
Velocity of air (ft. per Min.) from Man. readings	1740				Outlet Pipes.
Volume of air cu. ft. per Min	5940				" "
Equivalent velocity of air at 70 F. & 29.92" Hg.	1570				Free area.
" volume under above conditions	5350				" "
Velocity thru heater from condensation	931				" "

TESTS OF 4 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

TEST NO. B-4.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3"

DATE 4-26-12.

TOTAL HEATING SURFACE 222 sq. ft.

FROM 2:00 P.M. TO 3:00 P.M.

FREE AREA THRU HEATER 5.47 sq. ft.

Time	2:00	2:30	3:00	3:30	Av. Cor.
Barometer	28.6	28.70	28.79	28.70	28.70
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					225.9
Temp. of entering air	73	72	71.6	70.3	70.8
Temp. of leaving air	127.5	126.2	126.5	126	123.3
Temp. rise					52.3
Temp. of testroom.					61.8
R.P.M. of fan	336	333	342	330	333
R.P.M. of motor	813	833	831	793	819
Friction loss thru heater	.133	.134	.133	.133	.112
Calorimeter readings	.045 Lbs. in 20'		.075 Lbs. in 21'		

MANOMETER READINGS.

READINGS. (IN. of water)

1.	.08	.07	.07
2.	.08	.07	.07
3.	.08	.07	.07
4.	.085	.075	.075
5.	.090	.085	.080
6.	.100	.090	.085
7.	.105	.095	.085
8.	.115	.105	.095
9.	.110	.100	.100
10.	.115	.100	.095
11.	.085	.100	.090
12.	.085	.075	.070

No. of sections.

	1.	2.	3.	4.	Total
Condensation in Lbs. per hr.	102.3	73.5	55.3	44.3	275.4
" per sq. ft per hr.					1.24

Quality of steam 93.1% B.T.U. of steam used 895

Wt. of cu. ft. of air in blast .0334

Velocity of air (ft. per min.) from Man. readings 1222 Outlet Pipe.

Volume of air (cu. ft. per min.) " " " 4170 B B

Equivalent velocity of air at 70 F. & 29.92 B Hg. 1570 Free area

" volume under above conditions 3632 B B

Velocity thru heater from condensation 890 " "

TESTS OF 3 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

TEST NO. C-1.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3".

DATE 4-29-12.

TOTAL HEATING SURFACE 166.5 Sq. ft.

FROM 3:43 P.M. TO 5:13 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	3:43	4:13	4:43	5:13	Av, Cor.
Barometer	28.87	28.88	28.88	28.88	28.88
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	49.3	48.3	48	48	47.7
Temp. of leaving air	88	85	85	85	84.6
Temp. rise					36.9
Temp. of test room					79
R.P.M. of fan	756	780	781	780	774
R.P.M. of motor	766	787	790	789	783
Friction loss thru heater	.45	.46	.48	.47	.438
Calorimeter readings	.152 Lbs. in 29'		.943 Lbs. in 8'		
	.085 Lbs. in 20'				

MANOMETER READINGS.

READINGS (IN. of water)

1.	.435	.455	.435
2.	.435	.455	.435
3.	.460	.465	.445
4.	.480	.500	.480
5.	.525	.525	.520
6.	.550	.555	.545
7.	.575	.590	.575
8.	.600	.620	.600
9.	.635	.645	.630
10.	.650	.660	.665
11.	.610	.615	.605
12.	.510	.515	.500

Np. of section.

	1.	2.	3.	Total
Condensation in Lbs. per hr.	99.7	130.3	124.8	354.8
" per sq. ft. per hr.				2.14

Quality of steam 83.75% B.T.U. of steam used 852

Wt. of cu. ft. of air in blast .0705

Velocity of air (ft. per min.) from Man. readings 3055 Outlet Pipe

Volume of air (cu. ft. per Min.) B " " 10410 " "

Equivalent velocity of air at 70 F & 29.9 in. Hg. 1793 Free Area

" volume under above conditions 6820 " "

Velocity thru heater from condensation 1468 " "

TESTS OF 3 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

TEST NO. C-2.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3".

DATE 4-30-12.

TOTAL HEATING SURFACE 166.5 Sq. ft.

FROM 1:00 P.M. TO 2:00 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	1:00	1:30	2:00	2:30	Av. Cor.
Barometer	29.14	29.14	29.14	29.14	29.14
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	62	61	63	63	61.1
Temp. of leaving air	97	95	97	95	94
Temp. rise					32.9
Temp. of test room					84.1
R.P.M. of fan	510	558	570	572	567
R.P.M. of motor	813	802	816	821	813
Friction loss thru heater	.315	.298	.305	.31	.286
Calorimeter readings	.145 Lbs. in 24'		.105 Lbs. in 33'		
	.06 Lbs. in 33'				

MANOMETER READINGS.

READINGS (In. of water)

1.	.230	.235	.230
2.	.230	.235	.230
3.	.230	.235	.230
4.	.250	.240	.250
5.	.265	.255	.265
6.	.275	.265	.270
7.	.300	.290	.290
8.	.310	.300	.300
9.	.325	.310	.320
10.	.300	.290	.300
11.	.330	.320	.325
12.	.250	.250	.250

No. of section.

	1.	2.	3.	Total
Condensation in Lbs. per hr.	100.8	109.1	81.5	291.4
" per Sq. ft. per hr.				1.75
Quality of steam	91.4%			
B.T.U. of steam used	878			
Wt. of cu. fr. of air in blast	.0698			
Velocity of air (ft. per Min.) from Man. readings	2150	Outlet Pipe.		
Volume of air (cu. ft. per Min.)	7330	" "		
Equivalent velocity of air at 70 F. & 29.92" Hg.	2000	Free Area		
" volume under above conditions	6820	" "		
Velocity thru heater from condensation	1411	" "		

TESTS OF 3 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

TEST NO. C-3.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3".

DATE 4-30-12.

TOTAL HEATING SURFACE 166.5 Sq. ft.

FROM 8:55 A.M. TO 10:25 A.M.

FREE AREA THRU HEATER 5.47 " "

Time	8:55	9:25	9:55	10:25	Av. Cor.
Barometer	29.12	29.14	29.14	29.14	29.14
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	51	52	55	55.5	52.6
Temp. of leaving air	99	92.5	101	101	97.5
Temp. rise					44.9
Temp. of test room					79.1
R.P.M. of fan	439	446	444	441	442
R.P.M. of motor	814	829	806	816	816
Friction loss thru heater	.178	.178	.177	.172	.185
Calorimeter readings	.155	Lbs. in 22'		.21	Lbs. in 23'
	.065	B	"	17'	

MANOMETER READINGS.

READINGS (In. of water)

1.	.130	.130	.125
2.	.130	.130	.125
3.	.130	.130	.125
4.	.140	.140	.135
5.	.155	.150	.145
6.	.160	.160	.155
7.	.170	.170	.165
8.	.180	.175	.170
9.	.185	.185	.180
10.	.190	.190	.185
11.	.175	.175	.170
12.	.140	.140	.135

No. of section

	1.	2.	3.	Total
Condensation in Lbs. per hr.	121	97.7	83.7	302.4
" per sq. ft. per hr.				1.81

Quality of steam 83.5% B.T.U. of steam used 802

Wt. of cu. ft. of air in blast .0693

Velocity of air (ft. per min.) from Man. readings 1615 Outlet pipe

Volume of air (cu. ft. per min.) B " " 5510 " "

Equivalent velocity of air at 70 F & 29.92" Hg. 930 Free area

" volume under above conditions 5090 " "

Velocity thru heater from condensation 1010 " "

TESTS OF 3 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,
 TEST NO& C-4. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3" DATE 4-30-12.
 TOTAL HEATING SURFACE 166.5 sq. ft. FROM 2:45 TO 4:15 P.M.
 FREE AREA THRU HEATER 5.47 " "

Time	2:45	3:15	3:45	4:15	Av. Cor.
Barometer	29.14	29.14	29.14	29.15	29.14
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					288
Temp. of entering air	61	62.5	61	60	60.1
Temp. of leaving air	110	108.5	107.5	106	105.5
Temp. rise					45.4
Temp. of test room					90.3
R.P.M. of fan	339	343	348	345	344
R.P.M. of motor	837	863	838	860	849
Friction loss thru heater	.115	.118	.118	.125	.1008
Calorimeter readings	.045 Lbs. in 27'				.04 Lbs. in 28'.

MANOMETER READINGS.

READINGS (In. of water)

1.	.077	.08
2.	.077	.08
3.	.079	.08
4.	.08	.09
5.	.088	.095
6.	.095	.095
7.	.100	.102
8.	.105	.107
9.	.110	.112
10.	.113	.115
11.	.100	.105
12.	.080	.080

No. of section.

	1.	2.	3.	Total
Condensation in Lbs. per hr.	105.5	76.7	56.3	238.5
" per sq. ft per hr.				1.43
Quality of steam	95.7%	B.T.U. of steam used	920	
Wt. of cu. ft. of air in blast	.0684			
Velocity of air (ft. per min.)	from Man. readings			1285 Outlet Pipe
Volume of air (cu.ft, per min,)	"	"	"	4480 " "
Equivalent velocity of air at 70 F. & 29.92" Hg.				1200 Free area
" volume under above conditions				4090 " "
Velocity thru heater from condensation				896 " "

TESTS OF 2 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,
EAST LANSING, MICH.
TESTNO. D-1. DATE 5-1-12.
FROM 12:25 TO 1:55 P.M.

LENGTH OF PIPES 3'6" & 3'3".

TOTAL HEATING SURFACE 111 sq. ft.

FREE AREA THRU HEATER 5.47 sq. ft.

Time	12:25	12:55	1:25	1:55	Av, Cor.
Barometer	29.09	29.085	29.08	29.08	19.08
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	51	51.5	51.5	51.5	50.8
Temp. of leaving air	71	71.5	71.8	71.8	70.6
Temp. rise					19.7
Temp. of test room					71.5
R.P.M. of fan	769	765	769	769	767
R.P.M. of motor	772	771	777	777	775
Friction loss thru heater	.373	.373	.38		.366
Calorimeter readings	.065 Lbs. in 25'			.05 Lbs. in 22'	

MANOMETER READINGS.

READINGS (8n. of water)

1.	.460	.430	.430
2.	.460	.430	.430
3.	.470	.450	.455
4.	.505	.475	.485
5.	.550	.530	.525
6.	.580	.550	.555
7.	.600	.585	.600
8.	.650	.630	.640
9.	.690	.665	.655
10.	.705	.670	.675
11.	.660	.630	.630
12.	.550	.540	.540

No. of section.

	1.	2.	Total	
Condensation in Lba. per hr.	104.2	112.2	216.4	
" per sq. ft per hr.			1.95	
Quality of steam 94% B.T.U. of steam used 904				
Wt. of cu. ft. of air in blast .0728				
Velocity of air (ft. per min.) from Man. readings			3015	Outlet pipe
Volume of air (cu. ft. per min.) " " "			10280	" "
Equivalent velocity of air at 70 F & 29.92" Hg.			1825	Free area
" volume under above conditions			9990	" "
Velocity thru heater from condensation			1730	" "

TESTS OF 2 Hot Blast Heater Sections. MICHIGAN STATE COLLEGE,
 TEST NO. D-2. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-1-12.
 TOTAL HEATING SURFACE 111 sq. ft. FROM 2:05 P.M. TO 3:35 P.M.
 FREE AREA THRU HEATER 5.47 " "

Time	2:05	2:35	3:05	3:35	Av. Cor.
Barometer	29.08	19.075	19.07	19.07	29.075
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	52	54	53.5	54	52.4
Temp. of leaving air	72.5	75	75	75.5	73.9
Temp. rise					21.5
Temp. of test room					74.7
R.P.M. of fan	568	568	587	574	574
R.P.M. of motor	812	820	825	826	816
Friction loss thru heater	.217	.22	.23	.23	.214
Calorimeter readings	.0575 Lbs. in 33'			.0425 Lbs. in 19'	

MANOMETER READINGS.

READINGS (In. of water)

1.	.238	.238	.285	.270
2.	.238	.238	.285	.270
3.	.240	.250	.285	.270
4.	.255	.165	.308	.300
5.	.282	.290	.325	.315
6.	.300	.305	.350	.325
7.	.318	.225	.365	.350
8.	.335	.340	.380	.365
9.	.345	.350	.390	.390
10.	.350	.365	.405	.395
11.	.335	.335	.385	.370
12.	.285	.288	.325	.315

No. of section.

Condensation in Lbs. per hr.	85.3	98.7	184
" per sq. ft. per hr.			1.63
Wt. of cu. ft. of air in blast	.0723		
Velocity of air (ft. per min.) from Man. readings	2390	Outlet Pipe	
Volume of air (cu. ft. per min.)	8160	" "	
Equivalent velocity of air at 70 F & 29.92" Hg.	1440	Free area	
" volume under above conditions	7860	" "	
Velocity thru heater from condensation	1178	" "	

TESTS OF 2 Hot Vlast Heating Coils. MICHIGAN STATE COLLEGE,
 TEST NO. D-3. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-2-12.
 TOTAL HEATING SURFACE 111 sq. ft. FROM 8:38 A.M. TO 10:08 A.M.
 FREE AREA THRU HEATER 5.47 " "

Time	8:38	9:08	9:38	10:08	Av. Cor.
Barometer	29.145	29.16	19.18	19.18	19.18
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	64	64	64	65	63.2
Temp. of leaving air	94.2	94.5	94	94.5	92.5
Temp. rise					29.3
Temp. of test room					78.4
R.P.M. of fan	438	441	442	442	441
R.P.M. of motor	818	813	824	823	819
Friction loss thru heater	.13	.123	.128	.128	.119
Calorimeter readings	.08 Lbs. in	32'	.025 Lbs. in	16'	

MANOMETER READINGS.

READINGS (In. of water)

1.	.155	.1555	.155
2.	.155	.155	.155
3.	.160	.160	.160
4.	.172	.170	.170
5.	.185	.185	.185
6.	.192	.195	.195
7.	.205	.205	.207
8.	.208	.213	.215
9.	.220	.222	.225
10.	.225	.227	.228
11.	.225	.210	.210
12.	.170	.178	.180

No. of section.

	1.	2.	Total
Condensation in Lbs. per hr.	117.7	104	22.7
" per sq. ft. per hr.			2.99

Quality of steam 95% B.T.U. of steam used 914

Wt. of cu. ft. of air in blast .00993

Velocity of air (ft. per min.) from Man. readings 1790 Outlet Pipe

Volume of air (cu. ft. per min.) " " 4700 " "

Equivalent velocity of air at 70°F & 29.92" Hg 1045 Free Area

" volume under above conditions 5720 " "

Velocity thru heater from condensation 1257 " "

TESTS OF 2 Hot Blast Heating Coils. MICHIGAN STATE COLLEGE,
 TEST NO. D-4. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-2-12.
 FREE AREA THRU HEATER 5;47 Sq. Ft. FROM 10:13 A.M. TO 11:31 A.M.
 TOTAL HEATING SURFACE 111 " "

Time	10:13	10:43	11:13	11:31	Av. Cor.
Barometer	29.18	29.18	29.18	29.18	29.18
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					223
Temp. of entering air	65	66	67	67	66
Temp. of leaving air	99.5	100	100.8	100.6	99
Temp. rise					33
Temp. of test room					84.5
R.P.M. of fan	340	342	342	343	342
R.P.M. of motor	832	834	834	836	834
Friction loss thru heater	.09	.092	.088	.09	.0835
Calorimeter readings	.015 Lbs. in 22'			.035 Lbs. in 31'	
	.035 "	"	15'		

MANOMETER READINGS.

READINGS (In. of water)

1.	.0890	.090	.090
2.	.092	.092	.092
3.	.095	.095	.095
4.	.100	.100	.100
5.	.110	.110	.105
6.	.115	.115	.112
7.	.125	.120	.118
8.	.130	.123	.25
9.	.132	.132	.130
10.	.135	.135	.130
11.	.125	.125	.125
12.	.105	.105	.105

No. of section.

	1.	2.	Total
Condensation in lbs. per hr.	83	62	145
" per sq. ft per hr.			1.31
Quality of steam 93.4% B.T.U. of steam used			930
Wt. of cu. ft. of air in blast	.0394		
Velocity of air (ft. per min.) from Man. readings	1378	Outlet pipe	
Volume of air (cu. ft. per min.) " " "	4700	" "	
Equivalent velocity of air at 70 F. & 29.92" Hg.	797	Free Area	
" volume under above conditions	4360	" "	
Velocity thru heater from condensation	748	" "	

TESTS OF 2 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

Test No. E-1. EAST LANSING, Mich.

LENGTH OF PIPES 3'6" & 3'3". DATE 5-4-12.

TOTAL HEATING SURFACE 55.5 Sq. ft. FROM 3:00 P.M. TO 4:30 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	3:00	3:30	4:00	4:30	Av. Cor.
Barometer	29.16	29.14	29.14	29.13	29.14
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	75	73	72	72	71
Temp. of leaving air	85	84	83.2	82.5	82.4
Temp. of test room					11.4
R.P.M. of fan					82.4
R.P.M. of motor	773	779	775	774	775
Friction loss thru heater	778	784	785	788	784
Calorimeter readings	.235	.238	.235	.233	.224
	.055 Lbs. in 22'		.015 Lbs. in 15'		

Manometer Readings.

Readings. (In. of water)

1.	.480	.505	.480
2.	.480	.505	.480
3.	.510	.505	.480
4.	.535	.550	.510
5.	.585	.600	.560
6.	.620	.620	.698
7.	.670	.670	.625
8.	.700	.705	.685
9.	.735	.745	.710
10.	.760	.770	.745
11.	.745	.730	.705
12.	.615	.620	.610

No. of section,

	1.	Total	
Condensation in Lbs. per hr.	107.8	107.8	
" per sq. ft. per hr.		1.94	
Quality of steam 95.3% B.T.U. of steam used		920	
Wt. of cu. ft. of air in blast	.0713		
Velocity of air (ft. per min.) from Man readings		3204	Outlet pipe
Volume of air (cu. ft. per min.) B " "		10920	" "
Equivalent velocity of air at 70 F & 29.92" Hg.		1893	Free Area
" volume under above conditions		1293	B "
Velocity thru heater from condensation		1547	" "

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,
 TEST NO. E-2. EAST LANSING , MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-3-12.
 TOTAL HEATING SURFACE 55.5 Sq. ft. FROM 8:16 TO 9:46 A.M.
 FREE AREA THRU HEATER 5.47 B "

Time	8:16	8:46	9:16	9:46	Av. Cor.
Batometer	29.25	29.25	29.24	29.22	29.24
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	57.5	59	60	65	59.3
Temp. of leaving air	71.5	73	73.8	76	73.2
Temp. rise					13.9
Temp. of test room					73.8
R.P.M. of fan	544	555	561	560	555
R.P.M. of motor	795	800	802	808	801
Friction loss thru heater	.126	.125	.128	.127	.115
Colorimeter readings	Calorimeter showed no reading,				

MANOMETER READINGS.

READINGS (In. of water)

1.	.238	.260	.255
2.	.238	.262	.250
3.	.245	.262	.255
4.	.255	.285	.275
5.	.290	.305	.298
6.	.300	.325	.320
7.	.320	.345	.335
8.	.350	.385	.360
9.	.365	.395	.380
10.	.380	.400	.390
11.	.360	.385	.360
12.	.395	.325	.310

Condensation in #bs. per hr. 109

" per sq.ft. per hr. 1.97

Quality of steam 96.8% B.T.U. of steam used 930

Wt. of cu. ft. of air in blast .0728

Velocity of air (ft.per min.) from Man readings 2251 Outlet Pipes.

Volume of air (cu. ft. per min.) " " 7670 " "

Equivalent velocity of air at 70 F & 29.22" Hg. 1270 Free Area

" volume under above conditions 9610 " "

Velocity thru heater from condensation 1275 " "

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,

TEST NO. E-3.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'0".

DATE 5-3-12.

TPTAL HEATING SURFACE 55.5 Sq. ft. FROM 9:52 A.M. TO 11:22 A.M.

Time	9:52	10:22	10:52	11:22	Av. Cor.
Barometer	29.21	29.205	29.195	29.13	29.19
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	63.5	67	68	68	66.2
Temp. of leaving air	80	80	81	81	79
Temp. rise					12.8
Temp. of test room					30.1
R.P.M. of fan	440	440	452	452	447
R.P.M. of motor	323	321	329	331	326
Friction loss thru heater	.035	.023	.083	.085	.0805
Calorimeter readings	.04 Lbs. in 19'		.04 Lbs. in 30'		
	.04	"	" 30'		

MANOMETER READINGS.

READINGS (In. of water)

1.	.155	.165	.160
2.	.155	.165	.158
3.	.165	.165	.162
4.	.175	.178	.178
5.	.185	.195	.192
6.	.195	.200	.200
7.	.213	.215	.210
8.	.220	.230	.225
9.	.235	.245	.230
10.	.240	.245	.245
11.	.230	.248	.240
12.	.195	.210	.205

Condensation in lbs. per hr. 81.4

" per sq. ft. per hr. 1.47

Quality of steam 96.6% B.T.U. of steam used 928

Wt. of cu. ft. of air in blast .07175

Velocity of air (ft. per min.) from Man readings 1345 Outlet Pipes.

Volume of air (cu. ft. per min.) B " " 6290 " "

Equivalent velocity of air at 70 F & 29.92" Hg. 1100 Free Area

" volume under above conditions 6020 " "

Velocity thru heater from condensation 1042 " "

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,

TEST NO. E-4.

EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'6".

DATE 5-3-12.

TOTAL HEATING SURFACE 55.5 Sq. ft.

FROM 12:30 P.M. TO 1:50 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	12:20	12:50	1:20	1:50	Av. Cor.
Barometer	29.18	29.17	29.165	29.16	29.17
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	70	71	72	72	70
Temp. of leaving air	83.5	83.2	84	84.8	82.5
Temp. rise					12.5
Temp. of test room					84.1
R.P.M. of fan	342	345	345	345	345
R.P.M. of motor	835	838	836	837	834
Fricrion loss thru heater	.052	.052	.052	.052	.0385
Calorimeter readings	.045 Lbs. in 20'		.045 Lbs. in 34'		
	.05 Lbs. in 16'				

MANOMETER READINGS.

READINGS (In. of water)

1.	.100	.090	.090
2.	.100	.090	.090
3.	.100	.093	.095
4.	.105	.098	.100
5.	.115	.107	.108
6.	.118	.115	.118
7.	.128	.122	.122
8.	.138	.130	.130
9.	.145	.140	.138
10.	.145	.140	.140
11.	.132	.135	.135
12.	.122	.117	.115

Condensation in Lbs. per hr. 72.6

" per sq.ft. per hr. 1.31

Quality of steam 94.5% B.T.U. of steam used 908

Wt. of cu. ft. of air in blast .07125

Velocity of air (ft. per min.) from Man readings 1416 Outlet Pipes.

Volume of air (cu. ft. per min.) " " " 4823 " "

Equivalent velocity of air at 70 F & 29.92" Hg. 838 Free area

" volume under above conditions 4800 " "

Velocity thru heater from condensation 940 " "

TESTS WITH HEATING SECTIONS REMOVED.

MICHIGAN STATE COLLEGE,

TEST NO. F-1.

EAST LANSING, MICH.

LENGTH OF PIPES

DATE 5-3-12.

Time 10.00 a.m.
Barometer 29.14

Temp. of entering air 80.5
Temp. of leaving air 73.6
Temp. pipe 80.7
Temp. of test room 78.1
R.P.M. of fan 341
R.P.M. of motor 887

Barometer readings.
Headings (In. of water)

1.	.500
2.	.500
3.	.500
4.	.520
5.	.560
6.	.600
7.	.650
8.	.725
9.	.780
10.	.840
11.	.820
12.	.705

Nt. of cu. ft. of air in blast .0725

Velocity of air (ft. per min.) from Man readings

Volume of air (cu. ft. per min.) " " "

Equivalent velocity of air at 29.92" Hg.

" volume under above conditions

3324 Outlet pipes

11360 " "

2013 Free area

11000 " "

TESTS WITH HEATING SECTIONS REMOVED.

MICHIGAN STATE COLLEGE,

TEST NO. F-2.

EAST LANSING, MICH.

DATE 5-3-12.

Time	Av, Cor.
Barometer	29.14
Temp. of entering air	70.5
Temp. of leaving air	72.5
Temp. rise	2.6
Temp. of test room	75.1
R.P.M. of fan	447
R.P.M. of motor	834

MANOMETER READINGS.

READINGS $\frac{1}{2}$ In. of water)

1.	.285
2.	.285
3.	.285
4.	.290
5.	.315
6.	.330
7.	.360
8.	.390
9.	.420
10.	.445
11.	.435
12.	.380

Wt. of cu. ft. of air in blast ,07275

Velocity of air (ft. per min.) from Man. readings

Volume of air (cu. ft. per min.) $\frac{1}{2}$ " "

Equivalent velocity of air at 70 F & 29.92" Hg.

" volume under above conditions

2508 Outlet Pipes

8550 " "

1514 Free area

3280 " "

TESTS OF 2 Hot Vlast Heating Coils. MICHIGAN STATE COLLEGE,
 TEST NO. D-3. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-2-12.
 TOTAL HEATING SURFACE 111 sq. ft. FROM 8:38 A.M. TO 10:08 A.M.
 FREE AREA THRU HEATER 5.47 " "

Time	8:38	9:08	9:38	10:08	Av. Cor.
Barometer	29.145	29.16	19.18	19.18	19.18
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	64	64	64	65	63.2
Temp. of leaving air	94.2	94.5	94	94.5	92.5
Temp. rise					29.3
Temp. of test room					78.4
R.P.M. of fan	438	441	442	442	441
R.P.M. of motor	818	813	824	823	819
Friction loss thru heater	.13	.123	.128	.128	.119
Calorimeter readings	.08 Lbs. in	32'	.025 Lbs. in	16'	

MANOMETER READINGS.

READINGS (In. of water)

1.	.155	.1555	.155
2.	.155	.155	.155
3.	.160	.160	.160
4.	.172	.170	.170
5.	.185	.185	.185
6.	.192	.195	.195
7.	.205	.205	.207
8.	.208	.213	.215
9.	.220	.220	.225
10.	.225	.227	.228
11.	.225	.210	.210
12.	.170	.178	.180

No. of section.

	1.	2.	Total
Condensation in Lbs. per hr.	117.7	104	22.7
" per sq. ft. per hr.			2.99

Quality of steam 95% B.T.U. of steam used 914

Wt. of cu. ft. of air in blast .00993

Velocity of air (ft. per min.) from Man. readings 1790 Outlet Pipe

Volume of air (cu. ft. per min.) " " 4730 " "

Equivalent velocity of air at 70F- & 29.92" Hg 1045 Free Area

" volume under above conditions 5725 " "

Velocity thru heater from condensation 1257 " "

TESTS OF 2 Hot Blast Heating Coils. MICHIGAN STATE COLLEGE,

TEST NO. D-4. EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'3". DATE 5-2-12.

FREE AREA THRU HEATER 5;47 Sq. Ft. FROM 10:16 A.M. TO 11:31 A.M.

TOTAL HEATING SURFACE 111 " "

Time	10:16	10:46	11:16	11:31	Av. Cor.
Barometer	29.18	29.18	29.18	29.18	29.18
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					223
Temp. of entering air	65	66	67	67	66
Temp. of leaving air	99.5	100	100.8	100.6	99
Temp. rise					33
Temp. of test room					84.5
R.P.M. of fan	340	342	342	343	342
R.P.M. of motor	832	834	834	836	834
Friction loss thru heater	.09	.092	.088	.09	.0835
Calorimeter readings	.015 Lbs. in 22'		.035 Lbs. in 31'		
	.035 "	" 15'			

MANOMETER READINGS.

READINGS (In. of water)

1.	.0980	.0980	.0980
2.	.0992	.0992	.0992
3.	.0995	.0995	.0995
4.	.1000	.1000	.1000
5.	.1100	.1100	.1050
6.	.1115	.1115	.1112
7.	.1250	.1230	.1150
8.	.1230	.1230	.1250
9.	.1320	.1320	.1300
10.	.1350	.1350	.1300
11.	.1250	.1250	.1250
12.	.1050	.1050	.1050

No. of section.

	1.	2.	Total
Condensation in lbs. per hr.	83	62	115
" per sq. ft per hr.			1.31

Quality of steam 93.4% B.T.U. of steam used 930

Wt. of cu. ft. of air in blast .0394

Velocity of air (ft. per min.) from Man. readings 1378 Outlet pipe

Volume of air (cu. ft. per min.) " " " 4700 " "

Equivalent velocity of air at 70 F. & 29.92" Hg. 797 Free Area

" volume under above conditions 4360 " "

Velocity thru heater from condensation 748 " "

TESTS OF 2 Hot Blast Heating Sections. MICHIGAN STATE COLLEGE,

Test No. E-1. EAST LANSING, Mich.

LENGTH OF PIPES 3'6" & 3'3". DATE 5-4-12.

TOTAL HEATING SURFACE 55.5 Sq. ft. FROM 3:00 P.M. TO 4:30 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	3:00	3:30	4:00	4:30	Av. Cor.
Barometer	29.16	29.14	29.14	29.13	29.14
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	73	73	72	72	71
Temp. of leaving air	85	84	83.2	82.5	82.4
Temp. of test room					11.4
R.P.M. of fan					82.4
R.P.M. of motor	773	779	775	774	775
Friction loss thru heater	778	784	785	788	784
Calorimeter readings	.235	.238	.235	.233	.224
	.055 Lbs. in 22'		.015 Lbs. in 15'		

Manometer Readings.

Readings. (In. of water)

1.	.480	.505	.480
2.	.480	.505	.480
3.	.510	.505	.480
4.	.535	.550	.510
5.	.585	.600	.580
6.	.620	.620	.608
7.	.670	.670	.625
8.	.700	.705	.685
9.	.735	.745	.710
10.	.760	.770	.745
11.	.745	.730	.705
12.	.615	.620	.610

No. of section,

	1.	Total	
Condensation in Lbs. per hr.	107.8	107.8	
" per sq. ft. per hr.		1.94	
Quality of steam 95.3% B.T.U. of steam used	920		
Wt. of cu. ft. of air in blast	.0713		
Velocity of air (ft. per min.) from Man readings	3204	Outlet pipe	
Volume of air (cu. ft. per min.)	10920	" "	
Equivalent velocity of air at 70 F & 29.92" Hg.	1893	Free Area	
" volume under above conditions	1293	" "	
Velocity thru heater from condensation	1547	" "	

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,
 TEST NO. E-2. EAST LANSING, MICH.
 LENGTH OF PIPES 3'6" & 3'3". DATE 5-3-12.
 TOTAL HEATING SURFACE 55.5 Sq. ft. FROM 8:16 TO 9:46 A.M.
 FREE AREA THRU HEATER 5.47 B "

Time	8:16	8:46	9:16	9:46	Av. Cor.
Batometer	29.25	29.25	29.24	29.22	29.24
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	57.5	59	60	64	59.3
Temp. of leaving air	71.5	73	73.8	76	73.2
Temp. rise					13.9
Temp. of test room					73.8
R.P.M. of fan	544	555	561	560	555
R.P.M. of motor	795	800	802	808	801
Friction loss thru heater	.126	.125	.128	.127	.115
Colorimeter readings	Calorimeter showed no reading,				

MANOMETER READINGS.

READINGS (In. of water)

1.	.238	.260	.255
2.	.238	.262	.250
3.	.245	.262	.255
4.	.255	.285	.275
5.	.290	.305	.298
6.	.300	.325	.320
7.	.320	.345	.335
8.	.350	.385	.360
9.	.365	.395	.380
10.	.380	.400	.390
11.	.360	.385	.360
12.	.395	.325	.310

Condensation in #bs. per hr. 109

" per sq.ft. per hr. 1.97

Quality of steam 96.8% B.T.U. of steam used 930

Wt. of cu. ft. of air in blast .0728

Velocity of air (ft. per min.) from Man readings 2251 Outlet Pipes.

Volume of air (cu. ft. per min.) " " " 7670 " "

Equivalent velocity of air at 70 F & 29.22" Hg. 1270 Free Area

" volume under above conditions 9610 " "

Velocity thru heater from condensation 1275 " "

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,
 TEST NO. E-3. EAST LANSING, MICH.

LENGTH OF PIPES 6'6" & 6'6". DATE 5-3-12.

TPTAL HEATING SURFACE 55.5 Sq. ft. FROM 9:52 A.M. TO 11:22 A.M.

Time	9:52	10:22	10:52	11:22	Av. Cor.
Barometer	29.21	29.205	29.195	29.13	29.19
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					223
Temp. of entering air	63.5	67	68	68	66.3
Temp. of leaving air	80	80	81	81	79
Temp. rise					12.6
Temp. of test room					60.1
R.P.M. of fan	440	443	452	452	447
R.P.M. of motor	323	321	329	331	325
Friction loss thru heater	.085	.083	.083	.085	.0805
Calorimeter readings	.04 Lbs. in 19'		.04 Lbs. in 30'		
	.04 "	"	30'		

MANOMETER READINGS.

READINGS (In. of water)

1.	.155	.165	.160
2.	.155	.165	.158
3.	.165	.165	.162
4.	.175	.178	.178
5.	.185	.195	.192
6.	.195	.200	.200
7.	.213	.215	.210
8.	.220	.230	.225
9.	.235	.245	.230
10.	.240	.245	.245
11.	.230	.248	.240
12.	.195	.210	.205

Condensation in lbs. per hr. 81.4

" per sq. ft. per hr. 1.47

Quality of steam 96.6% B.T.U. of steam used 926

Wt. of cu. ft. of air in blast .07175

Velocity of air (ft. per min.) from Man readings 1345 Outlet Pipes.

Volume of air (cu. ft. per min.) B " " 6290 " "

Equivalent velocity of air at 70 F & 29.92" Hg. 1100 Free Area

" volume under above conditions 6020 " "

Velocity thru heater from condensation 1042 " "

TESTS OF 1 Hot Blast Heating Section. MICHIGAN STATE COLLEGE,

TEST NO. E-4. EAST LANSING, MICH.

LENGTH OF PIPES 3'6" & 3'6". DATE 5-3-12.

TOTAL HEATING SURFACE 55.5 Sq. ft. FROM 12:20 P.M. TO 1:50 P.M.

FREE AREA THRU HEATER 5.47 " "

Time	12:20	12:50	1:20	1:50	Av. Cor.
Barometer	29.18	29.17	29.165	29.16	29.17
Steam pressure in heater					5 Lbs.
Temp. of steam in heater					226
Temp. of entering air	70	71	72	72	70
Temp. of leaving air	83.5	83.2	84	84.8	82.5
Temp. rise					12.5
Temp. of test room					84.1
R.P.M. of fan	342	345	345	345	345
R.P.M. of motor	835	838	836	837	834
Fricrion loss thru heater	.052	.052	.052	.052	.0385
Calorimeter readings	.045 Lbs. in 20'		.045 Lbs. in 34'		
	.05 Lbs. in 16'				

MANOMETER READINGS.

READINGS (In. of water)

1.	.100	.090	.090
2.	.100	.090	.090
3.	.100	.093	.095
4.	.105	.098	.100
5.	.115	.107	.108
6.	.118	.115	.118
7.	.128	.122	.122
8.	.138	.130	.130
9.	.145	.140	.138
10.	.145	.140	.140
110	.132	.135	.135
12.	.122	.117	.115

Condensation in Lbs. per hr. 72.6

" per sq.ft. per hr. 1.31

Quality of steam 94.5% B.T.U. of steam used 908

Wt. of cu. ft. of air in blast .97125

Velocity of air (ft. per min.) from Man readings 1416 Outlet Pipes.

Volume of air (cu. ft. per min.) " " " 4823 " "

Equivalent velccity of air at 70 F & 29.92" Hg. 838 Free area

" volume under above conditions 4800 " "

Velocity thru heater from condensation 940 " "

TESTS WITH HEATING SECTIONS REMOVED.

MICHIGAN STATE COLLEGE,

TEST NO. F-1.

EAST LANSING, MICH.

LENGTH OF PIPES

DATE 5-3-12.

Time 11.00 a.m.
Barometer 30.14

Temp. of entering air 39.5
Temp. of leaving air 73.6
Temp. rise 34.1
Temp. of test room 75.1
B.P.M. of fan 341
B.P.M. of motor 837

Manometer readings.
Headings (H₂O of water)

1.	.500
2.	.500
3.	.500
4.	.520
5.	.500
6.	.600
7.	.650
8.	.725
9.	.780
10.	.840
11.	.830
12.	.705

Wt. of cu. ft. of air in blast .0725

Velocity of air (ft. per min.) from Man readings

Volume of air (cu. ft. per min.) " " "

Equivalent velocity of air at 70 F & 29.92" Hg.

" volume under above conditions

3324 Outlet pipes

11362 " "

2013 Free area

11000 " "

TESTS WITH HEATING SECTIONS REMOVED.

MICHIGAN STATE COLLEGE,

TEST NO. F-2.

EAST LANSING, MICH.

DATE 5-3-12.

Time	Av, Cor.
Barometer	29.14
Temp. of entering air	70.5
Temp. of leaving air	72.5
Temp. rise	2.6
Temp. of test room	75.1
R.P.M. of fan	447
R.P.M. of motor	834

MANOMETER READINGS.

READINGS $\frac{1}{2}$ In. of water)

1.	.285
2.	.285
3.	.285
4.	.290
5.	.315
6.	.330
7.	.360
8.	.390
9.	.420
10.	.445
11.	.435
12.	.380

Wt. of cu. ft. of air in blast ,07275

Velocity of air (ft. per min.) from Man. readings

2508 Outlet Pipes

Volume of air (cu. ft. per min.) B " "

8550 " "

Equivalent velocity of air at 70 F & 29.92" Hg.

1514 Free area

" volume under above conditions

3280 " "

TESTS WITH HEATING SECTIONS REMOVED. MICHIGAN STATE COLLEGE,

TEST NO. F-3.

EAST LANSING, MICH.

DATE 5-3-12.

	Av. Cor.
Barometer	29.14
Temp. of entering air	69
Temp. of leaving air	72.3
Temp. rise	3.3
Temp. of test room	75.1
R.P.M. of fan	571
R.P.M. of motor.	821

MANOMETER READINGS.

READINGS (In. of water)

1.	.180
2.	.180
3.	.180
4.	.180
5.	.195
6.	.200
7.	.223
8.	.245
9.	.270
10.	.275
11.	.270
12.	.233

Wt. of cu. ft. of air in blast .0725

Velocity of air (ft. per min.) from Man readings 1955 Outlet pipe

Volume of air (cu. ft. per min.) B " " 6660 " "

Equivalent velocity of air at 70 F & 29.92" Hg 1180 Free area

" volume under above conditions 6450 " "

TESTS WITH HEATING SECTIONS REMOVED. MICHIGAN STATE COLLEGE,

TEST NO. F-4.

EAST LANSING, MICH.

DATE 5-3-12.

	Av, Cor.
Barometer	29.14
Temp. of entering air	68
Temp. of leaving air	71.5
Temp. rise	3.5
Temp. of test room	75.1
R.P.M. of fan	736
R.P.M. of motor	785

MANOMETER READINGS.

READINGS (In. of water)

1.	.105
2.	.105
3.	.105
4.	.105
5.	.110
6.	.113
7.	.130
8.	.142
9.	.150
10.	.162
11.	.162
12.	.135

Wt. of cu. ft. of air in blast .0725

Velocity of air (ft. per min.) from Man readings 1955 Outlet pipes

Volume of air (cu. ft. per min.) B " " 5350 " "

Equivalent velocity of air at 70 F & 29.92" Hg. 948 Free area

" volume under above conditions 5180 " "




TABLE B.

VELOCITY OF AIR IN FT.
PER MIN. FROM CONDENSATION
METHOD.

FRICTION LOSS IN IN. OF WATER

NUMBER OF COILS IN HEATER.

SRR	1.	2.	3.	4.	5.
800	.03	.055	.105	.153	.387
900	.048	.084	.147	.100	.450
1000	.072	.115	.185	.145	.516
1100	.100	.147	.225	.295	.590
1200	.135	.185	.27	.350	.675
1200	.16	.23	.315	.41	.74
1400	.2	.167	.37	.460	.805
1500	.24	.315	.55	.57	.87

TABLE C.

RELATION OF R.P.M. TO AIR VELOCITY THRU HEATER.

R.P.M.	NO. COILS	1 COIL	2 COILS	3 COILS	4 COILS	5 COILS
300	800	730	680	620	580	570
400	1080	1010	950	890	830	805
500	1350	1290	1230	1170	1100	1050
600	1630	1570	1505	1435	1360	1290
700	1900	1840	1780	1710	1630	1540

TABLE D.

DROP IN AIR VELOCITY THRU HEATER IN PER CENT CAUSED BY THE
COILS FOR DIFFERENT R.P.M. OF FAN.

R.P.M.	1 COIL	2 COILS	3 COILS	4 COILS	5 COILS
300	8.75%	15.00%	22.50%	17.50%	18.80%
400	6.50%	12.00%	17.60%	23.00%	25.50%
500	5.50%	8.90%	13.00%	18.50%	22.20%
600	3.68%	7.67%	11.93%	16.60%	20.85%
700	3.16%	6.33%	10.00%	14.20%	18.95%

FRICTION LOSS INCHES WATER

7

6

5

4

3

2

1

0

500

600

700

800

900

1000

1100

1200

1300

1400

1500

1600

Velocity thru Heater in Ft per Min. App Condensation.

$N_2 H_4$

RELATIVE FRICTION LOSS
IN HEATER

1 section

2 sections

3 sections

4 sections

5 sections

6 sections

700

600


500

Pressure loss in water layer



RELATION BETWEEN FRICTION LOSS
AND SPEED.

No B



FRICTION LOSS RELATIVE TO DEPTH OF SECTIONS

No 5

Pressure Loss in Inches Water

Depth of Sections in Hoofers


2

3

4

5

750 RPM F.M.
700 RPM F.M.
650 RPM F.M.
600 RPM F.M.
550 RPM F.M.
500 RPM F.M.
450 RPM F.M.
400 RPM F.M.
350 RPM F.M.



FA per Min

Velocity Thru Clear Area
From Condensation


RELATIVE CONDENSATION
PER SQ FOOT PER HOUR


No. F.

1 section in Heater
2 sections in Heater
3 sections in Heater
4 sections in Heater
5 sections in Heater
6 sections in Heater
(Condensation wrong)

.5

Condensation per sq ft per hour





FAN PERFORMANCE
No. 6.

R.P.M.

MICHIGAN STATE UNIVERSITY LIBRARIES



3 1293 03145 0053