

HARRY R. FRASER



108
587
THS

THESIS
Design & Cost of
Heating System
For Farm House
HARRY R. FRASER
M. A. C. 1910

THESIS

cop. 1

Heating - Estimates

**SUPPLEMENTARY
MATERIAL
IN BACK OF BOOK**

PLACE IN RETURN BOX to remove this checkout from your record.
TO AVOID FINES return on or before date due.
MAY BE RECALLED with earlier due date if requested.

DATE DUE	DATE DUE	DATE DUE
06-21-09		

--00_00--

111111

---000000,000000---

DESIGN AND REPAIRS OF GOLF OF
HAWAII AIRFIELD CIVIC'S ROAD, FOR
CLUB, FOR-REPAIRS AND REPAIRS

---000000,000000---

by

Larry L. Braser

---000000,000000---

HAWAIIAN AGRICULTURAL COLLEGE

-00/1111/0-

--00_00--

THESIS

cop. 1



Alfred Clifford's Farm Residence,
Flint Township,
Flint, Michigan.

96319

OBJECT OF THESIS

The object of this thesis is to design and estimate the cost of installation and operation, separately, of steam, hot-water, and hot-air systems for heating the farm house of Alfred Gifford, located near Flint, Michigan.

DESCRIPTION OF HOUSE

The house is located about five miles west of Flint in Flint Township. It is a frame house, built about thirty-five years ago. During the summer and fall of 1907 the house was remodeled at an expense of about two thousand five hundred dollars (\$2500.00). A new roof was put on and the interior of the house completely changed, all the old lumber was used again, thus reducing the cost of remodeling. There is a cellar under all of the house except the kitchen, the walls are made of stone and eighteen inches in thickness. The walls of the house are built as follows: The studdings are 2"x6" with an inch sheathing next to the studding, then building paper with a matched sheathing over the paper, then clapboarded on the outside. The inside is lathed and plastered. All inside partitions are six inches thick with lath and plaster on both sides, except where it has been necessary to make the partitions thicker to keep the walls straight, as shown on the drawings. The first floor is all double-floored while the second is single-floored.

On the second floor are two tanks, one for hard water, the other for soft water. The hard water is pumped through the house to the barn by a windmill, while the soft water is pumped up by hand. The tanks being on the second floor give a gravity circulation of the water to the kitchen, bath-room, and cellar. The water for the bath-room is heated by a water-front in the litchen range.

The house is lighted by acetylene gas, the gas apparatus being enclosed in a small room in the cellar. The plumbing and fixtures for the gas and water, together, cost about two hundred and sixty dollars (\$260.00).

In the above costs no allowance is made for work done by Mr. Gifford or his men, nor is any allowance made for the boarding of the workmen: all the work being done by day's work.

HEATING SYSTEM OF HEATING

The house is heated by means of a Laminular furnace with 5.2 square feet of grate surface as follows: All rooms down stairs except the kitchen are heated from the furnace, the kitchen being heated by a steel range. The bedrooms marked "A" and "B" upstairs are heated direct from the furnace. Bedroom marked "C" is heated by means of a floor register from the sitting room directly below it. The bedroom marked "D" and the tank room are heated from the hall and the rooms below. In the fall and spring when the furnace is not running the sitting room is heated by a fire place.

Computation of Heat Losses

Constants used for heat losses	K
Windows	1.03
Outside walls, plastered, double sheathing, paper and clapboarded.	.18
Partitions, both sides plastered	.34
Ceilings, plastered	.62
Ordinary doors	.41
Ceiling single floor above, second floor	.45
Floor over cellar, double	.81

Allowance for Leakage

$$\text{Formula } L = \frac{NC}{30}(t_m - t_o)$$

L is the allowance for leakage in B.T.U. per hour.

N is the number of times air is changed per hour, taken
as 1½ in this case.

C is the contents of room in cubic feet.

t_m is the mean room temperature.

t_o is the outdoor temperature.

Bed Room "A"
Contents 1027 cubic feet

No.	amp.	Surf.	Dimensions	Area sq.ft.	$t_1 - t_0$ deg.F	$K(t_1 - t_0)$	B.T.U.	Total B.T.U.
1	W	Fin.	21"x32"	12	60	1.03	61.8	742.
2	W	Coil	9"x16.8-12	15.5	60	.18	10.8	1474
3	N	Fin.	2--21"x32"	21	60	1.03	61.8	1464
4	N	Coil	9"x17"-24	127.75	60	.18	10.8	<u>1466</u> 5163
			10% Allowance for N. and W. exposure					517
5	E	Coil	9"x1.5	49.5	60	.18	10.8	535 565
6		Coil.	8"x2.25	243.25	25	.62	11.5	3770 <u>3770</u>
			17 sq. ft.		... off.			
7		Single wall losses						99.8
8		Allowance for leakage by formula						5.17
9		Allowance for exposed location 25% of 7 and 8						<u>12.26</u>
10		B. T. U. required for continuous service						16631

Bed Room "B"
Contents 1623 cubic feet

No.	Exp. Surf.	Dimensions	Area sq. ft.	$t_1 - t_0$ deg. F	K	$K(t_1 - t_0)$	B. I. U.	Total
1	W. Lin	18"x102"	18	60	1.08	61.6	742	
2	W. Wall	9"x11-12	87	60	.18	10.8	940	1022
	10% Allowance for heat exposure							
3	S. Lin.	28"x102"	12	60	1.08	61.6	742	
4	S. Wall	9"x17-12	147	60	.18	10.8	<u>1896</u>	2918
5	" Wall	9"x6'	54	10	.34	3.4		199
6	Coil	7.75"x2.25' 17"x10.5'	196	28	.62	15.5		2017
7	Single wall losses							7415
8	Allowance for leakage by formula							2672
9	Allowance for exposed location 25% 7 and 8							<u>2154</u>
10	B. I. U. required for continuous service							12681

Box No. 1 "C"
Contents 1217 cubic feet

No.	Comp.	Surf.	Dimensions	Area sq.ft.	t ₁ -t ₀ deg.F	K	K(t ₁ -t ₀)	B.T.U.	Total
1	N	Win.	24"x32"	12	60	1.03	61.8	742	
2	N	Win.	24"x30"	8.8	60	1.03	61.8	556	
3	N	Wall	20'x9'-18	102	60	.18	10.8	<u>355</u>	2650
			10% Allowance for north exposure						285
4	N	Win.	24"x32"	12	60	1.03	61.8	742	
5	N	Wall	8.5'x9'-18	84.5	60	.18	10.8	696	1418
6		Cell.	10.5'x11.8'÷ 8.5'x27.75'	102	1.67 25	.62	15.5	<u>3121</u>	
7			Single wall leaves						7394
8			Allowance for leakage by formula						2488
9			Allowance for exposed location 25, 7 and 8						<u>3463</u>
10			B. T. U. required for continuous service						12045

Red Room "B"
Contents 11.6 cubic feet

No.	Exp. Surf.	Dimensions	Area sq. ft.	t ₁ -t ₀ deg. F	K	K(t ₁ -t ₀)	B.T.U.	Total
1	Fin.	28"x18"	11.8	10	1.03	11.5	132	
2	Wall	18'x9'-11.5'	16.7	50	.18	9.	870	1452
3	Fin.	26"x70"	12.6	50	1.03	11.5	669	
4	Wall	16.5'x9'-18.6'	142.9	50	.18	9.	1283	1832
5	Door	8'.10"x3'	11.7	10	.41	4.15	72	
6	Wall	6'x5.5'	33	15	.34	4.5	150	202
7	Coil.	16'x11.5'	184	15	.62	9.3		<u>1711</u>
8	Single wall losses							5257
9	Allowance for leakage by formula							1000
10	Allowance for exposed location 25%, 7 and 8							<u>1887</u>
11	B. T. U. required for continuous service							9184

Dining Room
Contents 1500 cubic feet

No.	Exp.	Surf.	Dimensions	Area sq.ft.	$t_1 - t_0$ deg. F.	K	$K(t_1 - t_0)$	B.T.U.	Total B.T.U.
1	W	Win.	36"x66"	16.6	70	1.05	72.1	1190	
2	W	Win.	2--36"x66"	25.6	70	1.03	72.1	1846	
3	W	Wall	7'x9.5' 6.8'x9.5'-42	66.25	70	.18	12.6	<u>1087</u>	4123
4	W	Door	6'x8"x36"	16.6	20	.41	8.2	156	
5	W	Wall	8.75'x9.5'-16.6	66.5	20	.34	6.8	412	500
6	W	Wall	7'x9.5'	66.5	70	.18	12.6		500
7		Ceiling	16'x11.25'	180	20	.45	9		1000
8		Floor	16'x11.25'	180	30	.31	9.3		<u>1074</u>
9		Simple wall losses							8000
10		Allowance for leakage by formula							5507
11		Allowance for exposed location 25, 9 and 10							<u>3012</u>
12		B. T. U. required for continuous service							15000

Bath Room
Contents 864 cubic feet

No.	Exp.	Surf.	Dimensions	Area sq.ft.	$t_1 - t_0$ deg. F.	K	$K(t_1 - t_0)$	B.T.U.	Total B.T.U.
1	W	Win.	20"x70"	11.6	70	1.05	72.1	983	
2	W	Wall	5.5'x9.5'-16.6	51.6	70	.18	12.6	<u>487</u>	1470
		10% allowance for wet exposure							147
3		Ceiling	11.25'x7'-4'x3'	66.75	20	.45	9		600
4		Floor	11.25'x7'-4'x3'	66.75	30	.31	9.3		<u>611</u>
5		Simple wall losses							2007
6		Allowance for leakage by formula							1115
7		Allowance for exposed location 25, 5 and 6							<u>912</u>
8		B. T. U. required for continuous service							4040

Kitchen

Contents 1810 cubic feet

No.	Exp. Surf.	Dimensions	Area sq. ft.	$t_1 - t_0$ deg. F	K	$K(t_1 - t_0)$	B. I. U.	Total B. I. U.
1	W	Win. 2--28"x70"	27.2	70	1.03	72.1	1061	
2	W	Wall 13.25'x9.5'-27.2	98.7	70	.18	12.6	<u>1244</u>	2305
10% Allowance for west exposure								
3	S	Floor 6'.10"x10"	17	70	.41	28.7	486	
4	S	Wall 17'x9.5'-17	144.5	70	.18	12.6	1820	2306
5	E	Glass 6'-10"x14"	6	70	1.03	72.1	433	
6	E	Floor 28"x12"-6	12.25	70	.41	28.7	222	
7	E	Wall 17'x9.5'-18.25	148.25	70	.18	12.6	1805	2309
8		Ceil 13.25'x13.75'	207	35	.62	21.7	4492	
9		Floor 13.25'x13.75'	207	30	.45	17.1	<u>3570</u>	
10	Single wall losses							16452
11	Allowance for leakage by formula							5415
12	Allowance for exposed location 25% 10 and 11							<u>4977</u>
13	B. I. U. required for continuous service							24887

Radiating Surface Needed, for Steam

Steam pressure in radiator 5 pounds per square inch.

Temperature of steam 227° F.

Temperature of room 70° F.

Difference in temperature between radiator and room 157° F.

Factor for heat lost from two column cast iron radiator 1.65

B. T. U. per degree difference in temperature per hour

$157 \times 1.65 = 259$ B. T. U. per square foot per hour.

Sq. Ft. Use

Bed room "A"	$16651 \div 259 = 64.5$	64
Bed room "B"	$12621 \div 259 = 48.5$	48
Bed room "C"	$12145 \div 259 = 47.5$	47
Bed room "D"	$9184 \div 259 = 35.5$	36
Bank room and hall	$3948 \div 259 = 15$	16
Barber	$17550 \div 259 = 68$	68
Bed room down stairs	$15324 \div 259 = 60$	60
Sitting room	$12290 \div 259 = 50$	60
Halls and vestibule	$14220 \div 259 = 55$	55
Dining room	$12082 \div 259 = 50$	60
Bath room	$4940 \div 259 = 19$	20
Kitchen	$24787 \div 259 = 95$	95

Total square feet of radiating surface $626 \frac{1}{2}$ 626 s. ft.

Size of Circulating Main for Steam.

Total B. T. U. supplied per hour 162,340

$162340 \div 966 = 168$ pounds steam circulated per hour.

$168 \times 20.25 = 3402$ cubic feet of steam per hour.

Allow a velocity of 20 feet per second in pipe.

$3402 \div 60 = 56.7$ cubic feet per minute.

$56.7 \div 60 = .945$ cubic feet per second

$(.945 \times 1728) \div (20 \times 12) = 6.8$ square inches of main area

$$d^2 \ 3.1416 = 6.8 \quad d^2 = \frac{6.8 \times 4}{3.1416} = 8.6$$

$d = 2.94$ inches in diameter use a 3 inch pipe.

Boiler, Pipe and Fittings for Steam

Ideal sectional boiler rated at 900 square feet

632 square feet of radiator surface, standard

38" cast iron radiators four square feet per section

4 - 1" and 4 - 1½" brass angle valves, with union

3 - 1½" and 1 - 1" brass globe valves. All valves are

to be rough body, plated all over.

165 feet 3 inch wrought iron pipe.

25 feet 2 inch " " "

65 feet 1½" " " "

35 feet 1" " " "

9 - 2" standard cast iron elbows, screwed.

4 - 1" and 6 - 1½" cast iron elbows, screwed.

2 reducing elbows from 2" to 1½"

4 " " " 1½" to 1"

3 " tees " 3" to 2"

5 " " " 3" to 1½"

3 " " " 1½" to 1"

1 " " " 1½" to 1"

15 Brass floor plates, nickel plated 6 - 1" and 7 - 1½"

5 patent two-piece ceiling plates 2 - 1½" and 3 - 1"

2 - 1" and 6 - 1½" wrought iron nipples

9 - 2" pipe hangers

12 radiator air valves
 90 feet of 3" pipe covering.
 33 feet of 2" pipe covering.
 18 feet of 1½" pipe covering.
 9 - 3" moulded elbow covers.
 8 - 3" moulded reducing tee covers.
 Pipe covering to be 15% magnesia.

Cost of Boiler, Pipe and Fittings for Steam.

Steel Sectional Boiler	\$148.00
632 square foot radiator surface	112.80
12 brass globe and angle valves	20.50
Brought iron pipe required	34.00
Cast iron elbows	5.00
Cast iron reducing tees	5.48
Floor and ceiling plates	1.22
Brought iron nipples	.62
Pipe hangers	2.82
Radiator air valves, wood, wheel, with name	9.00
Pipe covering	21.60
Moulded elbows and tees	3.02
12 day's work for plumber and helper (60 cents hr.)	64.80
Total Cost For Steam	446.56

Radiating Surface Needed For Hot Water

Temperature of water 170° F as maximum

Temperature of room 70° F

Difference $170 - 70 = 100^{\circ}$ F

Cast iron radiators 1.58 B. T. U. per degree difference
in temperature.

$1.58 \times 100 = 158$ B. T. U. per hour per sq. ft.

			sq. ft. Use
Bed room "A"	$16001 \div 158 = 101$		104
Bed room "B"	$12021 \div 158 = 76$		80
Bedroom "C"	$12045 \div 158 = 76$		80
Bed room "D"	$9184 \div 158 = 58.1$		60
Bank room and Hall	$8040 \div 158 = 51$		53
Barlor	$17050 \div 158 = 108$		108
Bedroom down stairs	$15094 \div 158 = 95$		100
Sitting room	$15000 \div 158 = 95$		95
Halls and vestibule	$14080 \div 158 = 89$		92
Dining room	$14002 \div 158 = 88.6$		90
Bath room	$4040 \div 158 = 25.6$		26
Kitchen	$24087 \div 158 = 152$		150
Total square feet radiating surface		1622	1622

Size of Circulating Pumps For Hot Water

Use two separate mains with the radiating surface
divided between them as follows:

Circulating Main No. 1

Bedroom "C"	80 Sq.Ft.
Bedroom "L"	86 " "
Sitting Room	96 " "
Halls and Vestibule	92 " "
Dining Room	96 " "
Kitchen	150 " "
Total radiating surface on main	570 Sq.Ft.

Circulating Main No. 2

Bedroom "A"	104 Sq.Ft.
Bedroom "B"	80 " "
Bank room and back hall	21 " "
Parlor	160 " "
Bedroom down stairs	160 " "
Bathroom	43 " "
Total radiating surface on main	458 Sq.Ft.

As the kitchen will probably not be heated by hot water the radiating surface is divided about equally between the two circulating mains.

Size of Circulating Mains for Hot Water

Temperature difference between water in the radiator and room, 100° F.

Unit radiation 1.58 B.T.U. per square foot per hour for one degree difference in temperature.

$1.58 \times 100 = 158$ B. T. U. per hour per square foot.

One pound of water circulating through the system loses 10 B. T. U. per hour.

$158 \div 10 = 15.8$ water circulated per hour per square foot of radiation.

15.8 x 452 = 7141.6, water circulated per hour in main. 17

7141.6 ÷ 3600 = 1.984" water circulated per second

1.984 ÷ 62.5 = .03174 cubic feet water per second

.03174 ÷ .54 = .0588 cubic feet cross sectional area of
circulating main

.0588 x 144 = 8.47 square inches area of pipe.

8.47 = $\pi d^2 \div 4$ (8.47 x 4) ÷ π = d^2

d^2 = 10.73 d = 3.28 inches Use a 3.5 inch pipe

Boiler, Pipes and Fittings for Hot Water

Ideal sectional boiler rated at 1350 square feet.

1022 square feet of radiator surface, standard.

22" cast iron, two column radiators.

4 - 1"; 2 - 1" and 18 - 1" brass angle valves with unions.

12 radiator air valves with wood wheel.

115' - 5½" wrought iron pipe for circulating mains.

230' - 1½" " " " " risers

40' - 1½" " " " " "

40' - 1" " " " " "

30' - 1" " " " to expansion tank

14 - 3½" cast iron elbows

26 - 1½" " " "

4 - 1½" " " "

6 - 1" " " "

5 - 1" " " "

12 - 3½" ducts cast iron reducing tees

12 - 3½" pipe hangers, sectional

6 - 1"; 4 - 1½"; and 24 - 1½" nickel plated floor plates

2 - 1": 2 - 1 $\frac{1}{2}$ " and 6 - 1 $\frac{1}{2}$ " patent two piece ceiling plates.

One expansion tank, galvanized iron.

125' - 3" pipe covering

160' - 1 $\frac{1}{2}$ " " "

10' - 1" " "

14 - 5 $\frac{1}{2}$ " moulded elbow covers

16 - 1 $\frac{1}{2}$ " " " "

12 - 5 $\frac{1}{2}$ " Lureka reducing tee covers

All pipe covering to be 85% magnesia.

Cost of Boiler, Pipe, and Fittings for Hot Water.

125 sq. ft. sectional boiler, 1250 square feet	132.00
160 sq. ft. radiator surface	182.48
24 brass angle valves	84.15
12 radiator air valves	6.00
brought iron pipe	59.17
cast iron elbows	9.70
12 - 5 $\frac{1}{2}$ " cast iron Lureka tees	18.96
12 - 3 $\frac{1}{2}$ " pipe hangers	4.20
Floor plates, nickel plated	1.49
patent two piece ceiling plates	1.26
expansion tank, galvanized iron	2.00
pipe covering, 85% magnesia	21.80
moulded elbow covers	3.96
Lureka reducing tee covers	3.15
14 days work for plumber and helper	<u>75.00</u>
Total cost for hot water	606.67

Size of Hot Air Furnace to Heat House

Total heat required 162542 B. T. U. per hour.

One pound of anthracite coal containing 9.1% of ash gives up
13189 B. T. U. (Heat)

Allowing 75% efficiency for furnace

$13189 \times 75\% = 9892$ B. T. U. converted into heat by combustion
of one pound of coal.

$162542 \div 9892 = 16.4$ pounds of coal burned per hour to heat
house.

Allowing $3\frac{1}{2}$ pounds of coal per square foot of grate surface
to be burned per hour.

$16.4 \div 3\frac{1}{2} = 4.7$ square feet of grate surface necessary in
furnace

Use a hot air furnace with a 20" fire pot giving a grate
surface of 4.88 square feet, as this is the largest
size furnace that can be gotten through the collar door.

Size of Hot Air Pipes

Divide the volume of the room by 20 and the square root
of the quotient will be the diameter of the pipe for first-
floor rooms. For second floor rooms divide the volume by 25 and
the square root of the quotient will be the diameter of
furnace pipe.

				Size of Pipe
Pipe for Bedroom "A"		$2027 \div 25 = 81$		10"
" " " "B"		$1693 \div 25 = 81$		9"
" " " "C"		$1517 \div 25 = 81$		8"
" " " "D"		$1505 \div 25 = 81$		8"

Size of
Pipe

Pipe for tank room and back hall	$642 \div 25 = 25$	5"
" " parlor	$1012 \div 20 = 50$	10"
" " bedroom down stairs	$1098 \div 10 = 109$	10"
" " sitting room	$1071 \div 20 = 53$	10"
" " halls and vestibule	$1010 \div 20 = 50$	10"
" " dining room	$1010 \div 20 = 50$	4 "
" " bath room	$214 \div 20 = 10$	5 use 8"
" " kitchen	$1010 \div 20 = 50$	10"

Use one 10" pipe for bedroom "B" and tank room.

Use one 14" pipe for parlor and bed room down stairs.

Size of registers necessary for rooms.

Calculations for Bedroom "A"

Temperature of air entering room 160° F.

Temperature of air in room 60° F.

Difference in temperature $(160 - 60) = 100^{\circ}$ F.

.2375 B. T. U. is the specific heat of air at a constant pressure, atmospheric pressure.

$.2375 \times 100 = 23.75$ B. T. U. per pound of air

$16631 \div 23.75 = 700.2$ pounds of air per hour.

$700.2 \times 15 = 9102.6$ cubic feet of air per hour.

$9102.6 \div 3600 = 2.528$ cubic feet per second.

Allowing a velocity of 4 feet per second to the second floor.

$2.528 \div 4 = .632$ square feet.

$.632 \times 144 = 91$ square inches effective area to which $1/3$

more must be added to get area register.

$91 \div 30 = 121$ square inches.

Register for the room	10" x 12"
Bedroom "B"	9" x 12"
Bedroom "C"	8" x 12"
Bedroom "A"	8" x 12"
Back room and back hall	8" x 10"
Parlor	10" x 12"
Bedroom down stairs	10" x 10"
Sitting room	12" x 12"
Halls and vestibule	10" x 12"
Dining room	9" x 12"
Bath room	8" x 10"
Kitchen	10" x 14"

Elbows and Length of Lin Pipe for Hot Air Flues

Length of 8" pipe, 18'

" " 9" " 10'

" " 10" " 8'

" " 14" " 10'

" " 20" " for ventilation 15'

" " 3 5/8" x 12" pipe in partition 50'

No. of 8" elbows, 3

" " 9" " , 3

" " 10" " , 10

" " 14" " , 2

9 dampers for hot air flues

Cost of Furnace, Pipe and Elbows for Hot Air

One Leis Furnace, 28" fire-pot with casing	\$130.00
12 Hot air registers	10.00
2 Ventilating pipe face plates	5.00
4 in pipe for flues, made up	14.85
Elbows made up 25 cents each	4.25
Regulator and chains	2.50
6 dampers for flues	1.60
Asbestos paper covering for flues	2.00
Cost of labor for installation	<u>30.00</u>
Total cost for hot air - - - - -	200.50

Ventilation of house

For ventilation of house use two cold air flues each 20" in diameter. One to be placed in the hall down stairs and one at the east wall of the sitting room, both pipes to be carried down to a conduit under the cellar floor to the base of the furnace.

Coal necessary to heat the house

The heat loss from the walls of the house during zero weather is 102342 B. T. U. per hour. One pound of commercial coal containing 9.1, ash contains 15189 B. T. U.

Allowing an efficiency of 75% for furnace the amount of coal necessary to heat the house for one hour in zero weather would be $102342 \div (15189 \times .75) = 16.4$ pounds.

$16.4 \times 24 = 396.6$ pounds of coal for twenty-four hours. As the average heat loss from a house during the heating season is about 50% of the loss during zero weather, (Authority, J. N. Allen)

the amount of coal necessary for one hundred and fifty days would be $293.6 \times 150 \times .5 \div 2000 = 14.76$ tons for the hot air system of heating.

The American Radiator Company consider that commercial coal contains 12000 B. T. U. per pound and that one pound of coal will evaporate eight and one-half pounds of water from and at 212° F. $966 \times 8\frac{1}{2} = 8211$ B. T. U. per pound of coal $132342 \div 8211 = 16.77$ pounds of coal per hour during

zero weather.

$16.77 \times 24 = 474.48$ pounds per day.

$474.48 \times 150 \times .5 \div 2000 = 17.786$ tons of coal for steam or hot water heating per year.

Authorities for information used in thesis; notes on Heating and Ventilation by Leon C. W. Mitchell. Notes on Heating and Ventilation by J. L. Allen. Michigan Supply Co. of Lansing, Mich., for heaters, pipes and cast iron fittings. Hurry and Hurry for hot-air furnace and flues. American Radiator Co. for radiators and efficiency of heaters.

Summary of thesis

Estimate cost of boiler, pipes, fittings and labor of installation for steam heating complete, \$446.56.

Estimate cost of boiler, pipes, fittings, and labor of installation for hot water heating, \$606.67.

Estimate cost of furnace and labor of installation for hot air heating, \$200.50.

Estimated amount of coal to heat the house by hot air
twenty-four hours in zero weather, 333.6 pounds. For heating
season of one hundred and fifty days, 14.75 tons. Estimated
amount of coal to heat house by steam or hot water for twenty-
four hours in zero weather, 474.48 pounds. For heating
season of one hundred and fifty days, 17.766 tons.

---oooOCCO,OOOooo---

[REDACTED]

3/29/40

[REDACTED]

Pocket has: 6 Suppls.

[REDACTED]

202/40


[REDACTED]

Pocket No. 1 & Supp.

MICHIGAN STATE UNIVERSITY LIBRARIES



3 1293 50023 4939



MICHIGAN STATE UNIVERSITY LIBRARIES



3 1293 50023 4939