

MACLEAN MORTON BABCOCK



101
349
THS

THESIS
DESIGN OF A
HEATING AND
LIGHTING SYSTEM

M. M. BABCOCK

L. W. DOUGHERTY


1910



This thesis was contributed by

Mr. L. W. Dougherty

under the date indicated by the department stamp,
to replace the original which was destroyed in
the fire of March 5, 1916.



SUPPLEMENTARY MATERIAL IN BACK OF BOOK

PLACE IN RETURN BOX to remove this checkout from your record.
TO AVOID FINES return on or before date due.
MAY BE RECALLED with earlier due date if requested.

DATE DUE	DATE DUE	DATE DUE
AUG 29 2009		

THESIS

---ooo000\$000ooo---

DESIGN OF

A

HEATING AND LIGHTING SYSTEM

FOR

REMODELLED BUILDING OF THE UNION LITERARY SOCIETY

---ooo000\$000ooo---

MICHIGAN AGRICULTURAL COLLEGE

--oo0\$0oo--

1910

By

M.M. Babcock,

L.W.Dougherty.

THESIS

12-4-51
(9)

DESIGN OF A HEATING AND LIGHTING SYSTEM

FOR

REMODELLED BUILDING OF THE UNION LITERARY SOCIETY.

It is the purpose of this thesis to investigate the methods commonly in use by Heating and Lighting Engineers for determining the amount of radiation required to heat a building, and also for determining the amount of light that should be supplied to a room in order to give satisfactory illumination. For this reason we chose to figure on a building that was to be constructed, and benefit ourselves by being able to see the actual results. The building for which we have designed heating and lighting systems is that belonging to the Union Literary Society of the Michigan Agricultural College, located at East Lansing, Michigan.

As the art of heating buildings has been studied for many years, we were able to find considerable data on the subject; and arrived at quite satisfactory results by several methods, which agreed with each other within reasonable limits. However the reverse is true concerning illumination, almost no data being available at this time; in fact authorities differ very widely as to the desired result. Naturally illumination may be said to be an inexact science. Experience seems to be the basis of figuring. Therefore we took the advice of an engineer who had had more or less experience along this line, and it was by his methods that we made our calculations for lighting. The rule may be said to be sort of "rule of thumb" method but it seems to be a good one, and gives quite satisfactory results.

The rule is, for ordinary heights of ceiling, (from 9 to 15 ft.) allow one 16 candle power lamp for every 36 square feet of floor.

The heating and lighting system as planned in this thesis are to be used in the remodelling of the building of the Union Literary Society, with few minor changes, and it may be of some interest to note the results.

A word might be said with regard to the piping as is shown by plans. One must bear in mind that this is not a new installation and it was desired to use as much of the old system as was consistent toward securing satisfactory results, and at the same time keep down expense. The lighting system is to be entirely new, none of the old wiring being used.

Methods of determining the radiation required.

- (1) By the wall losses. (See tables)
-

- (2) Carpenter's Method #1

$$\left(\frac{CN}{55} + \frac{W}{4} + G \right) d = \text{losses in B.T.U.}$$

$$\text{or } \frac{1}{250} \left(\frac{CN}{55} + \frac{W}{4} + G \right) d = \text{Sq. ft. of radiation surface}$$

Where

C = Volume in cubic feet.

W = Wall surface in square feet.

G = Glass surface in square feet.

d = difference in temperature on wall.

N = $\begin{matrix} 1 \text{ for ordinary rooms.} \\ 1.5 \text{ for corridors} \\ 2 \text{ to } 3 \text{ for vestibules.} \end{matrix}$ -- depending on tightness of room.

- (3) Carpenter's Method #2

$$\left(\frac{W}{4} + G \right) d n = \text{Square feet of radiation required.}$$

- (4) American Radiator Company's Method.

$$R = \frac{G}{2} + \frac{W}{20} + \frac{C}{200} = \text{Square feet of radiation required.}$$

- (5) Volumetric Method.

R = Volume divided by a constant K, which is 40 for ordinary exposure, and is 38 for rooms having a severe north or west exposure.

- (6) See tables showing a comparison of the different methods.

WALL LOSSES

A single wall having a thickness X is exposed on the inside to room temperature t , and on the outside to the temperature t_o which is less than t . (See fig. 1). There are two other temperatures to be considered t'_i and t'_o of the inside and the outside of the wall respectively.

The following relations exist.

$$t_i > t'_i > t'_o > t_o \quad (1)$$

otherwise heat does not flow across the system.

Let a_i and a_o be respectively the constant which multiplied by the temperature differences $(t_i - t'_i)$ and $(t'_o - t_o)$ will give the B.T.U. transmitted per hour per sq. ft. of wall surface.

$$\text{Evidently, } a_i(t_i - t'_i) = a_o(t'_o - t_o) \quad (2)$$

The coefficient of conductivity " e " is the B.T.U. which a wall of 1 inch thickness will transmit by conductor per hour per sq. ft. of exposed surface per degree difference of temperature.

$$\text{Evidently, } \frac{e}{X} (t'_i - t'_o) = a_i(t_i - t'_i) = a_o(t'_o - t_o) \quad (3)$$

A double wall of thickness X with air space and temperature conditions as shown on fig. 2; by a similar reasoning we get equations (4), (5) and (6).

$$t_i > t'_i > t'_2 > t''_2 > t'_o > t_o \quad (4)$$

$$a_i(t_i - t'_i) = a'_2(t'_2 - t'_2) = a''_2(t'_2 - t'_2) = a_o(t'_o - t_o) \quad (5)$$

$$a_i(t_i - t'_i) = \frac{e}{X}(t'_i - t'_2) = \frac{e}{X}(t'_2 - t'_2) \quad (6)$$

A compound wall composed of two materials as in fig. 3 may be considered as a special case of case 2, in which the air space is zero. By analogy,

$$\frac{e_1}{x_1}(t'_1 - t_2) = \frac{e_2}{x_2}(t_2 - t'_0) = a_1(t_1 - t'_1) = a_0(t'_0 - t_0) \quad (7)$$

$$t = \frac{\frac{e_1 t'_1}{x_1} + \frac{e_2 t'_0}{x_2}}{\frac{e_1}{x_1} + \frac{e_2}{x_2}} \quad (8)$$

For convenience it is desirable to have a formula for any combination design of the form $K(t_1 - t_0)$ in which K is the B.T.U. per hour per square foot per degree difference in temperature.

$$\text{Therefore in case 1, } K = \frac{1}{\frac{1}{a_1} + \frac{1}{a_0} + \frac{x}{e}} \quad (9)$$

$$\text{In case 2, } K = \frac{1}{\frac{1}{a_1} + \frac{1}{a_1'} + \frac{1}{a_0'} + \frac{1}{a_0} + \frac{x}{e} + \frac{x_2}{e_2}} \quad (10)$$

$$\text{In case 3, } K = \frac{1}{\frac{1}{a_1} + \frac{1}{a_0} + \frac{x}{e_1} + \frac{x}{e_2}} \quad (11)$$

These values of K have been worked out by experiment and otherwise by a greatmany experimenters, and these values were used im computations; except for the wall itself, in which case we solved equation (10) for a value.

VALUES OF K USED IN COMPUTATIONS.

For outside wall -----K = .25

For ceiling -----K = .10

For glass windows -----K = 1.03

For Door -----K = .41




Fig. 1.




Fig. 2.




Fig. 3.

For two column radiator of cast iron we find, that
unit radiation @ 1.66 when the temperature difference 155
 $225^{\circ} - 70^{\circ} = 155^{\circ}$

$1.66 \times 225 = 257$ B.T.U. per square foot of radiation
 per hour. 250 was used in computations.

Leakage correction was applied for all rooms.

$$L = \frac{nc}{55} (t_n - t_o)$$

Where n number of changes of air per hour by leakage.
 (n = 1 for ordinary houses)

c volume of room.

t_n inside temperature 70° .

t_o outside temperature 0° .

Allowance for north and west exposure

10% of the corresponding losses additional.

In ball-room an allowance was made for high ceiling
 being 14 feet high.

$$t_m = t + .015 (h - 10) t$$

t = head high temperature.

t_m = mean temperature of room.

h = height of ceiling.

Allowance was not made for intermittent service as
 heat is supplied day and night.

Determination of K for wall.

$$K = \frac{1}{\frac{1}{a_1} + \frac{1}{a'_1} + \frac{1}{a_o} + \frac{1}{a'_o} + \frac{1}{e_1} + \frac{1}{e_2}}$$

(See Fig. 4)

$$a_1 = c + d + \frac{(4c + 3d) T}{1000}$$

$$= 1.23 + .74 + \frac{(4 \times 1.23 + 3 \times .74) 14.4}{1000} = 2.0728$$

$$a'_1 = .82 + .74 + \frac{(4 \times .82 + 3 \times .74) 14.4}{1000} = 1.64$$

$$a'_o = .82 + .74 + \frac{(4 \times .82 + 3 \times .74) 1.8}{1000} = 1.59$$

$$a_o = 1.03 + .74 + \frac{(4 \times 1.03 + 3 \times .74)}{1000} = 1.78$$

$$K = \frac{1}{\frac{1}{2.07} + \frac{1}{1.64} + \frac{1}{1.57} + \frac{1}{1.78} + \frac{1}{5.6} + \frac{1}{.76}} = .2458$$

WALL LOSSES

Ball-room, Parlor and lower hall.

No	Exposure	Surface	Dimensions	Area in Sq. feet	$t_i - t_o$ F°	K	K($t_i - t_o$)	B.T.U.	Sq. feet Radiation
1	S	Wall	48' x 14'	576	74.2	.25	18.5	10670.	
2	S	4 Windows	8 x 3	96	"	1.03	76.4	7340.	
3	E	Wall	28 x 14	320	"	.25	18.5	5920.	
4	E	3 Windows	8 x 3	72	"	1.03	76.4	5510.	
5	W	Wall	28 x 14	320	"	.25	18.5	5920.	
6	W	3 Windows	8 x 3	72	"	1.03	76.4	5510.	
7	N	Wall	19 x 14	242	"	.25	18.5	4475.	
8	N	1 Window	8 x 3	24	"	1.03	76.4	1835.	
9								10% of N. and W. Exposures	1774.
10								Leakage	23940.
11								Total Losses	72894.
12								Square feet of radiation	290.
1	W	Wall	12 x 10	120.	70	.25	17.5	2100.	
2	E	Wall	12 x 10	100.5	"	.25	17.5	1752.	
3	E	1 Window	6½ x 3	19.5	"	1.03	72.1	1406.	
4	N	Wall	20 x 10	161.	"	.25	17.5	2817.	
5	N	2 Window	6½ x 3	39.	"	1.03	72.1	2812.	
6								10% of N. and W. Exposures	773.
7								10% for fireplace	1167.
8								Leakage	3360.
9								Total Losses	16194.
10								Square feet of radiation	65.
1	W	Wall	7½ x 10	51.	70	.25	17.5	892.5	
2	W	Window	8 x 3	24.	"	1.03	72.1	1730.4	
3	E	Wall	7½ x 10	67.	"	.25	17.5	1172.5	
4	E	Window	4 x 2	8.	"	1.03	72.1	576.8	
5	N	Door	5 x 8	40.	"	.41	28.7	1148.0	
6								10% of N. and W. Exposures	377.1
7								Leakage	2910.0
8								Total Losses	8807.3
9								Square feet of radiation	35.
10								Total radiation required	390.

WALL LOSSES

Upper hall, library and den.

.Exposure Surface		Dimensions	Area in t.-t. K	K(t, -t.)	B.T.U.	Sq. Feet Radiation
			Sq.Feet	F°		
W	Wall	7½ x 7½	36.7	70 .25	17.5	642.3
W	1 Window	3 x 6½	19.5	70 1.03	72.1	1405.9
	Ceiling	18 x 7½	135.	30 .10	3.0	405.0
			10% of west exposure			204.8
			Leakage			<u>1546.3</u>
			Total Losses			4204.3
			Square Feet of Radiation			17.
	Ceiling	17 x 9½	224.	30 .10	3.0	672.6
			Leakage			<u>2575.0</u>
			Total Losses			3247.6
			Square Feet of Radiation			13.
E	Wall	28 x 7½	151.5	70 .25	17.5	2651.3
E	3 Windows	3 x 6½	58.5	" 1.03	72.1	4217.8
S	Wall	19 x 7½	94.5	" .25	17.5	1653.7
S	2 Windows (8 x 6½)	39.0	" 1.03	72.1	2811.9	
N	Wall	9 x 7½	48.0	" .25	17.5	840.0
N	1 Window	3 x 6½	19.5	" 1.03	72.1	1405.9
	Ceiling	19 x 28	532.0	30 .10	3.0	1596.0
			10% of north exposure			224.6
			Leakage			<u>6710.0</u>
			Total Losses			22161.2
			Sq.Ft. of radiation			90.
E	Wall	13 x 5	65.	70 .25	17.5	2137.5
N	Wall	20 x 9	141.	" .25	17.5	2467.5
N	2 Windows	3 x 6½	39.	" 1.03	72.1	2811.9
W	Wall	13 x 5	57.	" .25	17.5	997.5
W	1 Window	2 x 4	8.	" 1.03	72.1	580.0
	Ceiling	20 x 13	260.	30 .10	3.0	780.0
			10% N. & W. Exposure			685.7
			Leakage			<u>2978.0</u>
			Total losses			13438.1
			Sq. Feet of Radiation			59.
			Total Radiation required			<u>179.</u>

WALL LOSSES

Three Dressing rooms, and lavatory.

.Exposure	Surface	Dimensions	Area in	t _i - t _o	K	K(t _i - t _o)	B.T.U.	Sq. Feet
			Sq. Feet	F ^o				Radiation
	Ceiling	14½ x 10½	149.	30	.10	3.0	447.	
N	Wall	7½ x 10	55.5	70	.25	17.5	971.3	
N	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
W	Wall	10½ x 7½	57.	70	.25	17.5	997.5	
W	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
	Low Ceiling	4½ x 10½	46.1	30	.10	3.0	138.3	
							10% of N. and W. Exposure	478.1
							Leakage	<u>1705.0</u>
							Total Losses	7549.0
							Square feet of Radiation	30.
S	Wall	12½ x 7½	74.2	70	.25	17.5	1298.5	
S	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
	Ceiling	12½ x 10½	128.0	30	.10	3.0	364.0	
	Wall	7½ x 3	22.5	70	.25	17.5	394.0	
	Low Ceiling	3 x 5	15.0	30	.10	3.0	45.0	
							Leakage	<u>1459.0</u>
							Total Losses	4976.4
							Square Feet of Radiation	20.
W	Wall	10½ x 7½	59.2	70	.25	17.5	1036.0	
W	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
S	Wall	12½ x 7½	74.2	70	.25	17.5	1298.5	
S	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
	Ceiling	12½ x 10½	128.0	30	.10	3.0	348.0	
	Ceiling	3 x 5	15.0	30	.10	3.0	45.0	
							10% of west exposure	<u>270.5</u>
							Total Losses	7314.8
							Square Feet of Radiation	30.
W	Wall	6½ x 7½	29.0	70	.25	17.5	507.5	
W	Window	3 x 6½	19.5	70	1.03	72.1	1405.9	
	Ceiling	6½ x 8½	48.7	30	.10	3.0	146.1	
							10% of west Exposure	191.4
							Leakage	<u>632.5</u>
							Total Losses	2883.4
							Square feet of Radiation	15.
							Total Radiation (Square feet)	<u>95.</u>

Table showing comparison of results by different methods.

		Square feet of radiation required.					
Method		#1	#2	#3	#4	#5	Used
Ball-Room	1	290	270	264	300	470	350
Parlor	2	65	55	45	60	65	65
Hall	3	65	65	75	80	85	35
Library	4	90	80	55	100	125	125
Den	5	60	45	30	50	60	65
Dressing room	6	30	30	20	35	45	30
Lavatory	7	15	10	10	15	15	15
Dressing room	8	30	30	20	30	30	30
Dressing Room	9	20	20	15	20	30	30
Total		665	605	534	690	925	745

Table showing the required illumination.

[illegible]

Estimated Cost of Illumination.

Room	Estimated hours used per week.	K.W. used per week.
1	10	10.640
2	3	4.200
3	20	.900
3	6	.270
3	6	.420
4	5	1.960
5	15	3.780
6	1	.112
7	10	.660
8	6	.280
9	30	1.680
toilet	2	.056
porch	3	.336

K.W. Hours per week 12.194

At 10 cents per K.W.hour the cost per week would be \$1.22,

Cost per month (30 days) \$5.24

Method of calculating the necessary illumination.

Allow one 16 C.P. lamp for every 36 square feet floor space.

Candle power needed = $\frac{\text{Area} \times 16}{36}$

Tungsten lamps use about 1.25 watts per candle power.

Carbon lamps use about 3.5 watts per candle power.

COST ESTIMATE.

Fixtures.

3 - 4 light chandeliers @	\$8.50	\$25.50
8 - 1 light wall brackets@	.90	7.20
1 - 2 light chandelier @	6.00	6.00
2 - 1 Light ceiling globe@	.60	1.20
6 - 1 light den brackets @	.50	3.00
2 - 1 light wall brackets@	2.00	4.00
3 - 1 light sockets & wire@	.50	1.50
1 - 1 light wall bracket @	.90	.90
1 - 1 piano lamp @	3.00	<u>3.00</u>

\$ 52.30

Glassware for fixtures

9 - 6" globes @	.20	1.80
3 - 7" globes @	.30	.90
8 shades @	.30	2.40
2 - 6" Ceiling globes @	.20	.40
6 shades @	.30	1.80
2 shades @	.50	<u>1.00</u>

\$ 8.30

Lamps.

20 - 70 Watt tungsten lamps @\$1.10		22.00
2 - 45 " " " @	.70	1.40
12 - 16 C.P. Carbon lamps @	.17	2.04
8 - 8 C.P. " " @	.15	<u>1.20</u>

\$ 26.64

Switches etc.

10 - Push button switches@	1.00	10.00
3 - Snap switches @	.25	.75
1 - Socket or receptacle@	1.00	<u>1.00</u>

\$ 11.75

Fuses, distribution panel and wire.

14 - Fuses & plugs @	.15	2.10
1100 feet #14 DRC wire @	.02	22.00
200 feet #10 DRC wire @	.02	4.00
8 - outlet, fuse box @	8.00	8.00
Labor of wiring		<u>20.00</u>

\$ 66.10

Tubes

Knobs

Loom

Tape

Solder


5.00
5.00
3.00
1.00
<u>.25</u>

\$ 14.25

Total Cost - - - - -

\$179.34

Packet



MICHIGAN STATE UNIV. LIBRARIES



31293500235118