

MICHIGAN STATE UNIVERSITY WATER SUPPLY AND CONSUMPTION REPORT

By

Nathan Ward Arnett

A THESIS

Submitted to
Michigan State University
in partial fulfillment of the requirements
for the degree of

MASTER OF SCIENCE

Environmental Engineering

2010

ABSTRACT

MICHIGAN STATE UNIVERSITY WATER SUPPLY AND CONSUMPTION REPORT

BY

NATHAN ARNETT

Obtaining water supply and consumption data is the first step towards formulating a water conservation program. It is important to quantify the volume of water used, the major users, and the potential sources of losses or leaks in order to be able to target areas of need.

This report quantifies and summarizes water supply and consumption on the Michigan State University (MSU) East Lansing main campus. Eleven different categories or sectors were evaluated in terms of their impact on water supply and consumption along with quantification methods. These are: Metering, Power Plant, Chilled Water, Irrigation, Research/South Campus Farms, Residence Halls, General Fund Buildings, Athletic Buildings, Water Sold by MSU, Water Bought by MSU, and a Miscellaneous category targeting flushing and unaccounted for water.

Eighty-one percent (81%) of water consumption on the MSU campus can be accounted for in 5 of these sectors. The sectors along with the estimated volumes and percentages of water utilized are: the Power Plant (411,000 KGAL per year, 21%), Research/South Campus Farms (393,000 KGAL per year, 20%), Residence Halls (336,000 KGAL per year, 18%), General Fund Buildings (290,000 KGAL per year, 15%), and Chilled Water (133,333 KGAL, 7%). Fifteen percent (15%) of the water utilized on campus cannot be unaccounted for. This is believed to be due to inaccurate metering, insufficient metering (since not all buildings are metered), and leaks.

ACKNOWLEDGEMENTS

This report was written with the continued support, cooperation and efforts of the individuals in: Residential and Hospitality Services, Land Management Office, Landscape Services, Physical Plant, Power and Water, and the Water Research Institute.

A special thanks goes out to the following individuals for your continued patience and support on this project (in no particular order):

Lynda Boomer, Physical Plant

Gus Gosselin , Physical Plant

Doug MacDonald, Power and Water

Bob Ellerhorst, Power and Water

Amanda Groll, Power and Water

Rick Johnson, Power and Water

Diane Barker, Residential and Hospitality Services

Steve Frank, Landscape Services

Ben Darling, Land Management Office

Ruth Kline-Robach, Water Research Institute

Pat Curry, Maintenance Service Department

TABLE OF CONTENTS

LIST OF TABLES	vi
LIST OF FIGURES	ix
Michigan State University Campus.....	1
MSU Water Supply	2
Wells.....	2
Red Cedar River	3
Water Bought and Sold	4
Bottled Water.....	5
Meters	7
Metering at MSU	7
Types of Meters.....	10
Meter Maintenance and Calibration	13
Recommendations.....	14
Power Plant	15
North Campus Substation	16
Chilled Water Plant.....	17
Water Consumption	19
Recommendations.....	23
Irrigation.....	24
Irrigation Water Supply – Main Campus	24
Irrigation Water Supply – South Campus: Research Farms	27
Consumption of Water	28
Conservation Measures.....	31
Recommendations.....	32
Residence Hall Water Consumption.....	33
Water Consumption	36
Effect of Renovations on Water Consumption	39
Estimation of Water Consumption for Non-metered Residence Halls.....	40
Cafeteria Water Use	41
Discussion	41
Conservation Measures.....	42
Conclusions.....	45
Recommendations.....	45
General Fund and Athletic Buildings	46
General fund buildings	46
Athletic Facilities.....	50

Bathrooms	51
Labs.....	53
Recommendations.....	55
Miscellaneous.....	57
Autoclaves	57
Reverse Osmosis Units	57
Flushing the Distribution System.....	62
Leak Study	62
Water Use Summary	64
Summary of Recommendations	67
Preventative Maintenance	67
Equipment Installation and Replacement	68
Monitoring.....	70
Future Studies	72
APPENDICES.....	74
Appendix A	75
Water Supply	75
Appendix B.....	77
Water Bought	77
Appendix C.....	78
Water Sold	79
Appendix D	83
Meters	84
Appendix E.....	90
Power Plant	90
Appendix F.....	92
Chilled Water	92
Appendix G	96
Irrigation	96
Appendix H	104
Residence Halls.....	104
Appendix I.....	109
Buildings	109
Appendix J	111
Miscellaneous.....	111
BIBLIOGRAPHY	118

LIST OF TABLES

Table 1: Water System	3
Table 2: Peak Annual Water Demand	3
Table 3: Water Production	3
Table 4: Red Cedar Supply.....	4
Table 5: Water Purchased (Averaged over 2004-2008)	4
Table 6: Water Sold from Main Wells.....	5
Table 7: Meters with Known Installation Dates	7
Table 8: Buildings with Meters of Unknown Installation Dates.....	9
Table 9: Meters Monitored for Water Purchased from MSU	10
Table 10: Chilled Water Make-Up 2008	19
Table 11: Annual Water Consumption by the Regional Chilled Water Building	22
Table 12: Areas on Main Campus Irrigated with water from the Red Cedar River	25
Table 13 Wells Supplying Irrigation Water on Main Campus	26
Table 14: Irrigation Wells on South Campus: Farms.....	27
Table 15: Water Consumption from Irrigation Wells	30
Table 16: Average Water Consumption for Residence Halls.....	35
Table 17: Residence Hall Per Capita Water Usage.....	38

Table 18: Bryan Restroom Upgrades	40
Table 19: General Fund Building Water Consumption	46
Table 20: Athletic Building Water Consumption	50
Table 21: Estimated Water Savings from Bathroom Upgrades	52
Table 22: Top 25 Buildings with Respect to Number of Labs	53
Table 23: Buildings That Should be Metered for Future Study	55
Table 24: Top 10 Buildings to Study.....	56
Table 26: List of RO Units in Residence halls.....	59
Table 27: RO Evaluation	61
Table 28: Leak Study	62
Table 29: Water Supply	64
Table 30: Total Water Consumption.....	65
Table 31: Complete List of Water Sold.....	80
Table 32: Complete List of Meters.....	85
Table 33: MSU Supply Meters	88
Table 34: 2007-2008 Chilled Water Make-Up	93
Table 35: Campus irrigation Sites	101
Table 36: Residence Hall Summary.....	105

Table 37: RO System Information – RHS Residence Halls (Updated 7/21/10).....	113
---	------------

LIST OF FIGURES

Figure 1: Water Meter (Old Unit)	11
Figure 2: Water Meter (Common Unit).....	12
Figure 3: Water Meter (New Unit)	12
Figure 4: Water Meter (Impulse Unit)	13
Figure 5: Chilled Water Make-Up 2008.....	21
Figure 6: Water consumption vs. number of Residents	36
Figure 7: Per Capita Data for Each of the Residence Halls	37
Figure 8: Water Consumption with Respect to Laboratories.....	54
Figure 9: Water Consumption Distribution	65
Figure 10: Irrigation Proposed Zone Map	102
Figure 11: Campus Irrigation Map	99

Michigan State University Campus

The Michigan State University (MSU) Campus has a contiguous area of 5,200 acres (21 km^2), 2,000 acres (8.1 km^2) of which are developed. In terms of infrastructure, there are 556 buildings: 100 for academics, 131 for agriculture, 166 for housing and food service, and 42 for athletics. Overall, the university has 22,763,025 square feet ($2,114,754.2 \text{ m}^2$) of total indoor space. For the sake of simplicity, in this report we have divided the campus into two sections. Main (North and South) Campus includes all property and buildings north of Mount Hope Road, bounded by Hagadorn Road on the east, Route 127 on the west and Grand River Avenue on the north. South Campus: Research Farms includes all contiguous property owned and maintained by MSU south of Mount Hope Road, west of Hagadorn Road and east of Route 127

MSU Water Supply

The majority of the water supplied to the Michigan State University campus is pumped from the Saginaw Aquifer. However, water is also pumped from the Red Cedar River (for irrigation) and purchased from East Lansing/Meridian Township, Lansing Board of Water and Light, and from private companies, which supply bottled water to some departments.

Wells

Water to the Michigan State University campus is supplied by 18 wells, which pump directly from the Saginaw Aquifer. These wells pump into a one million gallon reservoir where water is then chlorinated and distributed for potable use, chilled water, and irrigation. This water is also used for cooling water in the Power Plant. For simplicity, these wells will be denoted as “main” wells in this report.

In addition to the 18 wells that supply campus there are also a number of wells (estimated at 11) and are herein called “irrigation” wells. It is estimated that these wells supply significantly less water than the 18 main wells. While most of this water is used for irrigation, the water is also used for domestic purposes (hand-washing, flushing, and some human consumption) in a number of these buildings. Below are tables showing water productivity on the Michigan State University campus.

Table 1: Water System

Water System

# of wells		18
Nominal	Well	9000
Capacity (GPM)		
Reservoir	Storage	1,200,000
Capacity (Gal)		
Reservoir	Pump	9,600
Capacity (GPM)		

Source: Physical Plant Division 2008-2009 Annual Report

Table 2: Peak Annual Water Demand

Peak Demands	2004- 2005	2005- 2006	2006- 2007	2007- 2008	2008- 2009
Water (GPM)	5,800	6,300	5,600	6,400	6,300

Source: Physical Plant Division 2008-2009 Annual Report

Table 3: Water Production

Water Production and Consumption

Year	2004- 2005	2005- 2006	2006- 2007	2007- 2008	2008- 2009
Volume pumped from Main Wells (MGAL/yr)	2047	2185	1878	1801	1670
Volume pumped At Reservoir outlet (MGAL/yr)	1527	1587	1554	1533	1415
Volume pumped from Irrigation Wells (MGAL)	520	598	324	268	255

Source: Physical Plant Division 2008-2009 Annual Report

Red Cedar River

Water from the Red Cedar River is also used for irrigation. The Ingham County Health Department, monitors the Red Cedar River as it flows through the county for *E. coli* on a weekly basis from May through September. In East Lansing samples are collected at Hagadorn Road,

the Farm Lane Bridge, and Harrison Road. The Health Department advises that significant rain events (>1/4 inch in 48 hours) may increase *E. coli* counts, making the water unsafe for recreational activities. (Results of the sampling can be found at the website: <http://hd.ingham.org/environmental-health/other-services/water-quality/community-surface-water-sampling.aspx>). Water from the Red Cedar River is used solely for irrigation, primarily, for the athletic fields on campus. Signs are prominently posted, where appropriate, indicating that these fields are irrigated with non-potable water. The lines are also posted as non-potable water. Below is a table of water pumped from the Red Cedar River on an annual basis from 2004-2008. The total amount of land irrigated using water from the Red Cedar River is 48.46 acres.

Table 4: Red Cedar Supply

Water Supplied from Red Cedar River

Year	2004	2005	2006	2007	2008
Volume pumped (MGAL/yr)	14.05	28.64	13.53	13.68	17.71

Source: MSU Land Management Office, Personal Communication, 10/15/2009

Water Bought and Sold

In addition to the water that is supplied to the MSU campus by wells; the East Lansing/Meridian Township Water Treatment Plant and Lansing Board of Water and Light supply a small portion of water used on campus for the buildings listed in Table 5.

Table 5: Water Purchased (Averaged over 2004-2008)

	Water Purchased (KGAL/yr)
University village (East Lansing/Meridian Township)	3,000
Central School (Lansing Board of Water and Light)	110
Horse Research Facility (Lansing Board of Water and Light)	81
Henry Center (Lansing Board of Water and Light)	1400

Table 5 Cont.

Chemical Waste facility (Lansing Board of Water and Light)	5
Entomology (Lansing Board of Water and Light)	43
Civil Lab Jolly Road (Lansing Board of Water and Light)	600
Total	5,200

Source: MSU Power Plant, Personal Communication, 3/2/2010

The total water purchased annually at MSU is 5200 KGAL. This is small compared to the amount of water pumped from the MSU main wells (0.3%).

Water supplied from the MSU main wells is also sold by MSU to the entities shown in Table 6.

Table 6: Water Sold from Main Wells

	Average Amount of Water Bought from MSU in 2005- 2009 (KGAL)
State Control Laboratory	6500
MSU Credit Union*	1000
Michigan State Police	7600
USDA Agricultural Research	2300
TOTAL	17400

Source: MSU Power Plant, Personal Communication, 3/2/2010

* Although the MSU Federal Credit Union vacated the property on Crescent Rd., the January 2010 Utility Report still lists this as MSU Federal Credit Union. As such, we have used this label herein.

The average annual amount of water from the MSU main wells sold to non-MSU entities is 17,400 KGAL. This is 1% of the total amount of water pumped from the main wells on campus.

Bottled Water

Bottled water is a source of drinking water on campus. The evaluation of bottled water use on campus needs to be completed and recommendations need to be put in place to reduce bottled water use; however details are beyond the scope of this report. Bottled water has not been included in the total water supplied to or used on the MSU campus. From 2007 to June of

2009 nearly 2 million bottles of water were sold on campus. Through measures such as the installation of filtration units in residence halls, MSU is striving to reduce bottled water use. MSU has also campaigned for reusable water bottle use in residence halls by distributing flyers and refillable bottles to new residents and providing hydration stations in the residence halls.

Meters

Metering is important to water purveyors because it makes it possible to charge customers based on the amount of water they use. Metering can also be beneficial because it encourages users to conserve water, and holds the consumers responsible for their water use. A study completed by Steve H. Hanke of John Hopkins University concluded that domestic use of water was reduced by 36% after meter installation (Hanke, 1970). Meters also allow suppliers to keep track of the amount of water they pump and produce for the consumers. Metering also helps in determining if there are leaks in the distribution system, based on the difference between the amount of water that is pumped and the amount of water used.

Metering at MSU

Some of the MSU buildings on campus are metered. Meter readings are checked once a week.

A list of building meters with dates of installation is shown below in Table 7. (Dates listed first without months were provided by Pat Curry, all dates after given by the MSU Power Plant)

Table 7: Meters with Known Installation Dates

Bldg #	Building Name	Meter	Date of Installation
0189	REGIONAL CHILLED WATER PLANT NO. 1	0189W1	1971
0059	MUNN, CLARENCE L., ICE ARENA	0059W1	1974
77	FOOTBALL BUILDING	0077W1	1980
85	WHARTON CENTER	0085W1	1982
0084	COMMUNICATION ARTS & SCIENCES BUILDING	0084W1	1984
0203A	ENGINEERING RESEARCH COMPLEX	0203W1	1986
0069	BRESLIN, JACK, STUDENT EVENTS CENTER	0069W1	1989
0080	BUSINESS COLLEGE COMPLEX (EPPLEY) (Meter Date for North Complex)	0080W1	1993
0186	FOOD SAFETY AND TOXICOLOGY BUILDING	0186W1	1997
0212A	PAVILION FOR AGRICULTURE AND LIVESTOCK EDUCATION - HORSE BAR	0212W1	2000
0160	BIOMEDICAL PHYSICAL SCIENCES BUILDING	0160W1	2005
0313	BRODY HALL (East Lansing Water 2010)	0313W1	2010
0175	INTRAMURAL RECREATIVE SPORTS EAST	0175W1	2010

Table 7 Cont.

0311	RATHER HALL (East Lansing Water as of 2010)	0311W1	2010
0312	BRYAN HALL (East Lansing Water 2010)	0312W1	2010
0314	EMMONS HALL (East Lansing Water 2010)	0314W1	2010
0315	BAILEY HALL (East Lansing Water 2010)	0315W1	2010
0310	BUTTERFIELD HALL (East Lansing Water 2010)	0310W1	2010
0171	FOOD STORES	0171W1	2010
167	PHYSICAL PLANT		2010
158	GROUND HEADQUARTERS		2010
0024	NATURAL SCIENCE	0024W1	Jan-97
0128	NISBET, STEVEN S., BUILDING	0128W1	May-97
		0307W1	May-97
0308	WILLIAMS HALL	0308W1	Jun-97
0304	CAMPBELL HALL	0304W1	Jul-97
0306	YAKELEY AND GILCHRIST HALL	0306W1	Aug-97
0302	MASON AND ABBOT HALL	0302W1	Jan-98
0056	JENISON FIELDHOUSE	0056W1	Aug-98
		0077W2	Nov-98
0154	MANLY MILES BUILDING	0154W1	Feb-99
0005	HUMAN ECOLOGY	0005W1	May-99
0006	UNION BUILDING	0006W1	Aug-00
0305	LANDON HALL (Meter installation is expected at the given date)	0305W1	Aug-00
170	VETERINARY MEDICAL CENTER	0170W1	Aug-00
		0178W3	Oct-01
0086	PLANT & SOIL SCIENCES BUILDING	0086W1	Feb-02
0219	PARKING RAMP NO.1 SHAW LANE (NEW)	0219W1	Sep-02
0177	PACKAGING	0177W1	Apr-05
0058	SPARTAN STADIUM	0058W1	Aug-05
2000	CLINICAL CENTER	2000W1	Sep-05
0300	SNYDER AND PHILLIPS HALL	0300W1	Aug-07
0214	RADIOLOGY BUILDING	0214W1	Nov-07
0319	VANHOUSEN HALL	0319W1	Nov-07
		0170W2	Nov-07
0013	MUSEUM	0013W1	Jan-08
0163	CHEMISTRY	0163W1	Jan-08
		0203W2	Feb-08
		0170W3	Jul-08
0055	KELLOGG CENTER	0055W1	Mar-09
0083	MSU COLLEGE OF LAW	0083W1	Jun-09
0316	ARMSTRONG HALL	0316W1	Aug-09
0309	MARY MAYO HALL	0309W1	Sep-09
0028	GILTNER HALL	0028W2	Nov-09
		0028W1	Dec-09
0323	WONDERS HALL	0323W1	Jan-10

Source: Source: MSU Power Plant, Personal Communication, 3/2/2010 and Pat Curry, Personal Communication, 9/28/2010

Below (Table 8) is a list of meters on campus with unknown installation dates; these meters are assumed to be older meters.

Table 8: Buildings with Meters of Unknown Installation Dates

Bldg #	Building Name	Meter
0002	BERKEY HALL	0002W1
0003	OLIN MEMORIAL HEALTH CENTER	0003W1
0027	PSYCHOLOGY BUILDING	0027W1
0029	KEDZIE HALL (NORTH AND SOUTH)	0029W1
0035	COMPUTER CENTER	0035W1
		0055W2
0060	CENTRAL SERVICES BUILDING	0060W1
		0060W2
0068	LAUNDRY BUILDING	0068W1
0081	ENGINEERING BUILDING	0081W1
		0081W2
		0086W2
0087	PUBLIC SAFETY	0087W1
0132	ANTHONY HALL	0132W1
		0132W2
		0132W3
		0132W4
0178	PLANT BIOLOGY LABORATORIES	0178W1
		0178W2
		0303W1
0317	SHAW HALL	0317W1
0320	OWEN GRADUATE HALL	0320W1
0330	HOLMES HALL	0330W1
0446A	VETERINARY RESEARCH CENTER - LARGE ANIMAL BARN	0446W1
		0446W2
1121	MUSIC/MUSIC PRACTICE	1121W1
7000	FACULTY BRICK APARTMENTS	7000W1
91	FARRALL AGRICULTURAL ENGINEERING HALL	0091W1

Source: MSU Power Plant, Personal Communication, 3/2/2010

Michigan State University also has meters that are used to monitor water that is purchased from the University. Table 9 lists the location of meters that are used to track the consumption of purchased water.

Table 9: Meters Monitored for Water Purchased from MSU

Water Meters

618	James B. Henry Center
475A	Chemical Waste Facility #1 (Jolly Rd.)
475B	Chemical Waste Facility #2 (Jolly Rd.)
129	Entomology (Collins Rd.)
456O	Horse Research Center

Source: MSU Power Plant, Personal Communication, 9/29/2009

Types of Meters

The type of meters used by MSU varies with the age of the meter. Older meters vary by manufacturer but are turbine meters. Turbine meters have a rotating element that spins as the water passes across it. The volume of water is measured by the number of rotations within the device. Since older meters do not include a strainer they are subject to scaling or the deposition of particulates, which may cause the impeller to stick, resulting in inaccurate readings, usually underestimating flow rates. Minerals may include iron, calcium, manganese, and magnesium precipitates resulting from the natural hardness of the well water. (Rick Johnson, personal comm., 4/29/2010).

At present, the preferred meter for use on campus is the Sensus Omni T2 meter. The Sensus meter utilizes an impeller, but incorporates new “floating ball” technology. The Sensus meter also includes a strainer, which helps to remove debris and particulates, therefore increasing the integrity of the data generated by the meter.

Some buildings employ a Sensus Impulse Contactor that attaches to the meter. This type of meter reads impulses and after a certain volume of water has passed through the meter, the device records that amount. This type of meter does not give total flow rates but rather a volumetric quantity. Flow rates can then be determined manually by dividing the volumetric quantity by the time interval it took to reach that volume.

Photographs of meters that were determined to be old, normal, and new, are provided below.




Figure 1: Water Meter (Old Unit) (From MSU Power Plant employee – Rick Johnson, personal communication. 4/29/2010)

Figure 1 was taken of a meter at Berkey Hall, one of the buildings where the installation date of the meter is unknown. This is determined to be an “old meter”.



Figure 2: Water Meter (Common Unit)
(From MSU Power Plant employee – Rick Johnson, personal communication. 4/29/2010)

Figure 2 shows a Sensus meter. Although commonly found on campus, these meters are not used for new installations. This meter is located in Olin Memorial Health Center, and the date of installation is unknown.



Figure 3: Water Meter (New Unit) (From MSU Power Plant employee – Rick Johnson, personal communication. 4/29/2010)

The meter shown in Figure 3, which is located in Wonders Hall, is the meter type currently used by the university. This is a Sensus Omni T2 meter and it was installed January 2010.



Figure 4: Water Meter (Impulse Unit)
(From MSU Power Plant employee – Rick Johnson, personal communication. 4/29/2010)

Figure 4 shows a meter located in Wilson Hall. This meter has an impulse contactor connected to it. The installation date for this meter is unknown; however it is assumed to be a very recent installation (2010) and is not yet on record.

Meter Maintenance and Calibration

MSU does not currently have a meter maintenance and calibration program in place, nor is there a meter replacement program in place. Meters are simply replaced when they cease operation. Meters can typically last 15-20 years with proper maintenance, although no data exists for the average operational time for the meters on the MSU campus.

In 2005, Power Plant personnel began using a flow orifice to determine how much water was pumped from each of the 18 main wells. A flow orifice in general is thought to be more

accurate than the in-line meters that have been (and continue to be) used to measure the flow rate of water pumped from the main wells. Testing was done once a year. In 2005, it was found that the in-line meters had readings that were as much as 32% greater than the readings obtained using the flow orifice. Because of this discrepancy a program was put into place to clean the in-line meters once a year. By 2009, with regular maintenance the difference between the in-line meter readings and the flow orifice readings were not greater than 7.6%. This shows how important meter maintenance can be. Over the next year (2010) the Power Plant plans to replace the current in-line meters with magnetic flow meters which are thought to be as accurate or even more accurate than the flow orifice devices. (Doug Macdonald, Personal Communication, August 2010)

Also, it is believed based on this study that well production numbers may have been overvalued in the past.

Recommendations

It is recommended that a water meter maintenance and renewal program be explored. Meters should be checked, cleaned and calibrated every 7 to 10 years (Satterfield, Zane, P. E., and Bhardwaj, Vipin, Water Meter Tech Brief). Because the water at MSU is high in mineral content, maintenance is critically important to ensure proper operation of the meters employed on campus, and the integrity of the data collected.

A renewal program should also be explored to replace all water meters that do not meet current specifications.

Metering is the best way to determine water use, therefore accurate metering is the best way to track and document water consumption on MSU's campus.

Power Plant

Michigan State University is provided with energy from the T.B. Simon Power Plant. The power plant is a co-generating facility, meaning the facility utilizes the steam once to power turbines to produce electricity, and then it uses the steam to heat and cool the buildings on campus. Because of this co-generation, the power plant is 60% efficient, compared to traditional systems that may only be 30% efficient. Water consumption for the power plant is expected to be high considering the power plant is the main source of energy, heating, and cooling on campus.

The Physical Plant website (<http://www.pp.msu.edu/content/power.html>) states that in an average year the power plant uses 450,000 KGAL of water. The source of that datum is unknown. Physical plant personnel report the average water consumption for the power plant over the last 6 years as 411,000 KGAL and over the last three years the as 375,000 KGAL (Lynda Boomer, Doug MacDonald and Amanda Groll, Personal Communication, 6/24/2010). The total water used by the power plant for 2008-2009 was 391,000 KGAL (Source: Amanda Groll, Physical Plant, Personal Communication, 10/7/2009). Based on these values (411,000 KGAL), the power plant uses roughly 21% of water consumed at MSU.

North Campus Substation

The North Campus Sub-station is part of the condensate return system for all of North Campus which returns steam condensate to the power plant for reuse. There are vacuum pumps that are water cooled in the North Campus Sub-station, which leads to significant water use.

Water is lost in the system when condensate goes to the drain, rather than being returned to the Power Plant. This can cause operational issues at the Power Plant as well as causing higher water consumption due to make-up water being added. (Lynda Boomer)

Water usage in the North Campus substation is not metered.

Chilled Water Plant

Michigan State University utilizes a chilled water system to cool a large percentage of its buildings and facilities. The chilled water system acts as a steam absorption machine. The absorption chiller has five main phases; condensing, expansion, evaporation, absorption, and a generator or concentrator. In condensing, cooling water absorbs heat from a vaporized refrigerant (steam) thus turning the refrigerant (steam) into a liquid (water). The refrigerant (water) is then expanded on its way to an evaporator. During expansion the temperature of the refrigerant (water) is dropped due to a drop in pressure. The refrigerant (water) is then vaporized in an evaporator by being sprayed on tubes of chilled water; upon vaporization energy is removed from the chilled water. The vaporized refrigerant (steam) is then sprayed with a salt (lithium bromide) which absorbs the refrigerant (water). Cooling water absorbs the heat of vapor absorption. The salt and refrigerant solution (lithium bromide and water) then enters a concentrator where the solution is heated till the refrigerant (water) is vaporized and sent back to the condenser, thus completing the loop (<http://www.scribd.com/doc/17553414/Basics-for-Absorption-Chillers>). Because MSU's campus utilizes a central steam loop for power from the power plant, absorption chillers are a logical choice. In the summer, the steam produced to generate electricity can also be used to create chilled water, thus increasing the efficiency of the cogeneration power plant by utilizing as much of the thermal energy as possible. Winter operation includes a thermal component for heating (Lynda Boomer). Absorption chillers are also better for the environment because they use water as a refrigerant as opposed to electric chillers, which use chlorine based chlorofluorocarbons (CFCs) or hydrochlorofluorocarbons (HCFCs) refrigerants. CFCs and HCFCs,

while effective refrigerants, have been implicated in the formation of the “ozone hole” and are regulated under Title VI of the Clean Air Act. Since the absorption chillers on campus require a large volume of refrigerant for cooling purposes, a water-based system is also more economical than an electrical based system because the steam produced from the power plant is used for the refrigerant.

Water Consumption

Chilled water is provided from the central chilled water plant and from individual chillers around campus. Because steam absorption is not 100% efficient, the system requires water to make up for evaporation in the system and other losses. Shown in Table 10 are the volumes of make-up water used during 2008 from each of the individual chillers. Building names highlighted in light green denote systems that are run year round. Data under the volume column that are highlighted in green denote "General Fund Buildings". Volumes of make-up water for 2007 can be found in the Appendix F. Furthermore, buildings that have refrigeration labels are labeled as such because they are designated as refrigerators or cold rooms. Buildings that are labeled with absorption are designated as such, as they use chilled water for cooling the air in the building. Both the refrigerated systems and the absorption systems use chilled water.

Table 10: Chilled Water Make-Up 2008

BUILDING	Volume (KGAL)
Comm. Arts	6
Anthony - REFRIGERATION	74
CIPS Refrigeration	102
Clinical Center Refrigeration	105
Biochemistry Refrigeration	157
Natural Resources Refrigeration	169
Anthony - Dairy Plant Refrigeration	253
Olin Health Center Refrigeration	253
International Center	511
Administration Building - DATA	601

Table 10 Cont.	
PROCESSING	
Kedzie Hall Absorption	684
Anthony - Meat Laboratory Refrigeration	837
Breslin Center Absorption	1,072
Administration Building	1,170
Cyclotron CT-1 Refrigeration	1,172
Regional Chilled Water Plant 10	1,197
Wells Hall Absorption	1,296
Bessey Hall Absorption	1,396
Munn Ice Arena Refrigeration	1,396
Union Building Absorption	1,573
Regional Chilled Water Plant 8	1,732
Regional Chilled Water Plant 7	1,992
Kellogg Center (East)	2,225
Engineering Absorption	2,696
Fee Hall Absorption	2,782
Regional Chilled Water Plant 9	2,898
DCPAH-Diagnostic Center for Population and Animal Health	3,385
Regional Chilled Water Plant 5	3,437
Erickson Hall Absorption	4,107
Library Absorption	4,524
Kellogg Center (West)	4,806
Anthony – ABSORPTION	5,424
Food Science Absorption	5,511
Regional Chilled Water Plant 4	5,675
Regional Chilled Water Plant 2	5,879
Regional Chilled Water Plant 6	5,977
Regional Chilled Water Plant 3	6,077
Regional Chilled Water Plant 1	6,299
Biophysical Science	12,690

Source: Physical Plant, Personal Communication, 9/18/2009 (For interpretation of the references to color in this and all other figures, the reader is referred to the electronic version of this thesis)

The total water consumption for make-up water in the chilled water absorption system was 102,000 KGAL during 2008.

Figure 5 shows the distribution of makeup water for each of the buildings listed in Table 10. Green bars indicate “General Fund Buildings”. As shown, the largest user of make-up water is the Biophysical Science Building. The cause for this is unknown.




Figure 5: Chilled Water Make-Up 2008 (Source: Physical Plant, Personal Communication, 9/18/2009)

Data are also available for the consumption of water in the Regional Chilled Water Plant building. The Regional Chilled Water Plant building is responsible for providing chilled water to campus. This building is not part of the central power plant. The data for water consumption from 2005-2008 are shown below:

Table 11: Annual Water Consumption by the Regional Chilled Water Building

Year	KGAL
2005	65275
2006	24348
2007	20115
2008	15461
Average	31300

Source: Power Plant, Personal Communication, 9/29/2010

The average value given above is the total amount of water consumed in the plant, not only for chilled water purposes, but also for potable water uses such as sinks and toilets in restrooms.

As shown in Table 11, water use in the regional Chilled Water Building shows a decrease from 2005-2008. The reason for this decrease is unknown, but volumes are significant.

When the volume of make-up water from each individual chiller is added to the volume of water consumed at the Regional Chilled Water Plant, the total estimated annual water consumption due to chilled water is 133,300 KGAL or roughly 7% of water used on campus.

It should be noted that the North Campus Chilled Water Sub-station is not monitored. Because of this it is expected that the consumption of water for the chilled water system is actually greater than that reported herein.

Recommendations

A study to determine the efficiency of the chilled water system and whether there are newer technologies that can increase the efficiency of the system is recommended. However, considering that chilled water accounts for only approximately 7% of the total water consumption, efforts might be better focused in a higher use category.

Irrigation

Water for irrigation is supplied from three sources: irrigation wells, the University well system, and the Red Cedar River. Eleven irrigation wells are used to irrigate Main Campus and South Campus Farms. The University well system, consisting of 18 wells and feeding a main reservoir (1 million gallon storage tank), is also used for irrigation of a limited number of locations. Water from the Red Cedar River is used to irrigate 48.46 acres. (See Table 12 for complete list of acreage irrigated on campus). Maps showing the areas on campus that are irrigated are provided in Appendix G.

Irrigation Water Supply – Main Campus

Irrigation water for the Main (North and South) Campus is obtained from three sources: the university well system, two irrigation wells, and the Red Cedar River. Where water is used from the university well system, the water is supplied from the potable water lines supplied to the adjacent building(s).

A complete listing of areas on campus that are irrigated with water from the university well system is not available. However, it is thought that the gardens surrounding the Biophysical Science and old-Horticulture Buildings are irrigated using water from the university well system. In fact, water meters were installed in these buildings to monitor water used for irrigation. No data has been supplied for this report. (Personal Communication, Pat Curry, 9/28/2010).

Although the withdrawal is denoted as “Well Red Cedar SW” in the water use reports, water that is supplied by the Red Cedar River is pumped directly from the river. The water is initially filtered by a fine mesh filtration system. In 2002, a computerized Toro Sentinel Central Control system was installed to ensure that irrigation water is not obtained from the river after a rainfall of greater than 1/8 inch. After such rainfall events, the system is programmed to skip an irrigation cycle, thus complying with MSU policy. It is believed that the aeration of the water through the pump and sprinkler head diminishes the number of *E-coli* bacteria in the water (Frank, personal comm., 1/6/2010). A list of areas that are irrigated by the Red Cedar River is provided in Table 12. The east lawn of Brody Complex is the only area surrounding residence halls that is irrigated.

Table 12: Areas on Main Campus Irrigated with water from the Red Cedar River
Locations Irrigated by Red Cedar

Adams Field
Admin Bldg
Breslin
Kellogg Center
Cowles House
Baseball Diamond
Demonstration Hall
Football Practice Field
Munn Ice Arena
Soccer Fields
Track
Beal Garden
Brody Complex
Munn Field
Lot 79

Source: Steve Frank, Personal Communication, 2/10/2010

Irrigation water for the Main (North and South) Campus is also obtained from two wells: IM East and Stadium, which are used to irrigate the grounds around IM East and the Stadium, respectively. The location and acreage irrigated along with the Well ID are provided in Table 13.

Table 13 Wells Supplying Irrigation Water on Main Campus

Facility	Well ID	Area irrigated in 2008 (acres)
Grounds - IM East	IM East	13.5
Stadium	Stadium	2

Source: MSU Land Management Office, Personal Communication, 10/15/2009

Irrigation Water Supply – South Campus: Research Farms

On the South Campus: Research Farms, water for irrigation is obtained from the main university well system and from 10 irrigation wells. The main University well system serves the Golf Courses, Turf Grass, Plant Pathology, Tree Research, and Horticulture-Sand Hill. The irrigation wells supply the remaining areas of the South Campus: Research Farms. Table 14 lists the wells along with their locations and areas irrigated in 2008.

Table 14: Irrigation Wells on South Campus: Farms

Facility	Well ID	Area Irrigated in 2008 (acres)
Agronomy	Quonset	6.5
Agronomy	Soils Farm	0
Grounds – EDC	EDC	4
Horticulture	Domestic Well	11
Horticulture	Irrigation Well	50.6
Inland Lakes	Lake #1	8.1
Plant Pathology	Irrigation Well	4
Upper Fish Lab	#1-New-West	0
Upper Fish Lab	#2-Old-East	0
Vet Farm - Bennett	Bennett Farm	0

Source: MSU Land Management Office, Personal Communication, 10/15/2009

Consumption of Water

It is difficult to determine the exact volume of water that is used for irrigation. As mentioned earlier, on the Main Campus several areas are irrigated using water from the distribution system fed by the University wells. No sub-metering of buildings is conducted, so it is not possible to distinguish between volumes of water used for irrigation from those used for drinking and bathroom and laboratory use. For example, the grounds surrounding the Plant and Soil Sciences building and the Horticulture Demonstration Gardens are irrigated using water obtained from a General Fund Building, and as such would not be reported as irrigation water use, but as water consumed by a specific “building”.

As mentioned earlier, the Golf Courses, Turf Grass, Plant Pathology, Plant Pathology-East, Tree Research, and Horticulture - Sand Hill Farm are irrigated using water from the main University water system. Water is supplied directly from the wells before it enters the reservoir. As such, the total volume of University well water used directly for irrigation can be determined using the equation:

$$\text{Volume} = (\sum Q_n - Q_r) t$$

where Q = flow rate from each individual well

n = well number

r = Flow rate from the reservoir

t = time.

Using this equation and data from the “Physical Plant Division 2008-2009 Annual Report”, the average volume of water pumped directly from the main University well system and used for irrigation and research was 393,000 KGAL during 2004-2008. This is roughly 20% of the annual

water consumption on campus for 2004-2008. The complete data set is presented in Appendix A.

One source of error in this data set may include losses of water in the distribution system between the wellhead/pump and the outlet of the reservoir. Another source of error may be due to inaccuracy of the meters. Because there are no meter validation or leak detection programs currently in place, we are not able to assess the magnitude of these errors.

The irrigation wells on both the Main and South Campus; Research Farms are not metered.

Volumes of water used for irrigation are estimated from the following equation:

$$\text{Volume} = (t)(Q)(n)$$

where, t = the time (h) each sprinkler head is turned on

Q = the flow rate from each sprinkler head (gal/h)

n = number of sprinkler heads.

The flow rate, Q , is not measured; the rate is obtained based on manufacturer specifications provided at the time of purchase. The flow rate will vary due to differences in a number of parameters, including the pressure at the well and in the nozzle, length of hose, and in the size of the sprinkler nozzle aperture. The aperture is likely to decrease in size with time due to the deposition of minerals near or in the nozzles or clogging of the aperture by organic material. Another challenge in accurately determining flow rates is that the irrigation well water may be used for other purposes. For example, the well at Horticulture (identified as “Domestic”) feeds both the irrigation line and the plumbing for domestic toilet flushing and hand-washing.

The estimated average annual volume of water consumed from irrigation wells during the period from 2004 to 2008 for irrigation using water from the irrigation wells is documented in Table 15, and a complete set of data is shown in Appendix G. It should be noted that this list includes irrigation wells on both Main Campus and South Campus: Research Farms.

Table 15: Water Consumption from Irrigation Wells

Facility	Well ID	Average Annual Usage (KGAL)
Agronomy	Quonset	101
Agronomy	Soils Farm	-
Grounds – EDC	EDC	843
Grounds - IM East	IM East	6,163
Horticulture	Domestic Well	541
Horticulture	Irrigation Well	1,846
Inland Lakes	Lake #1	5,005
Plant Pathology	Irrigation Well	210
Stadium	Stadium	640
Upper Fish Lab	#1-New-West	259
Upper Fish Lab	#2-Old-East	1,589
Vet Farm - Bennett	Bennett Farm	59
	Total	18,255

Source: MSU Land Management Office, Personal Communication, 10/15/2009
(Complete data presented in Appendix G).

Based on this data, the average volume of water pumped annually from the irrigation wells is estimated to be 18,300 KGAL per year, amounting to roughly 1% of the total water use on campus.

It should be noted that water used for irrigation on the South Campus Farms is necessary for research, extension and demonstration. Very little irrigation water is used on the South

Campus: Research Farms for general production and activities. (MSU Land Management Office, Personal Communication, 7/2/2010)

The average volume of Red Cedar River water consumed (during the period of time from 2004 to 2008) for irrigation is 17,522 KGAL/yr. The volume is determined from the average of the annual volume pumped from the Red Cedar River and metered at the “well” designated Red Cedar – SW. This amounts to approximately 1% of the total water used on campus.

Summing the volumes from the irrigation well, the Red Cedar River, and main well system together (Research and South Campus Farms), the total annual water consumption on the MSU campus for irrigation is approximately 429,000 KGAL and roughly 22% of total water use on campus.

Conservation Measures

The Land Management Office oversees the irrigation of South Campus: Research Farms while Physical Plant-Landscape Services manages irrigation on the Main Campus. Numerous conservation measures have been implemented across campus. These include, but are not limited to: low mow and water conserving turf, expanded use of drip irrigation, drip lines and a computerized system. A computerized system allows for a more advanced and accurate system for irrigation, and also allows for leak detection and automated shutdown. A complete list of conservation practices is provided in Appendix G.

Recommendations

Because the irrigation sources are either not metered or the metered data is not collected and evaluated, if additional water conservation measures for irrigation are to be implemented, it is advisable to better quantify the volumes of water used for irrigation. Therefore, it is recommended that a metering program be put in place. This includes metering of irrigation wells, as well as sub metering of buildings that provide domestic water for irrigation purposes.

Residence Hall Water Consumption

Residence Halls at MSU are divided into six areas or “neighborhoods”: Brody, East, Red Cedar, River Trail, South, and West Circle. In addition there are four University apartment areas: Spartan Village, Faculty Bricks, Cherry Lane and University Village (newly opened 2007). Eighty-eight buildings came to the end of their expected useful life between 2002-2009 and have been demolished in Spartan Village and Old University Village area. Numerous renovations of residence halls have been completed in the last 10 years, including Shaw (residential wings), Snyder-Phillips (residential wings and The Gallery Cafeteria), Mason Abbot (residential wings) and Holden (center section) and Mayo Hall. Hubbard Hall (center section), Emmons Hall and Brody Building were renovated during Summer 2010.

The most significant and most recent renovation is that of the center building in Brody Complex, which will be completed by September 2011. Once complete, Brody Complex will be served by East Lansing/Meridian Township water treatment plant. University Village was opened in 2007 and is on East Lansing/Meridian Township water. Cherry Lane and Faculty Bricks Apartments are due to be closed and demolished beginning in summer of 2011. Details regarding these and other renovations will be discussed later in this report.

Use of residence halls during the summer months is highly variable and this complicates the interpretation of water consumption data. . For example South Complex residence halls are used extensively for sports camps. Case and Wilson halls are currently used for Academic and Parent Orientation Programs (AOP/POP). Snyder-Phillips and Owen Halls are used extensively

for summer school and conferences. East Complex halls are also used extensively for summer conferences, (two of the East Complex Halls were used in Summer 2009 and 2010 for conferences and two were off line for a majority of the both summer sessions because of construction activities). Hubbard Hall was not used in Summer 2010 because of center section renovations.

As of May 2010, all 24 residence halls are metered for water consumption. However, until August 2007, the only halls that were metered were: Brody, Williams, Campbell, Yakeley and Gilchrist, Mason and Abbot, Rather, Landon, Bryan, Emmons, Bailey, Shaw, Owen, and Butterfield. Meters were installed in Snyder-Phillips and Van Hoosen Halls in August and November 2007, respectively. Prior to the installation of meters in Holden, Wilson, Case, Wonders, McDonel, Hubbard, Akers, Holmes, and Mayo, water usage in these buildings was estimated by Physical Plant. Estimates for Holmes, Wonders, and Mayo have been included in our analysis. Based on the data reported for the period from 2004 to 2008 (i.e., the data that was available when this report was begun), residence hall metering data has been extensively analyzed. Eighteen (18) of the 24 residence halls on the Michigan State (MSU) campus have water consumption data available for this time period. Data for Van Hoosen Hall and Snyder-Phillips became available for 2008. Average water consumption for each of the residence halls is presented in Table 16 data was averaged for the period from 2004 to 2008. Data from Snyder-Phillips and Van Hoosen Halls for 2008 were included.

Table 16: Average Water Consumption for Residence Halls

Resident Hall	Average Water Consumption (KGAL)				
	Yearly	School Term (Sept-April)		Summer Term(May-Aug)	
		Total Average	Monthly Average	Total Average	Monthly Average
Akers	NA	NA	NA	NA	NA
Holmes	29721	25116	3140	4605	1151
Holden	NA	NA	NA	NA	NA
Hubbard	NA	NA	NA	NA	NA
Wilson	NA	NA	NA	NA	NA
Wonders	16861	13696	1712	3165	791
McDonel	NA	NA	NA	NA	NA
Shaw*	17338	13993	1749	3345	836
Case	NA	NA	NA	NA	NA
Mason/Abbot*	10252	8156	1020	2096	524
Snyder-Phillips†	10101	8255	1032	1845	461
Owen*	19839	14655	1832	5185	1296
Yakeley/Gilchrist*	10046	7801	975	2245	561
Armstrong	10389	6812	852	2223	556
Rather*	5822	4989	624	834	208
Emmons*	13093	8612	1077	4481	1120
Bailey*	14935	10502	1313	4433	1108
Bryan*	12925	9794	1224	3131	782
Butterfield*	4412	3871	484	541	135
Landon*	6950	6093	762	858	214
Campbell*	3331	2721	340	610	152
Mayo	2707	2144	268	228	57
Williams*	3493	3011	376	481	120
Van Hoosent†	1184	941	118	243	61
Totals	193400	151000		40500	

Source: Residential and Hospitality Services (RHS), Personal Communication, 2009 NA denotes residence halls that were not metered within the 2004-2008 timeframe. All halls listed above and marked with either an asterisk or dagger are metered; those with an asterisk were metered for the entire period from 2004-2008; those with a dagger were metered after 2007. Halls for which data are reported but are unmarked are not metered and the data reported are estimates from Physical Plant.

As shown in Figure 6, as one would expect, there is a linear relationship trend between water consumption and the number of residents in each hall. However, there is some variability as shown by the scatter in the data and the R-value.




Figure 6: Water consumption vs. number of Residents (Raw data provided in Appendix H)
Source: Residential and Hospitality Services (RHS), Personal Communication, 2009

Water Consumption

The metering data was evaluated and per capita water consumption rates were calculated for each residence hall. Per capita water usage rates were compared for residence halls with cafeterias versus residence halls without cafeterias. We attempted to determine why some buildings with fewer residents use more water on a per capita basis than others. A likely explanation is that some buildings have cafeterias while others do not. Another possibility is that some residence halls (namely, Holmes) have laboratories. Some residence halls also contain classrooms and academic offices (Holmes, Akers, McDonel, Hubbard, Wilson, Wonders, Case, Holden, Brody Building, and Snyder-Phillips). Snyder-Phillips, Holmes, Case, and Wilson

Halls all contain Living Learning Colleges, which increases the number of academic offices as compared to that in other halls. Several of the residence halls, including Case, Holden, and Wilson have several classrooms with capacities of 60-100 students and most have a large auditorium, which seats approximately 225.




Figure 7: Per Capita Data for Each of the Residence Halls

Source: Residential and Hospitality Services (RHS), Personal Communication, 2009

There are 14 residence halls on campus that have cafeterias. However, only 6 (Holmes, Landon, Owen, Shaw, Snyder-Phillips, Wonders, Yakeley/Gilchrist) of these halls have been metered since 2004. As such, the data for residence halls with cafeterias is limited compared to data obtained for residence halls without cafeterias (the list of cafeterias was found at eatatstate.com). Nonetheless, in general per capita water use is higher for residence halls that have cafeterias. The average per capita water use for residence halls without cafeterias was found to be 20.6 ± 8.2 KGAL/yr, while the per capita water use for residence halls with cafeterias was found to be 23.4 ± 6.1 KGAL/yr (\pm standard deviations).

Table 17 lists the per capita water usage for the residence halls for which data was available. It should be noted that four residence halls have extremely high per capita water use: Emmons, Bailey, Bryan, and Owen. The reason for the high consumption in Emmons, Bailey, and Bryan Halls is because prior to the summer of 2009 these halls had community bathrooms with old style tank urinals that have since been converted to low-flow 1/8th gallon urinals. The reason for the high consumption in Owen Graduate Center is unknown.

Table 17: Residence Hall Per Capita Water Usage

Residence Hall	Per Capita Water Usage (KGAL/person)
Holmes	25
Wonders	19
Shaw	20
Mason/Abbot	17
Snyder-Phillips	17
Owen	35
Yakeley/Gilchrist	22
Armstrong	23
Rather	14
Emmons	31
Bailey	36
Bryan	32
Butterfield	13
Landon	25
Campbell	14
Mayo	13
Williams	18
van Hoosen	16
Average	22
STDEV	7.5

Source: Residential and Hospitality Services (RHS), Personal Communication, 2009

Values were determined from annual data (including summer months) for the period of 2004-2008, except for Van Hoosen and Snyder-Phillips, which were not metered until 2007.

Effect of Renovations on Water Consumption

Major renovations of several residence halls are part of the MSU Master Plan. Brody Complex has been under construction for the last year and will be ready for the September 2010 school year. The goal of the plumbing renovations in this complex is to ensure that the buildings meet minimum LEED standards with the potential for LEED certification. Grey water reuse for toilet flushing is incorporated into the renovations of Brody Hall. By July 2009, tank urinal and low flow fixture renovations of the restrooms in all of Brody Complex Residential Buildings (Emmons, Bailey, and Bryan) were complete. Tank urinals, which flowed constantly, were replaced with low flow urinals. It is yet to be seen how these renovations have affected water consumption in these buildings since data is not available after 2008 for any of the buildings except Bryan Hall. However, in Bryan Hall water use dropped by more than fifty percent. Table 2 illustrates the reduction in water usage between 2007 and 2008, and between 2007 and 2009. As shown from the table, fixture upgrades have led to a significant reduction in water usage in Bryan Hall, the first of the halls to be fully renovated. Similar reductions are expected for the other Brody Complex halls.

Table 18: Bryan Restroom Upgrades

Bryan Restroom Upgrades

	2007-KGAL	2008-KGAL	2009-KGAL	2008 Percent Reduction	2009 Percent Reduction
January	1408	1498	549	NC	61
February	1482	1041	552	NC	63
March	1109	1029	399	NC	64
April	1638	1266	668	NC	59
May	1813	584	329	68	82
June	1773	214	14	88	99
July	191	59	100	69	48
August	490	330	300	33	39
September	1060	739	300	30	72
October	1295	562	NA	57	NA
November	1477	500	NA	66	NA
December	890	150	NA	83	NA

Source: Residential and Hospitality Services (RHS), Personal Communication, 2009

NC: Not calculated since the fixture replacements were completed until April 2008.

[Estimation of Water Consumption for Non-metered Residence Halls](#)

Using the per capita averages for water usage in residence halls, water consumption was estimated for the 6 residence halls that do not have meters. Since all six of the residence halls contain cafeterias, the 23.5 KGAL per resident average value was used. The estimated values were added to the metered data and it was determined that the water use for residence halls is approximately 336,000 KGAL per year. This number includes water use for the cafeterias.

Cafeteria Water Use

Cafeteria water use was estimated using the per capita data. New “cafeteria-less” water consumption was estimated for each of the 13 halls with cafeterias, by recalculating their water consumption rates using the number of residents and 20.6 KGAL per resident average. The difference between the estimated “cafeteria-less” water consumption and the water consumption rates already determined for the 13 residence halls is the estimated water use for cafeterias. Cafeteria water use is estimated to be approximately 28,000 KGAL per year.

Discussion

Some important issues arise when evaluating this data. Actual water consumption data (not estimated data) is lacking for six of the residence halls. Four of these residence halls are in the top five in terms of numbers of residents. If data for water consumption in these residence halls were available, it would make our analysis much more accurate and complete.

When the per capita values were calculated there were some interesting observations. For three of the residence halls in the Brody Complex; Emmons, Bailey, and Bryan, per capita water usage was nine or more KGAL/capita greater than the average. As mentioned earlier, the high consumption in these three residence halls is believed to be due to the type of urinals used in the community bathrooms. However, these residence halls have been renovated (July 2009) and it is believed that the renovations will decrease water consumption to normal levels. Table 18 illustrates this, as Bryan Hall shows a dramatic decrease in water consumption from renovations. As new data becomes available Emmons, Bailey, and Bryan should be monitored

to determine whether or not water consumption is decreased to average levels. Also, Owen Hall has the highest per capita water consumption. The reason for this is unclear, although higher rates for 2009 may be due to construction activities. Averages were found without removing these outlier data. This is because it was determined that removing the data does not significantly affect the overall average values.

Conservation Measures

The Residential and Hospitality Services (RHS) at MSU is very active in promoting and instituting water conservation measures. RHS is always seeking ways to conserve water while maintaining an enjoyable living experience for residents. Among conservation measures explored includes the installation of low flow shower heads and LEED-certified fixtures. Because of the state of water at MSU (water pumped from the wells contains a high iron and mineral content) it was found difficult to implement low flow shower heads because of clogging. However, low flow shower heads and other alternatives will continue to be explored, especially in cases where the water will be supplied by softened water from the East Lansing/Meridian Township Water Treatment Plant. The use of tray-less cafeterias has also been explored. It was also found that tray-less cafeterias are effective in small cafeterias as opposed to larger ones. A trial for a tray-less cafeteria was done at Yakeley and was found to be successful; implementing this in larger cafeterias is still being explored.

Another option that is being used on a trial basis is a pulper, which chops food waste with minimal additional water. The goal is minimize water use in the dish room and look for

potential opportunities to divert food waste from the landfill. A pulper has been installed in the Brody cafeteria and is under evaluation. In 2010-2011, a study will be conducted to evaluate the use of composting or anaerobically digestion of food waste.

The Master Plan calls for kitchen renovations in Case and Shaw Halls in the next five years. With these and all other renovations, appliances and processes are being studied to replace equipment and fixtures with water conserving fixtures that meet LEED and energy-star guidelines.

In 2005, reverse osmosis units were placed in each of the residence halls to meet the demand of residents for treated drinking water. However, these older units waste excessive amounts of water as only a fraction (typically 50-70%) of the water fed to the unit is fit for consumption. The remainder of the water is waste and is discharged to the sewer. In order to conserve water, these units have been replaced in fall 2010, with newer and improved filter technology, allowing 90-95% of the water treated to be used for human consumption. Brody Complex has been switched to East Lansing/Meridian Township water, eliminating the need for softening units in buildings and kitchens and the associated salts, along with reverse osmosis or filtration units in the hydration stations.

Along with the conservation measures that are being explored, other measures have been undertaken and have proven successful. Among these are using "Green" methods for cleaning, which use less chemicals and conserve water and are environmentally friendly. In cafeterias,

dishwashing units are now shut off in between meals; whereas in the past they were sometimes allowed to run. High use public area restroom renovations are currently in progress and are being completed on a regular basis. Furthermore, all remaining (un-renovated) residence halls are scheduled for renovations. (A complete listing is shown in Appendix H). As shown by the decrease in water consumption in Bryan Hall, these renovations could leave to a significant water reduction in residence halls. As of May 2010, water meters have now been installed in all residence halls, making it easier to assess water use in the residence halls.

Along with the conservation measures listed above, RHS has promoted decreased water bottle purchases at MSU. Upon entering the residence halls residents were given reusable water bottles and encouraged to refill water bottles at filling stations located in each residence hall.

Conclusions

Total water consumption was estimated using per capita data calculated from metered data. The total water consumption for residence halls (including cafeterias) is estimated to be 336,000 KGAL per year. Water consumption for cafeterias is estimated to be 28,000 KGAL per year. Water consumption for residence halls as a whole makes up for almost a quarter of the total water consumed on campus. The water consumption for cafeterias is relatively small compared to all water consumed on campus.

Recommendations

Since residence halls are and will continue to be a significant water user, conservation measures should continue to be explored. Since new water meter data will become available for all the residence halls, further evaluation of water consumption in these residence halls should take place.

Further investigation in some residence halls such as Owen Graduate Center, which has a high per capita water use, should also be completed.

Presently the cafeterias are not sub-metered; however, the kitchen in Brody Complex will be sub-metered as part of the ongoing renovations. Case and Shaw cafeterias will be sub-metered during planned renovations. This data should be carefully evaluated to better assess water consumption in the cafeterias and determine potential additional conservation measures.

General Fund and Athletic Buildings

The General Fund buildings are among the largest consumers of water on campus. This is not surprising due to high traffic volumes and bathroom and laboratory use. Although not all buildings on campus are metered, there is sufficient data on water usage for the General Fund buildings on campus to obtain a general picture of the consumption of water in these facilities.

Water is also consumed in the athletic buildings and complexes. Since athletic buildings are not supported from the General Fund they are discussed separately in this report.

General fund buildings

Using the data currently available, water usage in the General Fund buildings is tabulated in Table 19. The water consumption reported is the arithmetic average of the yearly consumption during the period from 2004-2008.

Table 19: General Fund Building Water Consumption

Bldg #	Bldg Name	Meter	Annual Water Usage (KGAL)
0055	KELLOGG CENTER		48560
0446A	VETERINARY RESEARCH CENTER - LARGE ANIMAL BARN	0446W1	46560
0086	PLANT & SOIL SCIENCES BUILDING	0086W1	44470
0189	REGIONAL CHILLED WATER PLANT NO. 1	0189W1	32130
0160	BIOMEDICAL PHYSICAL SCIENCES BUILDING	0160W1	29150
0178	PLANT BIOLOGY LABORATORIES	0178W1	12770
0132	ANTHONY HALL	0132W1	12350
170	VETERINARY MEDICAL CENTER	0170W1	9250
0081	ENGINEERING BUILDING	0081W1	7770

Table 19 Cont.

0203A	ENGINEERING RESEARCH COMPLEX	0203W1	6900
0068	LAUNDRY BUILDING	0068W1	6800
0186	FOOD SAFETY AND TOXICOLOGY BUILDING	0186W1	4570
0006	UNION BUILDING	0006W1	3960
0024	NATURAL SCIENCE	0024W1	3470
0212A	PAVILION FOR AGRICULTURE AND LIVESTOCK EDUCATION - HORSE BAR	0212W1	2450
0083	MSU COLLEGE OF LAW	0083W1	2060
0029	KEDZIE HALL (NORTH AND SOUTH)		1730
0003	OLIN MEMORIAL HEALTH CENTER	0003W1	1600
0084	COMMUNICATION ARTS & SCIENCES BUILDING	0084W1	1300
0080	BUSINESS COLLEGE COMPLEX (EPPLEY)	0080W1	1090
0002	BERKEY HALL		940
85	WHARTON CENTER	0085W1	900
0035	COMPUTER CENTER	0035W1	850
0128	NISBET, STEVEN S., BUILDING	0128W1	790
0087	PUBLIC SAFETY	0087W1	770
1121	MUSIC/MUSIC PRACTICE	1121W1	740
0027	PSYCHOLOGY BUILDING	0027W1	620
0005	HUMAN ECOLOGY	0005W1	570
0163	CHEMISTRY	0163W1	550
0177	PACKAGING	0177W1	520
0171	FOOD STORES	0171W1	430
0214	RADIOLOGY BUILDING	0214W1	430
0154	MANLY MILES BUILDING	0154W1	330
91	FARRALL AGRICULTURAL ENGINEERING HALL	0091W1	300
0219	PARKING RAMP NO.1 SHAW LANE (NEW)	0219W1	270
0060	CENTRAL SERVICES BUILDING	0060W1	80
2000	CLINICAL CENTER	2000W1	40

Source: Power Plant, Personal Communication, 12/23/2009

The data presented in Table 19 is given in KGAL/yr and are listed from the building with the highest water consumption to that with the lowest. There are several unexpected findings. For example, we did not expect water consumption in the Chemistry Building to be so low because of the many laboratories. This can be explained, however, because the piping in the Chemistry Building is not completely metered. It has been determined that only the North addition of the Chemistry building is metered, thus, the unexpected low water consumption. On the contrary the Plant and Soil Sciences Building, a building with many laboratories, consumes approximately 90 times the amount of water consumed by the Chemistry Building. It is unclear why this is the case.

Several changes in water use will occur in the future. For example, the Kellogg Center, which is the building with the highest water consumption, will be purchasing water from the East Lansing/ Meridian Township Water Treatment Plant in the near future.

Another forthcoming change is that there is a meter at the Diagnostic Center for Population and Animal Health (DCPAH) that was not being read by the Power Plant. However, personnel from the Power Plant will assume responsibility for this meter and data regarding the DCPAH building will be available.

It is also important to note that the Clinical Center building only has a meter in the new Radiology wing. The majority of the Clinical Center building is not metered.

These 37-metered buildings have a total annual water consumption of about 290,000 KGAL and account for 15% of the total water consumption on campus. Unfortunately, without metered data we do not have any way of estimating water consumption in the numerous unmetered buildings on campus. Water usage in these other buildings is therefore included in the “unaccounted for” category.

Athletic Facilities

Shown below in Table 20 is average annual water use for athletic facilities over the period of time from 2004 to 2008.

Table 20: Athletic Building Water Consumption

Bldg #	Bldg Name	Meter	Annual Water Usage (KGAL)
0058	SPARTAN STADIUM	0058W1	9960
0069	BRESLIN, JACK, STUDENT EVENTS CENTER	0069W1	4780
0059	MUNN, CLARENCE L., ICE ARENA	0059W1	2780
0056	JENISON FIELDHOUSE	0056W1	2220
77	FOOTBALL BUILDING	0077W1	1720

Source: Power Plant, Personal Communication, 12/23/2009

These five sports facilities are the most utilized on campus, featuring the facilities that house football, basketball, and hockey. The Intramural Sports buildings are not metered with the exception of Intramural East, which is metered, but according to Power Plant personnel the meter is not accurate. Spartan Stadium urinals previously ran year round. Urinals are now shut off between games unless there is a possibility of freezing (for games in November), and immediately after the season ends, water is shut off to the stadium and the stadium is winterized. It is not known how long this has been common practice for Spartan Stadium, but data from 2004-2008 suggest that there was no change in policy over that time as water consumption for Spartan Stadium only increased from 2004-2008. The overall water consumption for these 5 facilities is about 21,500 KGAL and 1% of water use on campus. Earlier reports did imply that urinals at the Spartan Stadium were allowed to run 24/7 during the season, but later reports dispute this original claim.

Bathrooms

Restroom use was evaluated in many general fund buildings on the MSU main campus. To estimate the amount of water used, the janitorial staff recorded the amount of paper towel rolls used for each restroom. It was assumed that on average 24 inches of paper towel is used per person per restroom visit. The total number of flushes were estimated from paper towel usage, assuming that paper towel use can be correlated with water use in the restrooms. Volumes of 3.5 gal/flush for toilets and 3 gal/flush for urinals were used to calculate water usage.

Estimated annual cost savings were estimated for each building. The annual savings were estimated by determining the predicted water saved if the plumbing fixtures were to be replaced with low flow technology (using 1.6 gal/flush for toilets and 0.125 gal/flush for urinals). Water was assumed to cost \$3.0321 per KGAL to produce (Gus Gosselin, 4/20/2010). A sample calculation is included in Appendix I. It is important to also take into account the onetime cost for fixture upgrades.

Shown in Table 21 are the top 11 buildings analyzed with respect to potential savings by upgrades. Data in this table are sorted based on highest to lowest savings. These buildings were chosen because the data for these buildings were found to be reliable and complete.

The estimated one-time costs for upgrades are listed in the Appendix I. Every estimated bathroom upgrade has a return on investment of less than 2 years.

Table 21: Estimated Water Savings from Bathroom Upgrades

Bldg #	Bldg Name	Annual Paper Towel Use (Rolls)	Estimated Savings	Estimated Water Savings (KGAL)	Rank Based on Potential Savings	Rank Based on Metered Water Usage
78	Wells Hall	282000	\$19,720	6500	1	NA
84	Comm. Arts	165600	\$12,785	4200	2	25
169	Intl. Center	150000	\$8,446	2800	3	NA
163	Chemistry	236400	\$8,365	2760	4	35
327	Fee (East)	144000	\$7,717	2550	5	NA
168	Biochemistry	122400	\$7,154	2360	6	NA
79	Bessey	132000	\$6,883	2300	7	NA
178	Plant Biology	170400	\$6,619	2200	8	6
170	Vet Clinic (North)	159600	\$5,916	1950	9	9
183	Life Sciences	97200	\$4,465	1500	10	NA
47	Olds Hall	84000	\$2,369	800	11	NA

Source: Gus Gosselin, Personal Communication 6/18/2010

The last column in the table shows the water consumption rank by metered data. High bathroom use does not seem to correlate to high water use within the buildings. Moreover, many of these buildings with high bathroom use are not metered.

It should be noted that tank type urinals had been installed in the Auditorium, Kresge Building, and Student Services Building. They were all replaced in 2009/2010 with 1/8 gallon per flush urinals. Since these buildings do not have water meters we cannot evaluate the effect of these renovations.

Labs

Below is a list of the top 25 General Fund buildings with respect to the number of laboratory and laboratory research support rooms in each building.

Table 22: Top 25 Buildings with Respect to Number of Labs

Rank Based On # of Labs	Bldg #	Bldg Name	Labs	Metered Rank
1	160	BIOMEDICAL PHYSICAL SCIENCES	183	5
2	28	GILTNER HALL	182	NA
3	86	PLANT AND SOIL SCIENCE	139	3
4	178	PLANT BIOLOGY LABORATORY	137	6
5	163	CHEMISTRY	131	35
6	81	ENGINEERING BUILDING	102	10
7	168	BIOCHEMISTRY	95	NA
8	24	NATURAL SCIENCE	94	17
9	179	FOOD SCIENCE	83	NA
10	183	LIFE SCIENCE	79	NA
11	215	DCPAH - DIAG CNTR POP ANIM HEALTH	79	NA
12	170	VETERINARY MEDICAL CENTER	78	9
13	132	ANTHONY HALL	77	7
14	186	FOOD SAFETY AND TOXICOLOGY	68	14
15	0203A	ENG RESEARCH COMPLEX	64	11
16	180	NATURAL RESOURCES	55	NA
17	164	CYCLOTRON	47	NA
18	0181A	CENTER INTEGRATIVE PLANT SYS - LAB	46	NA
19	327	FEE HALL	31	NA
20	27	PSYCHOLOGY BUILDING	27	33
21	84	COMMUNICATION ARTS	25	25
22	144	ERICKSON HALL	25	NA
23	0473B	POULTRY-LAB BLDG	25	NA
24	91	FARRALL AG ENGINEERING HALL	23	40
25	201	CLINICAL CENTER - OFFICE/LAB WING	22	NA

Source: Facilities Planning and Space Management, Personal Communication, 5/3/2010

Also listed in Table 21 is the ranking of water use from the metered data. Out of the 13 buildings on the list that are metered, 10 of these buildings are also in the top 25 of metered buildings with respect to water use. This list seems to indicate that high lab use correlates with high water consumption. Figure 7 shows the correlation between the number of labs and water consumption. As shown, there is a linear trend between high water consumption and buildings with a large number of laboratories. The value of R^2 shows how well the data follows a linear model. R^2 values range from 0 to 1, with an R^2 value of 1 showing a perfect linear fit. With an R^2 value of 0.6, this data suggest that there is not a strong correlation, but a significant correlation between water consumption and the number of laboratories. The more laboratories a building tends to lead to higher water consumption.




Figure 8: Water Consumption with Respect to Laboratories

Recommendations

Buildings that are listed in Table 21 have been recommended for restroom upgrades, based on water and cost saving estimations (Gus Gosselin, personal communication, 2010).

It is recommended that buildings be metered for future study to determine accurate water usage. The buildings that should be given high priority for the installation of water meters are listed in Table 23.

Table 23: Buildings That Should be Metered for Future Study

Building	Ranking Based On	
	Potential Savings from Bathroom Upgrades	Number of Laboratories
Erickson	NA	22
Fee	5	19
Biochemistry	6	7
Life Science	10	10
Chemistry	4	5

Four of these five buildings listed are in Table 23 as being recommended for bathroom upgrades, and all of them are on the top 25-laboratory list. As stated earlier only a portion (North addition) of the Chemistry Building is metered making it necessary to meter the rest of the building. In addition to these 5 buildings, any buildings that are on the list of 11 buildings suggested for significant bathroom upgrades or any buildings that are in the top 10 of laboratories should be considered for metering if not already metered.

The top ten buildings that are currently metered that should be studied to determine the reasons for the high water consumption are shown in Table 24.

Table 24: Top 10 Buildings to Study

Building	Meter Rank	Ranking Based On Potential Savings from Bathroom Upgrades	Number of Laboratories
Kellogg Center	1	NA	NA
Veterinary Research Center	2	9	12.
Plant and Soil Sciences	3	NA	3
Biomedical Physical Sciences	4	NA	1
Plant Biology	6	8	4
Anthony Hall	7	NA	NA
Spartan Stadium	8	NA	NA
Engineering Building	10	NA	6
Natural Science	17	NA	8
Communication Arts	25	2	21

Two other buildings not on the list in Table 24 that should be evaluated are Giltner Hall and the Clinical Center. Giltner Hall should be evaluated because of the significant number of labs located within (Rank 2 on number of laboratories) and therefore may have significant water consumption. An Omni meter was recently installed in 2010 for Giltner Hall and this data should be evaluated to assess water usage. Another building to consider is the Clinical Center. The Clinical Center is expected to show a significant amount of water use, however only the Radiology wing is metered. Therefore, the water consumption for the Clinical Center is likely to be undervalued, and another meter may be needed to obtain an accurate account of water use for the Clinical Center.

Miscellaneous

Autoclaves

Autoclaves are used in laboratories throughout campus to sterilize equipment. Autoclaves utilize saturated steam in the sterilization process, thus resulting in the loss of water and water consumption. It is believed that modifications can be made to autoclaves to reduce water consumption by 62%. There is no current supplied to this report listing autoclaves or autoclave use on campus.

Reverse Osmosis Units

Reverse Osmosis (RO) is a pressure based membrane filtration process used to treat water. RO is a relatively new technology and vast improvements have been made in the last five years. Older RO units often have a low efficiency of water production, typically around 60 % production of clean water. The remaining 40% is the “reject” stream and disposed of into the sanitary sewer. Currently, new systems can run at 90% or higher efficiency for the production of clean water. It is believed that switching to newer systems can help save money as these units use less energy and consume less water. MSU currently uses RO in some of its buildings to treat both drinking and laboratory water. A list of general fund buildings with RO units is shown below in Table 25.

Table 25: List and Location of RO units

<u>Building</u>	<u>Location/Room #</u>
Anthony	MR B-263
Bio Med Phys Sci.	Sparty's
Biochemistry	Penthouse
Chemistry	B-19 MR
CIPS	2nd Fl. Cust.
Clinical Ctr	Mr #AB-13
Clinical Ctr	Sparty's
DCPAH	Bas. MR #31
Eng. Res. Comp.	MR 3200
Engineering	MR #B-120
Engineering	MR # Penthouse S.W.
Engineering	Sparty's
Erickson	Sparty's
Giltner	West Penthouse #370A MR
Giltner	MR #35
Intn'l Center	Sparty's
Library	Sparty's
Life Sci.	S. Pent.
Munn	MR #24
Plant & Soil Sci.	MR A-51
Plant Bio	MR # S-28
Un. Res. Cont.	MR
Vet Med	MR #A-50
Vet Med	Rm. G138E (Purification System)

Source: Gus Gosselin, Personal Communication, 20/4/2010

It is important to note that the capacity and age of the systems are unknown. Also, this list may be incomplete and other RO units may be operational. One example being the Biomedical Physical Science Penthouse RO filtration unit. This unit is not on the list, but is believed to have a high water consumption (Personal Communication, Pat Curry, 9/28/2010).

Although many of the residence halls used RO units, many of these units have been replaced with newer filtration technology as discussed in the section specific to Residence Halls. A list of

residence halls and the RO units that were in place at the start of this project (Fall 2009) is shown in Table 26.

Table 26: List of RO Units in Residence halls

Building	Location/Room #	RO unit	Make	output
Akers	B-38 West Lobby DF	BP 3S Plus	Culligan	15.5 gph
Armstrong	MR C-1 lobby DF	BP 3S Plus	Culligan	15.5 gph
Bailey	MR C-1 lobby DF	BP 3S Plus	Culligan	15.5 gph
Bryan	MR C-1 lobby DF	BP 3S Plus	Culligan	15.5 gph
Butterfield	MR C-1 lobby DF	BP 3S Plus	Culligan	15.5 gph
Case Hall	MR 46A North utility sink laundry	BP 2L Plus	Culligan	25 gph
Emmons	MR C-1 Off Line	renov now	Culligan	
Holden	MR G-48 East lobby faucet main	BP 2L Plus	Culligan	25 gph
Holden	Sparty's	BP 2L Plus	Culligan	25 gph
Holmes	1st Fl. Comp. East lobby	BP 2L Plus	Culligan	25 gph
Holmes	1st Fl. Comp. West lobby	BP 2L Plus	Culligan	25 gph
Holmes	Sparty's	BP 2L Plus	Culligan	25 gph
Hubbard	MR G-75 N Hubb DF	renov now	Culligan	
Mas./Ab	C114B Abbott lobby	BP 2L Plus	Culligan	25 gph
McDonel	MR #B-8-A E lobby	BP 2L Plus	Culligan	25 gph
McDonel	MR #32A W lobby	BP 2L Plus	Culligan	25 gph
Owen Grad	Bas. B-1 basement center area	BP 2L Plus	Culligan	25 gph
Rather	MR C-1 lobby lobby DF	BP 3S Plus	Culligan	15.5 gph
Shaw Hall	Rm 106 lobby East	BP 3S Plus	Culligan	15.5 gph

Table 26 Cont.							
Sny/Phi	Bas. MR lobby Phillips lobby			BP Plus	2L	Culligan	25 gph
Sny/Phi	Sparty's			BP Plus	2L	Culligan	25 gph
Wilson Hall	MRR West W109			BP Plus	2L	Culligan	25 gph
Wonders Hall	B-2	North Lobby	Utility sink laundry	BP Plus	2L	Culligan	25 gph
Mayo Hall	239			ac	30	Culligan	30 gpd
Mayo Hall	225			ac	30	Culligan	30 gpd
Mayo Hall	325			ac	30	Culligan	30 gpd
Mayo Hall	339			ac	30	Culligan	30 gpd
Campbell	G-29			ac	30	Culligan	30 gpd
Campbell	G-11			ac	30	Culligan	30 gpd
Landon	G-11			ac	30	Culligan	30 gpd
Yakeley	E-54			ac	30	Culligan	30 gpd
Yakeley	E-53			ac	30	Culligan	30 gpd
Gilchrist	W-3			ac	30	Culligan	30 gpd
Williams	C-3			ac	30	Culligan	30 gpd
Williams	C-12			ac	30	Culligan	30 gpd
Williams	211A			ac	30	Culligan	30 gpd
Williams	261A			ac	30	Culligan	30 gpd
Williams	311A			ac	30	Culligan	30 gpd
Williams	361A			ac	30	Culligan	30 gpd

Source: Diane Barker, Personal Communication, 6/23/2010

The majority of these units are small units used to produce drinking water for residents. It is also important to note that all of these systems are to be replaced with alternatively efficient filtration devices by October 2010. A complete list is found in the Appendix J.

Considering the potential financial and energy savings of new RO units, it is recommended that large systems (whose age and size are not known) be surveyed to determine the age and size of each system so that action can be taken accordingly. An example of how upgrading to a new RO unit can save water and money is shown in Table 27.

Table 27: RO Evaluation

Efficiency of RO System (percent recovery of clean water)	50	90
Clean Water Produced (GAL) per KGAL	500	900
Water Lost (GAL) per KGAL produced	500	100
Expenditure per KGAL produced (\$)	1.52	0.30
	Savings (\$) per KGAL produced	1.21

Calculations are shown in Appendix J.

According to Crittenden (2005) the recovery of clean water for RO systems ranges from 50% to 90%. The upper and lower limits have been used to show the potential financial savings for high efficiency RO units. Using the universal cost of water for the MSU campus of \$ 3.0321 per KGAL the savings from the installation of a high efficiency RO system vs. a low efficiency RO system is \$1.2128 per KGAL. Therefore, if a RO unit on campus treats 1 MGAL of water per year (0.06% of total water pumped on campus) the total savings in water would be \$ 1,212.8. If a high efficiency RO unit were to cost \$6,000 the payback period for this system would be roughly 4.8 years.

Flushing the Distribution System

Once a year water is used to flush the well mains (well piping) on campus. This is done for sanitary reasons and maintenance. It is estimated that flushing uses 6,000 KGAL of water annually.

Every other year the distribution mains are flushed. It is estimated that every other year 4,000 KGAL of water is used (Doug Macdonald, Personal Communication, 2/1/2010).

Summing both of these volumes used for flushing to obtain a maximum annual water volume for flushing yields a total of 10,000 KGAL. This is only 0.5% of the overall water consumption on campus.

Leak Study

Based on numerous discussions with various personnel, it appears that there has not been a leak study performed on the distribution system at MSU in the last several decades. If one was performed, the report no longer exists and the results are unknown. While major leaks are more easily identified and repaired, it is smaller leaks that may go undetected for years. Over time these small leaks can add up and lead to a sufficient waste of water (AWWA, 2009). Table 28 shows an example of how a leak study can help save money and water.

Table 28: Leak Study

Cost for Leak Study (\$)	20,000
Water saved per year (KGAL)	1700
Money Saved Per Year	5,154.57
Payback Period (Years)	4

If the leak study has a one time cost of \$20,000 and helps saves 1700 KGAL of water per year (0.1% of total water pumped by MSU), the annual savings based on the universal MSU cost of water of \$3.0321 per KGAL would be \$5,154.57 per year. This yields a payback period of only 4 years.

Water Use Summary

Below is a sample pie chart showing the distribution of water on campus. A baseline of 1,916,200 KGAL was used for the total amount of water pumped from the wells on campus. This value was attained from averaged data from 2004-2008, and Table 29 shows the contribution of water supplied.

Table 29: Water Supply

	Total Water Supplied(KGAL)
Pumped from 18 Main Wells	1916200
Pumped from Irrigation Wells	18255
Pumped from Red Cedar	17522
Purchased	5200
Total	1957177




Figure 9: Water Consumption Distribution

Table 30: Total Water Consumption

	KGAL	% of Total
Power Plant	411,000	21
Chilled Water	133,300	7
Irrigation (Irrigation Wells) and Red Cedar	36,000	2
Research/South Campus Farms	393,000	20
Residence Halls	353,000	18
General Fund Buildings	290,000	15
Athletics Buildings	21,500	1
Flushing (well mains annually)	6,000	0.3
Flushing (Distribution mains every other year)	4,000	0.2
Water Sold From MSU	17,400	1
Water Bought For MSU (Not Main Wells)	5,200	0.3
Unaccounted For	286,777	15
Total	1,957,177	

As shown from this data water on the MSU campus is primarily used by five main sources. These are: Power Plant, South Campus: Research Farms, Residence Halls, General Fund Buildings, and Chilled Water. These five sectors are estimated to account for 81% of the water consumption at MSU.

It is important to note that 15% of water use is not accounted for. This error is believed to be the result of more than one problem. Firstly, it is believed and assumed that there will always be some inaccuracies with respect to meters. Another problem is that not all buildings on campus are metered, thus the General Fund building consumption is estimated to be undervalued. Lastly, the possibility of leaks in the distribution system could lead to unaccounted for water.

Summary of Recommendations

The recommendations that arose from this report have been divided into four sections:

Preventative/Maintenance

Monitoring/Data Collection

Updating Equipment

Further Study and needs

In order to build a sustainable and economically-efficient water system, a feedback loop needs to be developed with oversight of the entire water supply system, from the point of pumping from the wells to the release of the water into the sewer system or on land (irrigation) given to a single individual or office. In the same way that the Office of Campus Sustainability monitors energy consumption in buildings, water consumption needs to be monitored and evaluated on a regular basis. If MSU is serious about developing a comprehensive strategy to achieve efficient use of energy, steam, and water, it is imperative that the diffuse authority be placed in a central office.

Preventative Maintenance

At present, there is no clearly defined program for maintaining and replacing water meters. It is, therefore, recommended that a water meter maintenance and renewal program be developed. The responsibility for maintaining, scheduling maintenance, and assessing water meters needs to be designated. Meters should be checked, cleaned and calibrated every 7 to 10 years (Satterfield, Zane, P. E., and Bhardwaj, Vipin Water Meter Tech Brief). Because the water at MSU is high in mineral content, maintenance is critically important to ensure proper

operation of the meters employed on campus, and the integrity of the data obtained. As discussed earlier in the section of this report on meter maintenance, a study conducted by the Physical Plant showed that with increased maintenance and meter replacement, the accuracy of the well meters improved significantly.

Equipment Installation and Replacement

The water usage in the North Sub-station is anticipated to be high, although the exact amount is unknown since it is not metered. However, as the pumps are water cooled, they should be evaluated to determine if newer, more energy- and water-efficient pumps could replace the existing pumps. It is important to develop such a plan for replacement so that when money becomes available for such efforts, the project can be mobilized quickly.

A replacement program should be developed to replace all water meters that do not meet current specifications.

At present, none of the sources for irrigation are metered. If water consumption for irrigation is to be fully evaluated, it is recommended that a metering program be put in place. This would include metering of irrigation wells, as well as sub metering of buildings that provide domestic water for irrigation purposes. To maintain the integrity of these meters a maintenance plan should also be put in place to manage and secure the validity of the meter system.

It is recommended that select General Fund buildings be metered to determine accurate water usage. The buildings that should be given high priority for the installation of water meters are listed in Table 23. They are included in this table because they have a large number of high-use restrooms or a large number of laboratories, and are expected to have significant water consumption.

Table 23: Buildings That Should be Metered

Building	Ranking Based On	
	Potential Savings from Bathroom Upgrades	Number of Laboratories
Erickson	NA	22
Fee	5	19
Biochemistry	6	7
Life Science	10	10
Chemistry	4	5

Four of these five buildings listed are in Table 18 as being recommended for bathroom upgrades, and all of them are on the top 25-laboratory list. As stated earlier only a portion (North addition) of the Chemistry Building is metered; given the large number of laboratories, it would be prudent to meter the rest of the building.

If funding allows, additional metering of any of the unmetered buildings that have been suggested for significant bathroom upgrades or any buildings that are in the top 10 in terms of the number of laboratories should be considered. Metering will assist with future planning in terms of restroom renovations or other conservation measures.

Another building that should be metered is the Clinical Center. The Clinical Center is expected to use a significant amount of water, however only the Radiology wing is metered. Therefore, the water consumption for the Clinical Center is most likely significantly undervalued.

Buildings that are listed in Table 21 are recommended for restroom upgrades, based on water and cost saving estimations. Once upgrades are completed, these buildings should be metered and consumption should be monitored to determine the cost-effectiveness of these renovations and their return on investment. Such data is important for evaluating future bathroom upgrades and similar renovations.

In particular bathroom upgrades should be considered. Toilets that were installed pre 1990 can consume 3.5 gallons per flush while urinals installed before 1990 consume over 3 gallons per flush. These toilets can be retrofitted to be reduced to 1.6 gallons per flush for toilets and less than 1 gallons per flush for urinals. Also all tank type urinals should be replaced, specifically in Giltner Hall.

Monitoring

Metering is the best way to determine water use, therefore accurate metering is the best way to document water consumption on MSU's campus. However, unless the data is routinely evaluated, its collection serves little purpose. We recommend that the data be collected and evaluated in the same way that energy consumption data is evaluated. In this way, outliers

would be identified and the reason for the unanticipated water consumption could be addressed by either maintenance or equipment replacement.

Within the last year, meters have been installed in all residence halls. As these water consumption data become available, further evaluation of residence halls should take place. For example, some residence halls, such as Owen Hall, show higher than average per capita water use. Water usage in Owen hall and other halls (including Bryan, Emmons, and Bailey) that appear to have above average per capita usage should be further investigated. Recent renovations of Bryan Hall have resulted in a significant decrease in water consumption. Now that Emmons and Bailey Halls are also renovated and meters have been installed, it would be prudent to monitor their water consumption to determine if similar reductions have been attained.

Considering the potential financial and energy savings of new RO units and retrofitted autoclaves, it is recommended that all RO systems (whose age and size are not known) and autoclaves are surveyed to determine the age and size of each system so that appropriate action can be taken. It is also recommended that the Office of Campus Sustainability be given the authority to collect and maintain data on the location, age, specifications, and water consumption data for all RO units and autoclaves on campus.

Future Studies

At present we are unable to benchmark the water usage in the chilled water facility to determine if it is reasonable or not. As such, a study to determine the efficiency of the chilled water system and whether there are newer technologies that can increase the efficiency of the system is recommended. However, considering that chilled water accounts for only approximately 7% of the total water consumption, efforts might be better focused in a higher use category.

Presently the cafeterias are not sub-metered; however, the kitchen in Brody will be sub-metered as part of on-going renovations. Case and Shaw cafeterias will be sub-metered during planned renovations. This data should be carefully evaluated to better assess water consumption in the cafeterias and determine potential conservation measures.

The top ten buildings that are currently metered that should be studied to determine the reasons for the high water consumption are shown in Table 24.

Table 24: Top 10 Buildings to Study

Building	Meter Rank	Ranking Based On	
		Potential Savings from Bathroom Upgrades	Number of Laboratories
Kellogg Center	1	NA	NA
Veterinary Research Center	2	9	12
Plant and Soil Sciences	3	NA	3
Biomedical Physical Sciences	4	NA	1
Plant Biology	6	8	4
Anthony Hall	7	NA	NA
Spartan Stadium	8	NA	NA
Engineering Building	10	NA	6
Natural Science	17	NA	8
Communication Arts	25	2	21

One other building that should be evaluated is Giltner Hall. New Omni Meters were recently installed (2010) and once water consumption data is available Giltner Hall should be included in the list of buildings to study. Giltner Hall has a significant number of labs (Rank 2 on number of laboratories) and therefore may have significant water consumption.

No leak studies have been performed in recent years on the distribution system at MSU. While major leaks are more easily identified and repaired, smaller leaks may go undetected for years. Over time these small leaks can add up and lead to a sufficient waste of water (AWWA, 2009). Therefore, it is recommended that a leak study be explored.

APPENDICES

Appendix A

Water Supply

Some parts of Appendix A are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix B

Water Bought

Some parts of Appendix B are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix C

Water Sold

Table 31: Complete List of Water Sold

State
Control
Laboratory

	Jan	Feb	March	April	May	June	July	August	Sept	October	Nov	Dec	GAL
200							58700	54300	58100	60500	5050	60300	342400
4							0	0	0	0	00	0	0
200	41200	4600	4620	8160	47700	56800	65500	62900	46700	52400	5430	46300	647600
5	0	00	00	00	0	0	0	0	0	0	00	0	0
200	56600	5220	5670	5640	61500	62400	59200	62100	61100	52500	5470	46900	682300
6	0	00	00	00	0	0	0	0	0	0	00	0	0
200	54700	5770	6410	6120	50500	51200	68000	67500	69200	62000	5750	45300	708900
7	0	00	00	00	0	0	0	0	0	0	00	0	0
200	46200	4560	4910	5250	66000	57200	60600	67300	50300	53000	4320	42100	633100
8	0	00	00	00	0	0	0	0	0	0	00	0	0
200	39500	3160	4150	4280	53600	52400	59300	65400	43500	42600	3470	44200	551100
9	0	00	00	00	0	0	0	0	0	0	00	0	0
												AVERA GE	644600 0

Credit
Union

	Jan	Feb	March	April	May	June	July	August	Sept	October	Nov	Dec	
200										31070	6940		
4							32300	26100	23500	0	0	30500	492500
200		2630	3030	2800			14540	16360	13640	10390	2510		
5	28000	0	0	0	26300	30300	0	0	0	0	0	24200	767800
200		2690	3250	3070		27220	23870	25690	11780		2570		116900
6	27500	0	0	0	86800	0	0	0	0	25300	0	28000	0
200		2420	2610	2730			16470	19630	20430	13710	2440		
7	28600	0	0	0	47300	82700	0	0	0	0	0	21800	984800

Table 31 Cont.	2008	27400	26000	27600	29000	30000	116000	130300	128300	102400	155900	5400	5600	783900
	2009	5600	4900	5900	24900	69400	82600	954000	97400	77000	74600	17700	11700	1425700
													AVERAGE	1026240
Credit Union Metered Irrigation		Jan	Feb	March	April	May	June	July	August	Sept	October	Nov	Dec	
	2004							277100	291000	312400	282700	43100	200	1206500
	2005	0	0	0	240	16080	13050							29370
	2006													1235870
	2007													
	2008													
	2009													
Michigan State Police		Jan	Feb	March	April	May	June	July	August	Sept	October	Nov	Dec	
	2004							473000	517000	554000	560000	591000	444000	3139000

Table	200	33000	2510	4900	6580	86100	96400	11390	12930	90300	92300	8450	47300	913000
31 Cont.	5	0	00	00	00	0	0	00	00	0	0	00	0	0
	200	61000	3720	7350	5600	62700	87800	17320	80200	94700	69000	6900	72400	936700
	6	0	00	00	00	0	0	00	0	0	0	00	0	0
	200	73100	7090	7000	8930	11120	11280	12810	12800	12800	14210	6500	92000	121050
	7	0	00	00	00	00	00	00	00	00	00	00	0	00
	200	14200	2840	9620	8070	81900	12900	23500	16800	17300	22000	9300	19900	550900
	8	00	00	00	00	0	0	0	0	0	0	0	0	0
	200	10400	1120	1910	1700	37600		20000	15000	16000	22400	9600	17500	204400
	9	0	00	00	00	0	86000	0	0	0	0	0	0	0
													AVERA	763100
													GE	0

USDA
Ag
research

	Jan	Feb	March	April	May	June	July	August	Sept	October	Nov	Dec	
200							16786	17299	16135	15242	1773	14736	
4							0	0	0	0	70	0	979350
200	14137	1426	1590	1292	14585	17237	14368	16401	17013	17008	1544	11821	181099
5	0	30	00	30	0	0	0	0	0	0	30	0	0
200	14361	1310	1665	2064	22584	18049	18980	19903	39302	14017	1524	11677	224515
6	0	70	30	10	0	0	0	0	0	0	10	0	0
200	11855	1065	1372	1444	18243	26053	39513	38726	23561	38908	2453	26930	287147
7	0	20	70	40	0	0	0	0	0	0	50	0	0
200	47385	1520	3461	3680	42093	33441	27685	32299	12689	14782	9681	10491	317173
8	0	80	20	70	0	0	0	0	0	0	0	0	0
200	10063	9940	1730	1008	14715	11352	12456	13097	18541			31137	151370
9	0	0	70	10	0	0	0	0	0	23060	3750	0	0
												AVERA	232260
												GE	8

Some parts of Appendix C are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix D

Meters

Table 32: Complete List of Meters

0313	BRODY HALL	0313W1	Apr-96
0024	NATURAL SCIENCE	0024W1	Jan-97
			May-
0128	NISBET, STEVEN S., BUILDING	0128W1	97
			May-
		0307W1	97
0308	WILLIAMS HALL	0308W1	Jun-97
0304	CAMPBELL HALL	0304W1	Jul-97
0306	YAKELEY AND GILCHRIST HALL	0306W1	Aug-97
0302	MASON AND ABBOT HALL	0302W1	Jan-98
0056	JENISON FIELDHOUSE	0056W1	Aug-98
		0077W2	Nov-98
0154	MANLY MILES BUILDING	0154W1	Feb-99
			May-
0005	HUMAN ECOLOGY	0005W1	99
0175	INTRAMURAL RECREATIVE SPORTS EAST	0175W1	Jul-99
0311	RATHER HALL	0311W1	Jan-00
0006	UNION BUILDING	0006W1	Aug-00
0305	LANDON HALL	0305W1	Aug-00
170	VETERINARY MEDICAL CENTER	0170W1	Aug-00
		0178W3	Oct-01
0160	BIOMEDICAL PHYSICAL SCIENCES BUILDING	0160W1	Jan-02
0086	PLANT & SOIL SCIENCES BUILDING	0086W1	Feb-02
0219	PARKING RAMP NO.1 SHAW LANE (NEW)	0219W1	Sep-02
			May-
0312	BRYAN HALL	0312W1	04
			May-
0314	EMMONS HALL	0314W1	04
			May-
0315	BAILEY HALL	0315W1	04
			Mar-
0310	BUTTERFIELD HALL	0310W1	05
0177	PACKAGING	0177W1	Apr-05
0058	SPARTAN STADIUM	0058W1	Aug-05
0171	FOOD STORES	0171W1	Aug-05
2000	CLINICAL CENTER	2000W1	Sep-05
0300	SNYDER AND PHILLIPS HALL	0300W1	Aug-07
0214	RADIOLOGY BUILDING	0214W1	Nov-07
0319	VANHOOSSEN HALL	0319W1	Nov-07
		0170W2	Nov-07
0013	MUSEUM	0013W1	Jan-08
0163	CHEMISTRY	0163W1	Jan-08

Table 32 Cont.		0203W2	Feb-08
		0170W3	Jul-08
			Mar-
0055	KELLOGG CENTER	0055W1	09
0083	MSU COLLEGE OF LAW	0083W1	Jun-09
0316	ARMSTRONG HALL	0316W1	Aug-09
0309	MARY MAYO HALL	0309W1	Sep-09
		0028W2	Nov-09
0028	GILTNER HALL	0028W1	Dec-09
0323	WONDERS HALL	0323W1	Jan-10
0002	BERKEY HALL	0002W1	
0003	OLIN MEMORIAL HEALTH CENTER	0003W1	
0027	PSYCHOLOGY BUILDING	0027W1	
0029	KEDZIE HALL (NORTH AND SOUTH)	0029W1	
0035	COMPUTER CENTER	0035W1	
		0055W2	
0059	MUNN, CLARENCE L., ICE ARENA	0059W1	
0060	CENTRAL SERVICES BUILDING	0060W1	
		0060W2	
0068	LAUNDRY BUILDING	0068W1	
0069	BRESLIN, JACK, STUDENT EVENTS CENTER	0069W1	
0080	BUSINESS COLLEGE COMPLEX (EPPELY)	0080W1	
0081	ENGINEERING BUILDING	0081W1	
		0081W2	
0084	COMMUNICATION ARTS & SCIENCES BUILDING	0084W1	
		0086W2	
0087	PUBLIC SAFETY	0087W1	
0132	ANTHONY HALL	0132W1	
		0132W2	
		0132W3	
		0132W4	
0178	PLANT BIOLOGY LABORATORIES	0178W1	
		0178W2	
0186	FOOD SAFETY AND TOXICOLOGY BUILDING	0186W1	
0189	REGIONAL CHILLED WATER PLANT NO. 1	0189W1	
0203A	ENGINEERING RESEARCH COMPLEX	0203W1	
	PAVILION FOR AGRICULTURE AND LIVESTOCK EDUCATION –		
0212A	HORSE BAR	0212W1	
		0303W1	
0317	SHAW HALL	0317W1	
0320	OWEN GRADUATE HALL	0320W1	
0330	HOLMES HALL	0330W1	
0446A	VETERINARY RESEARCH CENTER – LARGE ANIMAL BARN	0446W1	
		0446W2	

Table

32

Cont.

1121	MUSIC/MUSIC PRACTICE	1121W1
7000	FACULTY BRICK APARTMENTS	7000W1
77	FOOTBALL BUILDING	0077W1
85	WHARTON CENTER	0085W1
91	FARRALL AGRICULTURAL ENGINEERING HALL	0091W1

Table 33: MSU Supply Meters

MSU Supply Meters

Bldg	Complex
Num	Complex Bldg Name
1121	MUSIC/MUSIC PRACTICE
7000	FACULTY BRICK APARTMENTS
77	FOOTBALL BUILDING
91	FARRALL AGRICULTURAL ENGINEERING HALL
85	WHARTON CENTER
2000	CLINICAL CENTER
0055	KELLOGG CENTER
170	VETERINARY MEDICAL CENTER
0163	CHEMISTRY
0171	FOOD STORES
0177	PACKAGING
0128	NISBET, STEVEN S., BUILDING
0024	NATURAL SCIENCE
0027	PSYCHOLOGY BUILDING
0029	KEDZIE HALL (NORTH AND SOUTH)
0058	SPARTAN STADIUM
0060	CENTRAL SERVICES BUILDING
0068	LAUNDRY BUILDING
0080	BUSINESS COLLEGE COMPLEX (EPPLEY)
0214	RADIOLOGY BUILDING
0160	BIOMEDICAL- PHYSICAL SCIENCES BUILDING
0006	UNION BUILDING
0083	MSU COLLEGE OF LAW
0186	FOOD SAFETY AND TOXICOLOGY BUILDING
0446A	VETERINARY RESEARCH CENTER – LARGE ANIMAL BARN
0056	JENISON FIELDHOUSE
0059	MUNN, CLARENCE L., ICE ARENA
0002	BERKEY HALL
0003	OLIN MEMORIAL HEALTH CENTER
0005	HUMAN ECOLOGY
0013	MUSEUM
0028	GILTNER HALL
0035	COMPUTER CENTER
0069	BRESLIN, JACK, STUDENT EVENTS CENTER
0081	ENGINEERING BUILDING
0084	COMMUNICATION ARTS & SCIENCES BUILDING
0086	PLANT & SOIL SCIENCES BUILDING
0087	PUBLIC SAFETY

Table 33 Cont.

0132	ANTHONY HALL
0154	MANLY MILES BUILDING
0175	INTRAMURAL RECREATIVE SPORTS EAST
0178	PLANT BIOLOGY LABORATORIES
0189	REGIONAL CHILLED WATER PLANT NO. 1
0300	SNYDER AND PHILLIPS HALL
0305	LANDON HALL
0308	WILLIAMS HALL
0309	MARY MAYO HALL
0310	BUTTERFIELD HALL
0311	RATHER HALL
0312	BRYAN HALL
0313	BRODY HALL
0314	EMMONS HALL
0315	BAILEY HALL
0319	VANHOUSEN HALL
0203A	ENGINEERING RESEARCH COMPLEX
0302	MASON AND ABBOT HALL
0304	CAMPBELL HALL
0306	YAKELEY AND GILCHRIST HALL
0316	ARMSTRONG HALL
0317	SHAW HALL
0320	OWEN GRADUATE HALL
0323	WONDERS HALL
0330	HOLMES HALL
	PAVILION FOR AGRICULTURE AND LIVESTOCK EDUCATION – HORSE
0212A	BAR
0219	PARKING RAMP NO.1 SHAW LANE (NEW)
215	DCPAH
	State Control Lab
	Michigan State Police
	MSUFCU

Purchased Water Meters

618	James B. Henry Center
475A	Chemical Waste Facility #1 (Jolly Rd.)
475B	Chemical Waste Facility #2 (Jolly Rd.)
129	Entomology (Collings Rd.)
456O	Horse Research Center

Appendix E

Power Plant

Some parts of Appendix E are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix F

Chilled Water

Table 34: 2007-2008 Chilled Water Make-Up

Water Usage Per System 2008

BUILDING	KGAL
Comm Arts	6
Anthony - REFRIGERATION	74
CIPS Refrigeration	102
Clinical Center Refrigeration	105
Biochemistry Refrigeration	157
Natural Resources Refrigeration	169
Anthony - Dairy Plant Refrigeration	253
Olin Health Center Refrigeration	253
International Center	511
Administration Building - DATA PROCESSING	601
Kedzie Hall Absorption	684
Anthony - Meat Laboratory Refrigeration	837
Breslin Center Absorption	1,072
Administration Building	1,170
Cyclotron CT-1 Refrigeration	1,172
Regional Chilled Water Plant 10	1,197
Wells Hall Absorption	1,296
Bessey Hall Absorption	1,396
Munn Ice Arena Refrigeration	1,396
Union Building Absorption	1,573
Regional Chilled Water Plant 8	1,732
Regional Chilled Water Plant 7	1,992
Kellogg Center (East)	2,225
Engineering Absorption	2,696
Fee Hall Absorption	2,782
Regional Chilled Water Plant 9	2,898
DCPAH-Diagnostic Center for Population and Animal Health	3,385
Regional Chilled Water Plant 5	3,437
Erickson Hall Absorption	4,107
Library Absorption	4,524
Kellogg Center (West)	4,806
Anthony - ABSORPTION	5,424
Food Science Absorption	5,511
Regional Chilled Water Plant 4	5,675
Regional Chilled Water Plant 2	5,879

Table 34 Cont.	
Regional Chilled Water Plant 6	5,977
Regional Chilled Water Plant 3	6,077
Regional Chilled Water Plant 1	6,299
Biophysical Science	12,690
	102,139

GENERAL FUND

Water Usage Per System 2007

<u>Building</u>	<u>Gallons</u>
Comm Arts	9700
Anthony - REFRIGERATION	65070
CIPS Refrigeration	112150
Clinical Center Refrigeration	137380
Natural Resources Refrigeration	194150
Anthony - Dairy Plant Refrigeration	248400
Biochemistry Refrigeration	255170
Olin Health Center Refrigeration	306160
Administration Building - DATA PROCESSING	527670
Kedzie Hall Absorption	862400
Anthony - Meat Laboratory Refrigeration	1003940
Cyclotron CT-1 Refrigeration	1059370
Munn Ice Arena Refrigeration	1209220
Administration Building	1453400
International Center	1519100
Breslin Center Absorption	1560900
Bessey Hall Absorption	1754100
Union Building Absorption	1822600
Wells Hall Absorption	1953900
Erickson Hall Absorption	2002000
Kellogg Center (West)	2384000
Fee Hall Absorption	2973600
Chilled Water Plant 10	3012800

Table 34 Cont.	
Chilled Water Plant 5	3111500
Engineering Absorption	3327200
Chilled Water Plant 9	3349300
DCPAH	3648700
Chilled Water Plant 4	3959300
Chilled Water Plant 8	5126300
Chilled Water Plant 6	5757400
Kellogg Center (East)	6086400
Food Science Absorption	6967100
Anthony - ABSORPTION	7138900
Library Absorption	7780800
Chilled Water Plant 3	7924800
Chilled Water Plant 2	8526500
Chilled Water Plant 1	8683400
Biophysical Science	15303000
Chilled Water Plant 7	50426320
Total Water Used :	
	173,544,100

CHILLED WATER USAGE

99,877,620

Some parts of Appendix E are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix G

Irrigation

MICHIGAN STATE UNIVERSITY




Figure 10: Irrigation Proposed Zone Map




Figure 10 Cont.

MICHIGAN STATE UNIVERSITY




Figure 11: Campus Irrigation Map




Figure 11 Cont.

Table 35: Campus irrigation Sites

Irrigation Systems	Area	Water
Adams Field	Acad	River
Admin Bldg	Acad	River
Biomedical & Physical Sciences	Acad	Dom
Breslin	Acad	River
Clancie Lewis	Acad	Dom
Law Bldg.	Acad	Well
Grand River 1 & 2	Acad	Well
Kellogg	Acad	River
Plant Biology	Acad	Dom
Presidents House	Acad	River
Radiology	Acad	Dom
Shaw Lane	Acad	Well
Soil Science	Acad	Dom
Stud Serv Grdn	Acad	Dom
Toxicology	Acad	Dom
Wharton	Acad	Dom
Baseball	Athletic	River
Dem Hall	Athletic	River
Football Practice	Athletic	River

Table 35 Cont.

Munn Ice Arena	Athletic	River
Soccer	Athletic	River
Track	Athletic	River
Beal Gardens	Beal	River
Brody	Housing	River
Van Hoosen	Housing	Dom
IM East 'Fields'	IM	Well
Munn Field	IM	River
Lot 39	Park	Dom
Lot 40	Park	Dom
Lot 79	Park	River
Ramp 1	Park	Dom
Ramp 5	Park	Well

Some parts of Appendix G are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix H

Residence Halls

Table 36:Residence Hall Summary

Resident Hall	Enrollment	Cafeteria	Water Consumption	Per Capita	Water Consumption Estimates	Water Consumption Total Estimated	Estimates without cafeteria	Cafeteria Consumption
Akers	1250	Y	NA		29290.9857		25815.0320	
				25.2088210	4	29291	7	3476
Holmes	1179	Y	29721.2	3		29721	5	5372
					25283.9788		22283.5356	
Holden	1079	Y	NA		9	25284	8	3000
					24768.4575		21829.1911	
Hubbard	1057	Y	NA		4	24768	2	2939
					23034.4311		20300.9412	
Wilson	983	Y	NA		8	23034	2	2733
Wonders	908	Y	16860.8	18.569163		16861	18752.0393	-1891
					20667.7195		18215.0866	
McDonel	882	Y	NA		4	20668	3	2453
				20.2785964			17657.4819	
Shaw	855	Y	17338.2	9		17338	4	-319
					19636.6768			
Case	838	Y	NA		4	19637	17306.3975	2330
				16.5893203				
Mason/Abbot	618		10252.2	9		10252.2		
				17.2070187			12122.7390	
Syder/Phillips	587	Y	10100.52	4		10100.52	6	-2022
				35.3643493			11585.7863	
Owen	561	Y*	19839.4	8		19839.4	9	8254
Yakeley/Gilchrist	454	Y	10046	22.1277533		10046	9	670
Armstrong	446		10388.67	23.2929820		10388.67		

Table 36 Cont.			6				
Rather	424		5822.4	7	5822.4		
				31.1738095			
Emmons	420		13093	2	13093		
				35.6448687			
Bailey	419		14935.2	4	14935.2		
				32.4748743			
Bryan	398		12925	7	12925		
				12.9770588			
Butterfield	340		4412.2	2	4412.2		
				25.2738181		5679.30705	
Landon	275	Y	6950.3	8	6950.3	6	1271
				14.1147457			
Campbell	236		3331.08	6	3331.08		
				12.9497607			
Mayo	209		2706.5	7	2706.5		
				18.0036082			
Williams	194		3492.7	5	3492.7		
				16.2191780			
VanHoosen	73		1184	8	1184		
Average Per							
Capita without	20.6520256	8.20566698					
Cafeteria	6	6					
Average Per							
Capita with	23.4327885	6.09607705					
Cafeteria	9	9					
Total Water							
Consumption	336082						

Table 36 Cont.	
Total Cafeteria	
Consumption	28266

Sample Calculation

For McDonel Hall

Water consumption estimate= Enrollment * Average Per Capita with Cafeteria

Water Consumption = 882 Residents * 23.43 KGAL per Resident = 20668 KGAL

Some parts of Appendix H are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix I

Buildings

Sample Calculations for restroom savings

Estimated Water Savings for Vet Clinic = ((# of toilets * (3.5 gal/flush - 1.6 gal/flush) + # of urinals * (3 gal/flush - .125 gal/flush) + # of sinks * 2) * # of paper towel use * 3.0321 \$/KGAL/1000 KGAL)

Some parts of Appendix H are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

Appendix J

Miscellaneous

Calculations on how an updated RO system can save money.

Efficiency of RO system = 50%, Water Lost per 100 gallons= $1000 \times .5 = 500$ gal, Money lost per

1000 gal = $500 \times 3.0321 \text{ \$/1000 GAL} = \$1.52$ lost per 1000 per gal.

Table 37: RO System Information – RHS Residence Halls (Updated 7/21/10)

Hall	RO Location	Water/Ice Dispenser location (s)	Type of Ice Maker /Dispenser/Faucet	RO Removed, Date	Filter System Proposed
East Neighborhood					
Akers	C-38	West corridor	Drinking Fountain		CFS22, BEV145
Holmes	1st Floor East Comp Rm	East Lobby Alcove	Hoshizaki DCM-270BAH	Yes, 7/10	CFS22, ICE45-S
	1st floor West Comp Rm	West Lobby Alcove	Manitowoc SY0424A (floor unit)	Yes, 3/10	CFS22, ICE45-S
Hubbard	MR G-75	North 1 st floor corridor	Drinking Fountain Will be adding a Manitowoc SY042A (floor unit) in the North Laundry Room		CFS22, ICE45-S
Riverwalk Neighborhood					
McDonel	MR B-8-A	East Lobby Alcove	Hoshizaki DCM-270BAH		CFS22, ICE45-S
	MR 32 A	West Lobby Alcove	Hoshizaki DCM-270BAH		CFS22, ICE45-S
			*Both McDonel alcoves also have Coster water stations for filling large containers		
Owen	B1 Basement	West Elevator lobby – small room off lobby	Hoshizaki DCM-270BAH Plus sink with gooseneck faucet		CFS22, ICE45-S
Shaw	Room 106	Right of East Desk	Manitowoc SY0424A (floor unit)		CFS22, ICE45-S
Red Cedar Neighborhood					
Mason/Abbot	Storage by Kitchenette	New Kitchenette old cafeteria	Manitowoc SY0424A (floor unit)		CFS22, ICE45-S

Table 37 Cont.					CFS22, ICE45-S
Sny/Phi	MR W031	Phillips Main Lobby Vendor Alcove	Manitowoc SY0424A (floor unit)		
South Neighborhood					
Case	MR 46A	North Laundry North Lobby	Hoshizaki DCM-270BAH Faucet Fill in North Laundry Drinking fountain in North Lobby		CFS22, ICE45-S
Holden	MR A (inside MR G-48)	West Laundry	Manitowoc SY0424A (floor unit)		CFS22, ICE45-S
Wilson	1 st floor West W109	West Main Corridor	Faucet Fill		CFS22, BEV145
Wonders	B2 Basement (non-MR) (SS Storage)	North Laundry	Faucet Fill		CFS22, BEV145
Brody Neighborhood					
Armstrong	MR C-1	Main Lobby	Drinking Fountain		None—City Water
Bailey	MR C-1	Main Lobby	Drinking Fountain		None—City Water
Bryan	MR C-1	Main Lobby	Drinking Fountain		None—City Water
Butterfield	MR C-1	Main Lobby	Drinking Fountain		None—City Water
Emmons	MR C-1	Main Lobby	Drinking Fountain		None—City Water
Rather	MR C-1	Main Lobby	Drinking Fountain		None—City Water
West Circle Neighborhood					

Table 37 Cont. Campbell					CFS22, BEV145
	G-29	G-29	Direct to Water Dispenser		
Campbell	G-11	G-11	Direct to Water Dispenser		CFS22, BEV145
Gilchrist	W-3	W-3	Direct to Water Dispenser		CFS22, BEV145
Landon	G-11	G-11	Direct to Water Dispenser		CFS22, BEV145
Mayo	225	225	Bottle Fill		CFS22, BEV145
Mayo	239	239	Bottle Fill		CFS22, BEV145
Mayo	325	325	Bottle Fill		CFS22, BEV145
Mayo	339	339	Bottle Fill		CFS22, BEV145
Williams	C-3	C-3	Faucet in Kitchenette		CFS22, BEV145
Williams	C-12	C-12	Faucet in Kitchenette		CFS22, BEV145
Williams	211A	211A	Faucet in Kitchenette		CFS22, BEV145
Williams	261A	261A	Faucet in Kitchenette		CFS22, BEV145
Williams	311A	311A	Faucet in Kitchenette		CFS22, BEV145
Williams	361A	361A	Faucet in Kitchenette		CFS22, BEV145
Yakeley	E-53	E-53	Direct to Water Dispenser		CFS22, BEV145

Table 37 Cont. Yakeley	E-54	E-54	Direct to Water Dispenser	CFS22, BEV145
------------------------------	------	------	---------------------------	------------------

System Description and Costs

CFS22 & BEV145: This system is to be used in areas where there is no ice maker in place. It includes a 20" sediment filter and a single cartridge filter to provide purified water for consistent high quality taste and appearance. A one-time cost for the filter bracket and housing is \$250.54. The first set of filters will cost (CFS210-2 = \$41.70 and HF45 = \$69.44), for a total of \$111.14. The CFS210 will be replaced quarterly, while the HF45 will be replaced every 6 months. Annual filter replacement costs will be \$305.68 per system.

CFS22 & ICE45-S: This system is to be used in areas where there are ice makers in place. It includes a 20" sediment filter and a single cartridge filter to provide purified water for consistent high quality taste and appearance. In addition, the filter has a built-in scale inhibitor for equipment protection and clearer ice. A one-time cost for the filter bracket and housing is \$252.55. The first set

of filters will cost (CFS210-2 = \$41.70 and HF45-S = \$71.35), for a total of \$113.05. The CFS210 will be replaced quarterly, while the HF45-S will be replaced every 6 months. Annual filter replacement costs will be \$309.50 per system.

Installation: Installation costs will vary, based upon the complexity of the install (e.g., access, material required), but should not exceed \$150 per system.

NOTE: Red in Filter System column indicates that these filters have been installed.

Some parts of Appendix I are not listed in this report due to formatting difficulties. For a report with a complete Appendix please contact:

Susan Masten at masten@msu.edu

Ruth Kline-Robach at kliner@anr.msu.edu

Nathan Arnett at arnettn3@msu.edu

BIBLIOGRAPHY

BIBLIOGRAPHY

Amanda Groll, Michigan State University Power and Water Division, East Lansing MI. Interview. 2009

Ben Darling, Michigan State University Office of Land Management Division, East Lansing MI. Interview. 2009

Bob Ellerhorst, Michigan State University Power and Water Division, East Lansing MI. Interview. 2009

Crittenden, John C.; Trussell, R. Rhodes; Hand, David W.; Howe, Kerry J.; Tchobanoglous, George Water Treatment - Principles and Design (2nd Edition).. John Wiley & Sons.

Diane Barker, Michigan State University Residential and Hospitality Services Division, East Lansing MI. Interview. 2009

Gus Gosselin , , Michigan State University Physical Plant Division, East Lansing MI. Interview. 2009

Hanke, S. (1970), Demand for Water under Dynamic Conditions, Water Resour. Res., 6(5), 1253-1261.

Lahlou, Zacharia M. "Leak Detection and Water Loss Control." National Drinking Water Clearinghouse. Civil and Environmental Engineer, Wiley and Wilson, Lynchburg, VA

Lynda Boomer, Michigan State University Physical Plant Division, East Lansing MI. Interview. 2009

Michigan State University Physical Plant Division 2008-2009 Annual Report, October 29,2009.

Pat Curry, Michigan State University Maintenance Service Department, East Lansing MI. Interview. 2010.

Peralta, Alexandra, and Scott Swinton. *Cost and Returns Analysis of Library First Floor Restroom Renovation and Implications of Conservation Savings for MSU Facilities Replacement Scheduling*. Rep. no. Briefing Paper No.08-5. Print. Date?

Steve Frank, Michigan State University Landscape Services Division, East Lansing MI. Interview. 2009

Water audits and loss control programs. Denver, CO: American Water Works Association, 2009.

Satterfield, Zane, P. E., and Bhardwaj, Vipin "Water Meters." National Drinking Water Clearinghouse. 2004.